

KATTERJAKK, Sweden

WMO: 020200

Lat: 68.420N

Lon: 18.168E

Elev: 1696

StdP: 13.82

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.5	-10.6	-19.8	2.0	-14.8	-14.7	2.6	-10.2	34.6	25.3	31.2	21.4	2.5	210	0.810

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	69.1	56.9	65.1	55.2	61.5	53.3	58.5	66.3	56.5	63.1	54.6	60.3	7.3	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
55.1	68.9	61.0	53.1	63.9	59.0	51.4	59.9	57.3	26.1	66.4	24.8	63.2	23.6	60.2	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.7	24.3	20.6	-20.3	74.9	4.1	4.0	-23.2	77.7	-25.7	80.1	-28.0	82.3	-31.0	85.2		
(5)			-20.1	61.1	4.0	2.4	-23.0	62.8	-25.3	64.2	-27.6	65.6	-30.5	67.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	30.7	13.1	12.1	18.2	26.3	35.1	44.8	52.3	49.8	42.3	31.0	23.2	18.3		
	DBStd	15.98	12.20	12.09	9.59	7.38	6.33	6.15	6.12	5.61	5.77	6.97	8.16	10.39		
	HDD50	7280	1144	1062	987	712	463	180	45	72	239	588	805	983		
	HDD65	12541	1609	1482	1452	1162	926	605	395	472	682	1053	1255	1448		
	CDD50	217	0	0	0	0	2	25	117	66	7	0	0	0		
	CDD65	3	0	0	0	0	0	0	2	1	0	0	0	0		
	CDH74	22	0	0	0	0	0	0	19	3	0	0	0	0		
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0		
	WSAvg	7.3	7.3	7.1	8.9	7.7	7.6	7.2	6.6	6.3	6.9	6.9	6.7	8.0		
	PrecAvg	34.3	2.8	2.4	2.6	1.7	1.7	2.5	3.5	3.1	3.8	4.1	2.6	3.3		
(15) Precipitation	PrecMax	44.0	9.4	4.7	6.8	3.5	3.0	4.1	6.5	7.2	8.5	6.9	6.2	8.5		
	PrecMin	27.5	0.0	0.2	0.6	0.6	0.4	0.7	1.6	1.2	1.0	1.3	0.4	0.2		
	PrecStd	3.8	2.0	1.2	1.6	0.9	0.7	0.8	1.5	1.3	1.8	1.3	1.6	2.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.4	37.7	38.8	44.1	62.3	69.0	76.7	72.0	60.5	50.5	42.2	39.8		
		MCWB	35.5	35.4	34.5	38.0	49.7	54.5	61.1	58.3	51.9	44.9	39.9	36.4		
	2%	DB	35.6	34.7	36.0	40.9	51.7	63.5	70.9	67.2	56.7	45.3	39.4	36.8		
		MCWB	33.4	32.9	33.2	36.5	43.7	51.7	58.1	57.0	50.0	42.3	37.3	34.3		
	5%	DB	33.1	32.3	33.9	38.3	46.5	59.4	67.0	62.8	53.6	43.0	36.7	34.0		
		MCWB	31.6	30.9	31.8	34.9	40.5	49.8	56.4	55.0	48.9	40.9	34.6	31.7		
	10%	DB	29.4	29.0	31.4	36.2	43.3	55.5	63.2	59.1	50.8	40.4	33.7	31.8		
		MCWB	28.1	27.5	29.5	33.6	38.6	48.1	54.6	53.2	47.5	38.6	32.3	30.1		
	0.4%	WB	36.0	35.6	35.5	38.9	49.6	56.0	62.4	61.3	53.9	45.3	40.4	37.4		
		MCDB	37.6	36.9	37.2	42.7	61.2	64.0	73.5	67.9	57.7	47.9	41.5	38.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	33.9	33.2	33.7	37.0	44.3	53.5	59.7	57.7	51.3	42.6	37.7	34.5		
		MCDB	35.3	34.4	35.5	40.3	51.0	61.5	68.7	64.3	54.7	44.2	39.1	36.6		
	5%	WB	31.4	31.0	31.9	35.4	41.1	51.0	57.6	55.9	49.5	40.6	35.0	32.2		
		MCDB	33.0	32.4	33.9	37.8	45.6	57.9	65.2	62.0	52.7	42.4	36.6	33.7		
	10%	WB	28.2	27.8	29.5	33.8	39.1	48.6	55.7	53.9	47.7	38.6	32.4	30.1		
		MCDB	29.6	29.1	31.4	35.9	42.7	54.3	61.8	58.6	50.6	40.3	33.7	31.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.5	11.8	10.9	10.8	9.8	10.7	12.5	11.9	10.1	7.9	9.1	10.6		
		MCDBR	12.3	12.5	11.0	11.0	13.9	17.8	19.9	19.0	14.8	9.7	10.7	11.7		
		MCWBR	11.2	11.3	9.6	8.2	8.3	9.6	9.7	10.1	9.1	7.3	9.0	10.0		
		MCDBR	11.9	11.8	10.6	10.3	13.0	15.6	17.7	16.4	12.8	9.0	9.7	11.2		
	5% WB	MCWBR	11.0	11.2	9.5	7.9	8.3	9.3	9.7	9.4	8.4	7.4	8.6	10.1		
(40) Clear-Sky Solar Irradiance	taub		0.182	0.239	0.283	0.306	0.319	0.322	0.328	0.316	0.290	0.249	0.186	N/A		
	taud		1.905	2.084	2.146	2.206	2.293	2.414	2.489	2.508	2.538	2.219	1.951	N/A		
	Ebn at Noon		26	174	235	266	276	279	273	264	244	170	22	0		
	Edh at Noon		2	14	25	32	33	31	28	24	18	12	2	0		
(44) All-Sky Solar Radiation	RadAvg		9	120	523	1134	1559	1553	1421	1025	540	176	25	0		
	RadStd		1	19	56	68	115	159	141	92	49	27	2	0		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page