

STORA SJOFALLET, Sweden

WMO: 020240

Lat: 67.495N

Lon: 18.291E

Elev: 1394

StdP: 13.97

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.1	-13.7	-24.0	1.5	-18.1	-19.4	2.0	-13.7	54.9	30.5	49.8	29.6	11.0	130	0.967

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	71.8	58.4	67.6	56.6	64.0	55.3	60.3	68.7	58.3	65.3	56.4	62.4	9.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.7	72.2	63.2	54.8	67.4	61.7	53.0	63.0	59.9	27.2	68.9	25.9	65.5	24.6	62.8	66.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
46.3	39.1	33.7	-22.7	75.5	3.4	2.9	-25.2	77.6	-27.2	79.3	-29.1	80.9	-31.6	83.0
			-24.2	62.2	3.8	1.6	-27.0	63.4	-29.2	64.3	-31.3	65.2	-34.1	66.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	33.1	12.4	13.0	18.8	29.1	39.5	48.2	55.9	53.8	45.6	34.7	25.9	18.8
	DBStd	17.42	13.36	13.32	11.25	7.52	6.21	6.26	5.73	5.12	5.19	6.41	8.32	12.12
	HDD50	6583	1167	1037	968	627	332	109	10	19	147	476	724	967
	HDD65	11660	1632	1457	1433	1077	790	505	287	350	582	941	1174	1432
	CDD50	407	0	0	0	0	7	54	194	136	16	0	0	0
	CDD65	8	0	0	0	0	0	0	7	1	0	0	0	0
	CDH74	42	0	0	0	0	1	3	33	5	0	0	0	0
	CDH80	2	0	0	0	0	0	0	2	0	0	0	0	0
	WSAvg	15.8	17.1	17.6	16.6	14.7	15.3	16.8	15.0	13.3	15.3	15.9	15.1	16.6
	PrecAvg	29.7	2.4	1.8	1.7	1.5	2.0	3.0	4.0	3.4	2.7	2.4	2.4	2.4
(15) Precipitation	PrecMax	39.1	4.5	3.1	3.0	2.8	3.8	5.2	6.4	6.2	6.3	4.6	5.2	5.5
	PrecMin	20.6	0.3	0.3	0.7	0.4	0.6	1.0	1.0	1.3	0.9	0.6	0.9	0.7
	PrecStd	4.6	0.8	0.8	0.6	0.7	0.9	1.1	1.4	1.4	1.2	0.9	1.1	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.5	40.4	40.6	48.9	67.9	72.2	77.8	73.4	61.3	52.1	44.2	40.5
		MCWB	37.2	36.7	35.6	40.5	50.8	55.4	61.6	60.6	54.0	46.3	40.5	37.2
	2%	DB	37.3	37.3	38.3	44.4	58.0	65.7	73.5	68.8	57.1	48.7	42.0	37.7
		MCWB	34.6	34.4	34.8	38.5	47.3	53.1	59.4	58.0	51.0	44.4	39.4	34.9
	5%	DB	33.9	34.9	35.8	41.4	52.9	61.6	69.9	64.8	54.7	46.2	39.4	35.3
		MCWB	31.8	32.6	32.7	36.9	44.6	51.2	58.0	56.8	49.9	42.6	37.0	32.5
	10%	DB	30.0	31.6	33.2	38.9	48.8	58.4	65.8	62.0	52.9	43.5	36.3	33.1
		MCWB	28.4	30.0	30.7	35.0	42.2	49.8	56.4	55.0	48.7	40.5	34.1	30.9
	0.4%	WB	37.6	37.3	36.9	41.5	52.4	57.6	63.7	61.8	54.8	46.9	41.1	37.7
		MCDB	40.1	39.9	39.6	46.6	66.7	64.8	72.7	70.8	59.1	50.8	43.4	40.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	34.8	34.8	34.9	39.2	48.0	55.1	61.2	59.4	52.3	44.7	39.6	35.1
		MCDB	37.2	36.9	37.7	43.7	56.5	62.7	70.5	66.3	56.0	48.4	42.0	37.3
	5%	WB	32.2	32.5	33.0	37.3	45.3	52.7	59.6	57.7	50.7	42.9	37.2	32.8
		MCDB	34.3	34.6	35.6	41.3	52.4	60.3	67.7	64.0	53.9	46.1	39.3	34.9
	10%	WB	28.5	29.9	30.7	35.3	42.7	50.6	57.6	55.8	49.2	40.7	34.3	30.9
		MCDB	30.2	31.8	33.2	38.8	48.0	57.6	64.5	60.9	52.4	43.4	36.2	33.0
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	12.9	11.8	11.4	10.8	11.1	11.5	10.3	7.9	6.4	7.8	10.1
		MCDBR	11.8	14.5	11.0	12.2	19.0	17.6	18.7	16.0	11.2	8.4	9.3	9.8
		MCWBR	10.2	12.6	8.6	8.3	10.4	8.4	7.9	7.8	7.1	6.1	7.2	8.6
	5% WB	MCDBR	11.3	14.4	10.9	11.4	17.7	16.1	15.6	14.4	9.3	7.8	9.1	9.7
		MCWBR	9.9	12.6	8.9	7.9	10.4	9.0	7.5	7.6	6.5	5.9	7.1	8.8
(40) Clear-Sky Solar Irradiance	taub		0.173	0.235	0.276	0.303	0.320	0.325	0.334	0.320	0.289	0.253	0.177	N/A
	taud		1.924	2.128	2.190	2.222	2.339	2.469	2.489	2.508	2.561	2.286	1.960	N/A
	Ebn at Noon		53	190	244	269	278	279	273	265	249	182	46	0
	Edh at Noon		3	15	25	32	32	30	28	25	18	13	3	0
(44) All-Sky Solar Radiation	RadAvg		15	154	607	1228	1566	1582	1453	1071	571	194	35	0
	RadStd		1	17	39	63	132	136	151	107	66	30	3	0

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page