

NAIMAKKA, Sweden

WMO: 020550

Lat: 68.6762N

Lon: 21.5229E

Elev: 1319

StdP: 14.01

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -28.6	(c) -23.8	(d) -35.0	(e) 0.8	(f) -28.2	(g) -29.6	(h) 1.1	(i) -23.4	(j) 26.5	(k) 27.9	(l) 23.2	(m) 26.2	(n) 2.6	(o) 260	(p) 0.784

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.8	72.6	58.9	68.3	57.1	64.3	55.1	61.0	69.0	58.8	65.7	56.7	62.5	7.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.8	74.8	63.6	55.7	69.3	61.4	53.6	64.2	59.6	27.7	69.4	26.2	65.3	24.8	62.4	67.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 22.6	(b) 18.4	(c) 15.6	(e) -37.6	(f) 76.6	(g) 5.3	(h) 3.2	(i) -41.4	(j) 78.9	(k) -44.5	(l) 80.7	(m) -47.4	(n) 82.5	(o) -51.2	(p) 84.8		
(a) 22.6	(b) 18.4	(c) 15.6	(e) -36.9	(f) 63.2	(g) 4.6	(h) 2.3	(i) -40.2	(j) 64.9	(k) -42.9	(l) 66.2	(m) -45.5	(n) 67.5	(o) -48.8	(p) 69.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.5	5.3	6.0	15.3	25.5	37.4	46.9	54.3	50.3	41.9	28.9	16.1	11.9
	DBStd	19.75	15.20	15.01	11.35	8.36	6.97	5.96	5.79	5.89	6.27	8.83	12.32	14.79
	HDD50	8142	1385	1232	1074	735	393	129	22	68	251	654	1017	1182
	HDD65	13337	1850	1652	1539	1185	854	542	334	456	692	1119	1467	1647
	CDD50	283	0	0	0	0	3	38	156	78	8	0	0	0
	CDD65	3	0	0	0	0	0	0	2	1	0	0	0	0
	CDH74	68	0	0	0	0	0	5	52	11	0	0	0	0
	CDH80	4	0	0	0	0	0	0	4	0	0	0	0	0
(14) Wind	WSAvg	6.5	6.0	6.3	7.7	6.9	7.4	7.9	6.4	5.7	6.3	6.1	5.3	6.3
(15) Precipitation	PrecAvg	17.5	1.0	0.9	0.9	0.7	1.1	2.0	3.1	2.4	1.7	1.5	1.1	1.0
	PrecMax	22.9	1.9	2.2	1.9	1.8	3.7	4.0	8.0	4.2	3.7	3.1	2.3	3.1
	PrecMin	12.3	0.2	0.2	0.2	0.0	0.0	0.0	1.0	0.9	0.4	0.5	0.1	0.2
	PrecStd	2.9	0.4	0.6	0.6	0.5	0.8	1.0	1.4	0.8	0.9	0.8	0.6	0.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.5	40.1	40.6	50.1	66.6	72.0	79.0	75.2	62.2	50.5	41.8	41.0
		MCWB	35.5	36.8	35.4	42.6	51.4	56.8	61.6	60.4	52.6	45.6	39.0	37.3
	2%	DB	34.6	34.8	37.5	43.9	58.8	66.1	74.5	69.7	58.0	46.9	38.3	37.9
		MCWB	31.9	31.8	33.8	38.3	48.3	53.5	59.9	58.9	51.3	43.4	36.2	35.0
	5%	DB	30.0	31.3	34.6	40.5	52.9	61.7	70.7	65.0	55.0	44.4	34.5	34.1
		MCWB	28.0	29.0	31.4	35.6	44.3	51.5	58.4	56.7	49.9	41.4	32.7	31.5
	10%	DB	26.3	27.5	31.5	38.1	48.8	58.3	66.5	61.5	52.3	41.4	31.9	31.1
		MCWB	24.8	25.7	28.7	34.0	42.4	49.7	57.1	54.7	48.2	38.9	30.6	29.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.2	37.1	36.3	42.6	53.3	61.2	64.3	63.2	54.8	46.5	39.3	37.8
		MCDB	38.7	40.3	39.7	49.7	65.1	69.5	74.0	72.0	59.0	49.5	41.3	40.6
	2%	WB	32.2	32.0	34.0	38.8	48.3	56.3	61.8	60.0	52.6	43.7	36.3	35.1
		MCDB	34.4	34.7	37.2	43.6	57.1	62.1	70.9	66.4	56.7	46.7	38.2	38.0
	5%	WB	28.3	29.2	31.4	36.0	45.1	53.3	59.9	57.9	50.7	41.6	33.0	31.8
		MCDB	30.1	31.4	34.3	39.8	51.9	59.8	67.9	63.7	53.9	44.3	34.4	33.8
	10%	WB	24.9	25.8	28.9	34.2	42.8	50.9	58.0	55.6	48.8	38.9	30.8	29.3
		MCDB	26.6	27.5	31.3	37.6	48.3	56.9	65.0	60.5	51.8	41.2	31.9	31.1
(35) Mean Daily Temperature Range	5% DB	MDBR	17.7	18.7	19.3	17.4	13.8	14.5	16.8	16.7	13.9	11.8	15.6	17.1
		MCDBR	17.2	17.3	16.2	17.0	22.8	21.9	25.0	23.9	18.7	13.3	14.5	13.4
		MCWBR	15.6	15.4	14.3	12.6	13.5	11.5	12.3	13.9	12.4	10.1	13.2	11.7
	5% WB	MCDBR	17.0	17.0	15.3	15.4	21.4	18.8	21.0	21.2	15.4	12.3	13.7	12.9
		MCWBR	15.8	15.4	13.6	11.5	13.2	10.7	11.3	12.9	10.7	10.0	12.6	11.7
(40) Clear-Sky Solar Irradiance	taub		0.177	0.233	0.275	0.302	0.321	0.326	0.332	0.318	0.287	0.248	0.179	N/A
	taud		1.916	2.090	2.183	2.215	2.359	2.490	2.494	2.511	2.559	2.270	1.964	N/A
	Ebn at Noon		23	175	239	266	276	278	272	263	245	171	20	0
	Edh at Noon		2	14	24	32	31	29	28	24	17	11	2	0
(44) All-Sky Solar Radiation	RadAvg		8	140	608	1241	1606	1568	1455	1036	560	179	25	0
	RadStd		1	12	26	55	137	119	131	78	56	23	3	0

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page