

SAITTAROVA, Sweden

WMO: 020640

Lat: 67.3363N

Lon: 22.2288E

Elev: 240

StdP: 98.47

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.6	-26.2	-33.3	0.2	-29.5	-29.5	0.3	-26.0	9.4	-2.4	8.4	-2.2	0.4	350	0.691

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.3	24.3	16.2	22.4	15.3	20.5	14.5	17.8	22.6	16.5	20.5	15.4	19.0	2.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	11.7	19.4	14.8	10.8	18.0	13.8	10.1	17.0	51.1	22.8	47.1	20.4	43.8	19.1	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	6.8	5.9	-32.3	26.3	3.1	2.3	-34.5	27.9	-36.3	29.3	-38.0	30.6	-40.2	32.2		
(5)			-32.7	19.1	2.8	1.4	-34.7	20.1	-36.3	20.9	-37.9	21.7	-39.9	22.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.9	-11.9	-11.3	-5.9	0.2	6.3	11.5	15.0	12.6	7.6	0.3	-6.2	-8.7		
	DBStd	10.58	7.42	7.56	5.30	3.77	4.22	3.73	3.31	3.24	3.31	4.45	5.90	6.82		
	HDD10.0	3689	681	597	493	293	132	26	2	12	86	299	487	580		
	HDD18.3	6394	939	831	752	543	374	207	114	178	322	558	737	838		
	CDD10.0	350	0	0	0	0	16	71	156	93	14	0	0	0		
	CDD18.3	13	0	0	0	0	0	2	9	2	0	0	0	0		
	CDH23.3	103	0	0	0	0	4	17	70	11	0	0	0	0		
	CDH26.7	11	0	0	0	0	0	2	8	0	0	0	0	0		
(14) Wind	WSAvg	2.5	2.1	2.3	2.9	2.7	2.8	2.7	2.4	2.3	2.6	2.4	2.0	2.4		
(15) Precipitation	PrecAvg	567	35	28	30	29	43	65	84	69	50	48	45	40		
	PrecMax	717	59	56	72	73	79	119	140	115	145	115	78	121		
	PrecMin	403	5	7	6	4	8	8	30	29	18	19	13	7		
	PrecStd	97	14	14	16	17	19	31	29	27	32	23	20	25		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.2	5.6	7.3	14.5	23.7	25.4	27.7	24.8	18.0	11.3	6.6	5.0		
		MCWB	2.6	2.8	3.1	7.5	13.0	17.3	18.2	17.9	13.1	8.2	4.8	2.9		
	2%	DB	1.4	2.8	4.8	10.1	20.4	22.5	25.2	22.3	15.7	9.4	4.6	2.8		
		MCWB	0.1	0.6	1.6	4.9	12.3	14.1	16.9	16.2	11.9	7.5	3.4	1.2		
	5%	DB	-0.3	0.7	3.1	8.2	16.4	20.3	23.3	20.4	14.2	8.0	2.5	1.1		
		MCWB	-1.2	-0.8	0.7	3.9	10.0	12.7	16.2	15.5	11.4	6.4	1.7	-0.1		
	10%	DB	-2.2	-1.0	1.4	6.3	13.4	18.2	21.2	18.1	12.7	6.3	0.7	-0.1		
		MCWB	-2.9	-2.0	-0.7	2.7	8.1	12.1	15.4	14.1	10.5	5.1	0.1	-0.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.7	3.2	3.2	7.6	14.4	18.1	19.5	19.4	14.0	9.0	5.4	3.0		
		MCDB	4.2	5.4	6.7	13.3	21.4	24.5	24.0	23.5	15.9	10.1	5.9	4.7		
	2%	WB	0.2	0.7	1.9	5.5	12.5	15.5	18.2	17.2	12.9	7.7	3.3	1.4		
		MCDB	1.0	2.4	4.4	9.5	19.1	19.6	23.5	20.7	15.0	9.3	4.5	2.7		
	5%	WB	-1.2	-0.8	0.8	4.1	10.3	13.9	17.1	15.9	11.8	6.6	1.8	0.2		
		MCDB	-0.3	0.5	2.8	7.5	15.7	18.3	21.4	19.2	13.6	7.9	2.5	0.9		
	10%	WB	-2.9	-2.0	-0.4	2.9	8.6	12.7	16.0	14.7	10.9	5.3	0.2	-0.8		
		MCDB	-2.2	-1.0	1.2	6.1	12.8	17.1	19.9	17.5	12.4	6.4	0.6	0.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.1	7.3	8.0	7.7	8.2	8.0	8.3	7.9	6.7	5.1	5.7	6.9		
		MCDBR	7.5	7.9	8.3	9.9	13.1	11.2	11.1	10.9	8.8	6.4	5.6	6.2		
	5% WB	MCWBR	7.0	6.7	6.1	6.0	6.8	5.3	5.2	5.7	5.7	5.0	5.0	5.6		
		MCWBR	7.4	7.4	7.7	9.2	12.0	9.7	9.7	9.3	7.4	6.1	5.4	5.7		
(40) Clear-Sky Solar Irradiance	taub		0.184	0.248	0.283	0.314	0.332	0.337	0.345	0.329	0.299	0.271	0.343	N/A		
	taud		1.933	2.124	2.214	2.258	2.464	2.487	2.479	2.507	2.566	2.372	2.765	N/A		
	Ebn at Noon		164	580	765	840	867	870	849	826	774	570	204	0		
	Edh at Noon		11	48	78	99	91	92	90	78	58	39	14	0		
(44) All-Sky Solar Radiation	RadAvg		0.05	0.55	2.06	3.95	4.82	5.08	4.76	3.47	1.88	0.65	0.11	0.00		
	RadStd		0.00	0.07	0.14	0.18	0.47	0.36	0.47	0.27	0.25	0.11	0.01	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page