

PARKALOMPOLO, Sweden

WMO: 020720

Lat: 67.7301N

Lon: 22.8219E

Elev: 313

StdP: 97.62

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.6	-27.2	-33.9	0.2	-29.7	-30.8	0.2	-27.2	6.3	-4.8	5.6	-5.4	0.1	340	0.710

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	23.9	15.3	21.8	14.7	19.8	13.7	17.2	21.8	15.8	19.8	14.7	18.2	2.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.4	11.4	18.5	14.1	10.4	17.3	13.0	9.7	16.0	49.5	22.2	45.4	19.9	42.0	18.3	21.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.4	5.5	5.0	-33.3	25.6	3.3	2.3	-35.7	27.3	-37.7	28.7	-39.5	30.0	-41.9	31.6		
			-33.5	18.2	3.3	1.3	-35.8	19.1	-37.7	19.9	-39.6	20.6	-41.9	21.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.5	-13.0	-13.1	-7.7	-1.3	5.1	10.4	13.8	11.3	6.3	-1.3	-7.5	-10.2	(6)
(7)		DBStd	10.67	6.91	7.12	5.45	4.10	4.27	3.80	3.44	3.49	3.59	4.90	6.01	6.68	(7)
(8)		HDD10.0	4106	712	646	550	338	164	40	7	27	121	349	524	628	(8)
(9)		HDD18.3	6891	971	879	808	588	410	239	146	219	362	608	774	886	(9)
(10)		CDD10.0	263	0	0	0	0	13	52	123	67	8	0	0	0	(10)
(11)		CDD18.3	7	0	0	0	0	0	1	5	1	0	0	0	0	(11)
(12)		CDH23.3	78	0	0	0	0	4	13	52	8	0	0	0	0	(12)
(13)		CDH26.7	6	0	0	0	0	0	2	4	0	0	0	0	0	(13)
(14)	Wind	WSAvg	2.1	1.2	1.5	2.4	2.4	2.7	2.8	2.5	2.2	2.3	2.1	1.6	1.5	(14)
(15)	Precipitation	PrecAvg	536	35	27	28	27	39	60	77	64	51	47	43	37	(15)
(16)		PrecMax	729	68	51	68	69	76	118	128	110	136	98	84	98	(16)
(17)		PrecMin	357	6	4	5	8	6	6	22	21	14	15	12	3	(17)
(18)		PrecStd	93	13	13	15	16	19	29	31	24	30	21	20	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.5	3.6	6.2	12.8	23.7	24.9	27.2	24.5	16.8	10.0	5.2	3.2	(19)
(20)		MCWB	0.5	1.5	2.2	6.3	11.8	16.6	17.6	17.5	12.4	7.9	4.6	1.6	(20)	
(21)		2%	DB	-0.5	1.1	3.7	9.1	19.8	22.0	24.7	21.7	14.9	8.2	2.6	0.6	(21)
(22)		MCWB	-0.9	-0.4	0.9	4.5	11.6	13.4	16.0	15.6	11.6	7.1	1.9	0.0	(22)	
(23)		5%	DB	-1.9	-1.4	1.7	7.1	15.8	19.7	22.8	19.7	13.3	6.8	0.8	-0.3	(23)
(24)		MCWB	-2.2	-2.1	-0.3	3.3	9.4	12.2	15.5	14.6	10.9	6.0	0.5	-0.6	(24)	
(25)		10%	DB	-3.7	-3.1	0.0	5.3	12.4	17.5	20.5	17.5	12.0	5.1	-0.1	-1.3	(25)
(26)		MCWB	-4.0	-3.7	-1.3	2.0	7.2	11.3	14.8	13.5	10.2	4.4	-0.3	-1.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.7	1.9	2.5	6.7	13.7	17.5	19.1	18.7	13.6	8.5	4.7	1.7	(27)
(28)		MCDWB	1.1	3.4	5.7	11.6	20.5	23.7	23.4	22.2	15.2	9.1	5.0	2.8	(28)	
(29)		2%	WB	-0.8	-0.3	1.2	4.8	11.8	14.5	17.6	16.6	12.5	7.2	2.0	0.2	(29)
(30)		MCDWB	-0.6	1.0	3.2	8.2	19.0	18.7	22.5	20.0	13.9	8.1	2.4	0.6	(30)	
(31)		5%	WB	-2.3	-1.9	0.0	3.5	9.7	13.0	16.5	15.3	11.4	5.9	0.5	-0.6	(31)
(32)		MCDWB	-2.0	-1.2	1.4	6.7	15.1	17.8	21.0	18.6	12.7	6.8	0.8	0.8	-0.3	(32)
(33)		10%	WB	-4.0	-3.6	-1.2	2.3	7.9	12.0	15.3	14.0	10.5	4.5	-0.3	-1.7	(33)
(34)		MCDWB	-3.7	-3.0	-0.1	5.1	11.8	16.7	19.3	16.8	11.8	5.1	-0.1	-1.3	(34)	
(35)	Mean Daily Temperature Range		MDBR	7.5	8.4	9.8	8.8	8.5	8.6	9.1	9.1	7.8	6.2	6.5	7.4	(35)
(36)		5% DB	MCDBR	7.1	7.4	9.6	10.2	13.8	12.3	12.4	12.3	9.3	6.8	4.8	6.0	(36)
(37)		MCWBR	7.0	6.7	7.4	6.5	7.3	6.0	5.9	6.9	6.4	5.7	4.7	5.8	(37)	
(38)		5% WB	MCDBR	6.9	7.3	8.3	9.4	12.7	10.0	10.7	10.5	7.4	6.4	4.8	5.7	(38)
(39)		MCWBR	6.9	6.7	6.7	6.1	7.3	5.6	5.9	6.2	5.4	5.5	4.7	5.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.182	0.243	0.279	0.309	0.327	0.333	0.340	0.325	0.295	0.264	0.347	N/A	(40)	
(41)		taud	1.925	2.109	2.207	2.237	2.446	2.492	2.485	2.509	2.567	2.351	2.788	N/A	(41)	
(42)		Ebn at Noon	136	571	764	841	870	872	852	828	773	563	184	0	(42)	
(43)		Edh at Noon	10	47	77	100	92	91	89	78	57	38	13	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.04	0.53	2.06	4.00	4.85	5.04	4.71	3.42	1.84	0.62	0.10	0.00	(44)	
(45)		RadStd	0.00	0.06	0.12	0.17	0.47	0.34	0.46	0.25	0.23	0.10	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page