

PAJALA, Sweden

WMO: 020950

Lat: 67.2036N

Lon: 23.3899E

Elev: 537

StdP: 14.41

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.5	-21.4	-32.2	0.9	-26.4	-26.5	1.3	-21.3	18.3	24.4	16.1	24.0	1.7	340	0.688

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	77.3	61.5	73.6	59.9	69.9	58.1	63.9	72.7	61.9	69.7	59.9	67.1	6.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.9	81.5	66.5	58.6	75.0	64.6	56.7	69.8	62.6	29.5	72.6	27.9	69.8	26.6	67.1	71.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.4	13.2	11.7	-31.6	80.7	5.4	3.4	-35.5	83.2	-38.7	85.2	-41.7	87.2	-45.7	89.7		
(5)			-31.8	66.8	5.4	2.8	-35.7	68.8	-38.8	70.5	-41.9	72.1	-45.8	74.1	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	31.8	8.0	9.0	19.3	30.8	41.8	51.9	58.2	52.8	44.2	32.0	19.3	12.8		
	DBStd	19.99	14.53	14.85	10.78	7.74	7.28	6.33	5.93	6.35	6.66	8.87	12.39	14.20		
	HDD50	7182	1302	1147	953	577	273	50	6	43	198	557	922	1154		
	HDD65	12134	1767	1567	1418	1027	721	395	223	380	623	1022	1372	1619		
	CDD50	539	0	0	0	0	18	108	259	130	24	0	0	0		
	CDD65	16	0	0	0	0	0	2	11	3	0	0	0	0		
	CDH74	279	0	0	0	0	9	50	184	36	0	0	0	0		
	CDH80	29	0	0	0	0	0	6	21	2	0	0	0	0		
	WSAvg	5.0	4.2	4.5	5.7	5.4	6.0	6.0	5.3	4.9	5.0	4.7	4.1	4.4		
	PrecAvg	22.1	1.6	1.2	1.2	1.2	1.5	2.3	3.3	2.7	1.9	1.8	1.9	1.6		
(15) Precipitation	PrecMax	28.3	2.6	2.5	2.4	2.8	2.8	3.8	6.8	6.0	4.5	3.7	3.3	3.7		
	PrecMin	16.5	0.2	0.2	0.4	0.2	0.2	0.3	1.1	0.9	0.6	0.8	0.7	0.3		
	PrecStd	3.6	0.6	0.6	0.6	0.7	0.7	0.9	1.5	1.2	1.1	0.8	0.8	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.3	41.0	45.6	57.1	74.6	80.6	82.9	78.1	65.4	52.3	42.9	39.3		
		MCWB	34.2	36.8	37.9	45.5	56.9	61.4	64.5	64.2	55.2	48.1	41.7	36.4		
	2%	DB	33.1	35.7	41.1	50.5	67.6	73.8	78.7	73.3	61.7	49.4	38.7	34.8		
		MCWB	31.5	32.8	35.3	40.8	53.1	57.9	62.3	61.2	53.2	46.5	37.0	33.4		
	5%	DB	31.0	32.4	37.7	46.6	60.7	69.3	75.5	69.1	58.7	46.8	35.7	33.0		
		MCWB	30.0	30.9	33.0	38.7	48.8	55.6	60.9	59.2	52.6	44.5	34.8	32.1		
	10%	DB	27.9	29.8	34.4	42.9	56.2	65.0	71.9	65.1	55.8	43.9	33.7	31.6		
		MCWB	26.9	28.5	31.0	36.2	46.4	53.2	59.8	57.1	51.5	41.8	33.0	30.9		
	0.4%	WB	34.8	37.3	38.6	45.8	57.7	64.1	67.5	66.6	57.9	50.0	42.0	36.4		
		MCDB	36.2	41.1	44.6	56.9	71.6	75.7	76.5	74.8	61.5	51.1	42.4	38.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	32.0	33.3	35.7	41.3	54.1	60.5	64.9	62.9	55.4	47.1	37.4	33.7		
		MCDB	32.9	35.1	40.1	49.1	65.3	69.6	74.2	70.5	59.3	48.8	38.4	34.5		
	5%	WB	30.0	31.1	33.6	39.1	50.3	57.3	63.0	60.5	53.7	44.7	35.0	32.3		
		MCDB	30.9	32.3	36.9	45.8	58.7	65.2	71.0	66.4	57.3	46.5	35.6	32.9		
	10%	WB	26.9	28.4	31.6	36.9	47.4	54.9	61.1	58.5	51.9	42.0	33.2	30.8		
		MCDB	27.9	29.8	34.1	42.1	54.9	62.9	69.0	63.7	55.1	43.8	33.6	31.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.0	16.6	20.5	17.9	17.8	16.9	19.1	18.9	16.1	11.5	12.5	14.3		
		MCDBR	13.5	13.1	19.0	22.0	28.6	25.4	26.8	25.7	21.4	13.1	9.7	11.2		
		MCWBR	13.0	11.9	14.4	13.8	15.9	12.1	12.9	14.7	14.3	10.5	9.2	10.6		
		MCDBR	13.6	13.1	16.5	20.7	25.8	20.7	22.9	21.7	16.7	11.1	8.6	11.2		
	5% WB	MCWBR	13.2	11.7	12.8	13.3	15.2	11.5	13.0	13.1	11.8	9.5	8.3	10.7		
(40) Clear-Sky Solar Irradiance	taub		0.190	0.254	0.288	0.320	0.336	0.341	0.350	0.334	0.305	0.277	0.345	N/A		
	taud		1.932	2.112	2.198	2.243	2.450	2.479	2.467	2.495	2.555	2.363	2.723	N/A		
	Ebn at Noon		52	181	240	264	274	275	267	260	243	179	63	0		
	Edh at Noon		4	16	25	32	30	30	29	25	19	13	4	0		
(44) All-Sky Solar Radiation	RadAvg		18	179	660	1253	1523	1622	1520	1111	599	208	37	0		
	RadStd		1	25	49	61	152	115	148	85	79	36	4	0		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page