

STEKENJOKK, Sweden

WMO: 021020

Lat: 65.0929N

Lon: 14.5055E

Elev: 3399

StdP: 12.98

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.0	-1.5	-12.6	3.2	-4.9	-6.7	4.4	-0.7	73.9	25.6	65.3	26.6	18.0	100	1.096

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	65.7	54.5	62.4	53.0	59.4	51.8	56.5	62.0	54.6	59.6	52.8	57.7	12.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
54.2	70.8	58.3	52.2	65.8	56.4	50.2	61.1	54.6	25.5	61.8	24.2	59.8	23.1	57.6	66.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 56.2	48.1	41.7	DB	-9.7	69.1	5.0	4.7	-13.3	72.4	-16.2	75.2	-19.0	77.8	-22.6	81.2	(4)
(5)			WB	-9.7	59.0	5.1	3.7	-13.3	61.7	-16.3	63.8	-19.2	65.9	-22.9	68.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	29.8	15.3	15.0	17.9	25.7	34.5	42.0	49.7	47.2	38.9	29.1	22.2	18.8		
	DBStd	14.01	8.26	8.74	7.11	6.46	7.66	7.37	7.25	6.45	5.74	6.42	7.35	7.74		
	HDD50	7540	1077	980	994	729	485	261	98	134	334	647	834	967		
	HDD65	12852	1542	1400	1459	1179	945	690	476	551	782	1112	1284	1432		
	CDD50	165	0	0	0	0	5	21	88	49	2	0	0	0		
	CDD65	2	0	0	0	0	0	0	2	0	0	0	0	0		
	CDH74	1	0	0	0	0	0	0	1	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	19.0	22.6	21.9	21.4	18.1	16.3	16.3	14.8	15.1	18.3	19.6	20.3	23.9		
	PrecAvg	30.7	3.2	2.9	2.2	1.4	1.4	2.5	3.5	3.1	2.5	2.6	2.3	3.1		
(15) Precipitation	PrecMax	38.5	6.2	7.9	5.7	3.1	2.5	4.4	7.6	6.5	4.1	4.6	5.9	5.7		
	PrecMin	22.9	0.4	0.3	0.4	0.4	0.5	0.6	1.6	0.9	0.7	1.4	0.5	0.9		
	PrecStd	4.5	1.7	2.0	1.3	0.7	0.6	1.0	1.5	1.5	1.0	0.8	1.4	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.4	33.8	37.1	45.4	60.8	66.9	72.1	66.6	57.4	45.5	44.0	33.6		
		MCWB	30.7	31.4	30.2	38.4	48.9	52.6	58.7	55.5	48.0	43.7	34.6	32.8		
	2%	DB	30.8	30.9	31.8	41.8	53.8	61.7	67.7	63.3	52.5	42.0	38.1	32.0		
		MCWB	30.2	30.1	30.7	35.8	45.6	50.3	55.6	54.1	48.4	39.6	36.3	31.6		
	5%	DB	28.6	28.6	29.8	37.2	50.3	57.5	64.1	60.3	49.3	39.9	33.7	30.0		
		MCWB	28.0	28.1	29.4	32.7	43.1	48.7	54.5	52.9	46.7	38.3	32.9	29.8		
	10%	DB	26.3	26.2	27.9	34.4	46.3	53.5	60.9	57.3	46.6	38.1	31.3	28.3		
		MCWB	25.7	25.7	27.4	31.6	41.7	46.7	52.7	52.3	44.9	37.0	31.0	28.0		
	0.4%	WB	32.0	32.3	32.7	39.2	50.2	54.7	60.7	57.9	51.9	43.7	39.1	33.3		
		MCDB	32.1	32.4	33.4	44.2	58.8	60.9	69.8	62.4	53.6	44.5	39.4	33.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	30.4	30.4	30.7	36.4	47.5	51.3	57.5	56.0	49.2	40.5	35.1	31.6		
		MCDB	30.6	30.5	31.1	40.2	53.1	58.9	64.1	60.6	51.3	41.2	37.9	31.7		
	5%	WB	28.1	28.1	29.2	33.9	44.7	49.5	55.5	54.1	47.2	38.9	32.7	29.7		
		MCDB	28.3	28.4	29.8	35.7	48.8	55.9	60.8	59.0	49.2	39.4	33.7	29.8		
	10%	WB	25.8	25.7	27.4	32.2	41.8	47.4	53.7	52.4	45.3	37.1	30.9	28.0		
		MCDB	26.3	26.3	28.2	33.7	46.8	52.6	58.8	56.9	46.8	37.6	31.5	28.2		
	5% DB	MDBR	7.1	7.7	7.4	7.1	8.5	10.4	10.6	8.9	7.2	5.6	5.9	6.3		
		MCDBR	7.8	8.4	8.0	8.6	12.4	14.3	13.7	10.9	10.9	7.3	6.8	6.9		
		MCWBR	7.8	8.2	7.8	6.0	8.0	7.8	6.5	5.9	7.5	6.3	6.3	7.1		
		MCWBR	7.6	8.4	7.9	7.4	11.7	12.6	12.0	10.3	9.5	6.5	6.5	6.9		
(35) Mean Daily Temperature Range	5% WB	MCWBR	7.7	8.4	7.8	5.8	8.4	7.8	6.8	6.5	7.4	6.2	6.3	7.1		
	taub		0.162	0.233	0.262	0.289	0.297	0.300	0.309	0.297	0.277	0.253	N/A	0.165		
		taud	1.923	2.202	2.252	2.270	2.394	2.531	2.530	2.549	2.590	2.420	N/A	1.933		
(42) Clear-Sky Solar Irradiance	Ebn at Noon		121	218	263	281	290	292	285	279	263	213	N/A	35		
		Edh at Noon	7	16	25	32	31	28	28	24	19	13	N/A	2		
	RadAvg		34	180	614	1195	1496	1567	1466	1095	600	228	57	11		
(44) All-Sky Solar Radiation	RadStd		3	37	73	98	113	136	178	114	75	27	8	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page