

HEMAVAN-GIEREVARTO, Sweden

WMO: 021030

Lat: 65.7813N

Lon: 15.0623E

Elev: 2602

StdP: 13.37

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.1	-2.6	-11.7	3.2	-5.4	-7.3	4.1	-0.8	46.7	29.0	41.8	25.3	16.3	140	0.909

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	68.3	56.4	64.7	55.0	61.3	53.3	58.5	64.9	56.3	62.1	54.3	59.7	9.8	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.8	72.9	61.0	53.6	67.4	59.0	51.5	62.3	56.5	26.5	65.0	25.1	62.2	23.8	60.0	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 38.0	32.6	28.7		-10.2	71.8	6.0	3.9	-14.5	74.6	-18.1	76.9	-21.5	79.1	-25.9	81.9	
(5)			DB	-9.3	60.0	7.7	2.1	-14.8	61.5	-19.3	62.7	-23.6	63.9	-29.1	65.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	31.8	16.7	15.9	19.4	28.2	36.5	45.2	51.9	49.3	41.6	31.3	24.4	19.7
	DBStd	14.50	9.32	9.71	7.87	5.99	7.18	7.54	6.70	6.07	5.79	6.36	7.16	8.70
	HDD50	6892	1033	954	948	654	425	188	57	89	256	578	769	941
	HDD65	12132	1498	1374	1413	1104	882	595	409	488	701	1043	1219	1406
	CDD50	239	0	0	0	0	8	43	116	66	6	0	0	0
	CDD65	3	0	0	0	0	0	0	3	0	0	0	0	0
	CDH74	8	0	0	0	0	0	0	8	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	13.0	14.8	14.6	14.5	13.0	12.7	12.0	10.9	10.8	12.9	13.3	12.7	14.3
Precipitation	PrecAvg	31.4	3.3	2.8	2.7	1.5	1.4	2.2	3.3	2.7	3.0	2.9	2.4	3.1
	PrecMax	44.6	7.9	7.0	6.4	4.7	3.0	3.9	7.8	5.5	7.5	7.5	6.7	8.1
	PrecMin	22.9	0.2	0.1	0.7	0.4	0.3	0.2	1.3	0.5	0.7	0.9	0.4	0.9
	PrecStd	5.1	1.9	2.1	1.7	0.9	0.6	1.1	1.6	1.3	1.6	1.5	1.6	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.4	34.2	37.4	45.5	63.4	70.0	74.6	69.4	59.2	47.8	42.6	36.3
		MCWB	34.2	33.5	32.6	38.8	49.9	55.5	61.0	58.1	50.9	45.4	38.9	35.6
	2%	DB	32.8	32.4	33.8	41.6	57.3	65.2	69.9	65.6	54.8	44.5	38.3	34.5
		MCWB	32.0	31.6	32.5	36.5	47.0	52.9	57.1	56.5	49.5	42.9	36.9	33.6
	5%	DB	31.0	30.8	31.9	38.5	52.3	61.0	66.0	62.1	52.0	42.0	35.8	32.4
		MCWB	30.2	29.9	30.9	34.8	44.7	50.5	55.8	55.2	48.5	40.7	34.7	31.5
	10%	DB	28.6	28.6	30.0	36.1	47.8	57.3	62.4	58.5	49.5	39.9	33.3	30.5
		MCWB	27.9	27.9	29.1	33.5	42.6	49.0	54.5	53.2	47.0	38.9	32.6	29.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.3	34.0	34.7	40.3	51.7	57.9	62.8	60.6	53.4	45.9	41.4	36.0
		MCDB	34.7	34.0	35.7	44.7	62.4	67.8	69.5	65.9	55.9	46.8	41.6	36.1
	2%	WB	32.1	32.0	32.7	37.6	48.4	54.3	59.4	57.8	51.0	43.1	36.8	33.8
		MCDB	32.4	32.3	33.5	40.3	54.4	61.8	66.5	63.3	53.4	44.0	37.6	34.4
	5%	WB	30.2	30.2	31.0	35.6	45.5	51.9	57.3	55.7	49.1	40.9	34.6	31.7
		MCDB	30.7	30.7	31.8	37.6	52.3	59.2	63.3	60.9	51.3	41.7	35.8	32.2
	10%	WB	27.8	27.8	29.1	33.7	42.3	49.8	55.4	53.5	47.2	38.9	32.6	29.8
		MCDB	28.3	28.5	30.0	35.7	47.7	56.3	60.7	58.2	49.2	39.7	33.1	30.3
Mean Daily Temperature Range	5% DB	MDBR	7.5	7.6	7.5	7.4	9.0	11.1	11.1	9.6	7.8	5.6	6.0	6.6
		MCDBR	7.4	8.1	7.5	9.2	15.4	16.0	15.5	13.5	10.8	7.1	7.1	6.8
		MCWBR	7.5	8.2	6.9	6.3	9.3	8.7	8.0	7.9	7.3	6.2	6.6	7.1
	5% WB	MCDBR	7.2	8.4	7.4	8.3	14.6	14.5	14.3	12.3	9.2	6.6	6.8	7.1
		MCWBR	7.4	8.5	7.0	6.4	9.4	9.0	8.9	8.1	7.0	6.4	6.5	7.4
Clear-Sky Solar Irradiance	taub	0.162	0.232	0.263	0.288	0.298	0.302	0.312	0.300	0.278	0.252	0.167	0.165	
	taud	1.929	2.201	2.257	2.281	2.393	2.534	2.535	2.555	2.593	2.407	1.974	1.937	
	Ebn at Noon	105	213	260	280	288	290	283	277	261	207	97	21	
	Edh at Noon	6	16	25	31	31	28	27	24	18	13	5	1	
All-Sky Solar Radiation	RadAvg	27	162	595	1185	1518	1537	1438	1079	582	211	52	6	
	RadStd	2	34	75	96	105	142	176	116	71	28	6	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page