

HEMAVAN-GIEREVARTO, Sweden

WMO: 021030

Lat: 65.7813N

Lon: 15.0623E

Elev: 793

StdP: 92.15

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-21.7	-19.2	-24.3	0.5	-20.8	-21.8	0.6	-18.2	20.9	-1.7	18.7	-3.7	7.3	140	0.909

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	20.2	13.6	18.1	12.8	16.3	11.8	14.7	18.3	13.5	16.7	12.4	15.4	4.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.2	10.4	16.1	12.0	9.6	15.0	10.9	8.9	13.6	43.8	18.3	40.4	16.8	37.4	15.6	22.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	14.6	12.8	-23.4	22.1	3.4	2.2	-25.9	23.7	-27.8	24.9	-29.7	26.1	-32.1	27.7
			-22.9	15.6	4.3	1.2	-26.0	16.4	-28.5	17.1	-30.9	17.7	-34.0	18.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.1	-8.5	-8.9	-7.0	-2.1	2.5	7.3	11.1	9.6	5.4	-0.4	-4.2	-6.9
	DBStd	8.06	5.18	5.39	4.37	3.33	3.99	4.19	3.72	3.37	3.22	3.53	3.98	4.83
	HDD10.0	3829	574	530	527	363	236	104	32	49	142	321	427	523
	HDD18.3	6740	832	763	785	613	490	331	227	271	389	579	677	781
	CDD10.0	133	0	0	0	0	4	24	64	37	3	0	0	0
	CDD18.3	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH23.3	4	0	0	0	0	0	0	4	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.8	6.6	6.5	6.5	5.8	5.7	5.4	4.9	4.8	5.8	5.9	5.7	6.4
Precipitation	PrecAvg	798	84	71	69	38	36	56	85	68	77	73	62	79
	PrecMax	1134	201	179	162	120	75	99	199	140	190	191	171	205
	PrecMin	582	5	3	18	11	7	5	34	12	19	22	10	22
	PrecStd	130	49	53	43	24	16	28	41	34	41	37	40	50
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.9	1.2	3.0	7.5	17.4	21.1	23.7	20.8	15.1	8.8	5.9	2.4
		MCWB	1.2	0.8	0.3	3.8	9.9	13.1	16.1	14.5	10.5	7.4	3.8	2.0
	2%	DB	0.5	0.2	1.0	5.3	14.0	18.5	21.0	18.7	12.7	6.9	3.5	1.4
		MCWB	0.0	-0.2	0.3	2.5	8.4	11.6	13.9	13.6	9.7	6.1	2.7	0.9
	5%	DB	-0.6	-0.7	0.0	3.6	11.3	16.1	18.9	16.7	11.1	5.5	2.1	0.2
		MCWB	-1.0	-1.2	-0.6	1.6	7.0	10.3	13.2	12.9	9.1	4.8	1.5	-0.3
	10%	DB	-1.9	-1.9	-1.1	2.3	8.8	14.0	16.9	14.7	9.7	4.4	0.7	-0.8
		MCWB	-2.3	-2.3	-1.6	0.8	5.9	9.5	12.5	11.8	8.3	3.8	0.3	-1.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.3	1.1	1.5	4.6	10.9	14.4	17.1	15.9	11.9	7.7	5.2	2.2
		MCDB	1.5	1.1	2.1	7.0	16.9	19.9	20.8	18.8	13.3	8.2	5.3	2.3
	2%	WB	0.0	0.0	0.4	3.1	9.1	12.4	15.2	14.3	10.5	6.2	2.7	1.0
		MCDB	0.2	0.2	0.8	4.6	12.4	16.6	19.2	17.4	11.9	6.7	3.1	1.3
	5%	WB	-1.0	-1.0	-0.6	2.0	7.5	11.1	14.0	13.2	9.5	4.9	1.5	-0.1
		MCDB	-0.7	-0.7	-0.1	3.1	11.3	15.1	17.4	16.1	10.7	5.4	2.1	0.1
	10%	WB	-2.3	-2.3	-1.6	1.0	5.7	9.9	13.0	12.0	8.4	3.9	0.3	-1.2
		MCDB	-2.1	-2.0	-1.1	2.0	8.7	13.5	15.9	14.6	9.6	4.3	0.6	-1.0
Mean Daily Temperature Range	5% DB	MDBR	4.2	4.2	4.1	4.1	5.0	6.2	6.2	5.4	4.3	3.1	3.3	3.7
		MCDBR	4.1	4.5	4.2	5.1	8.5	8.9	8.6	7.5	6.0	3.9	3.9	3.8
		MCWBR	4.2	4.6	3.8	3.5	5.1	4.8	4.5	4.4	4.0	3.5	3.7	3.9
	5% WB	MCDBR	4.0	4.7	4.1	4.6	8.1	8.0	7.9	6.9	5.1	3.7	3.8	3.9
		MCWBR	4.1	4.7	3.9	3.5	5.2	5.0	5.0	4.5	3.9	3.5	3.6	4.1
Clear-Sky Solar Irradiance	taub	0.162	0.232	0.263	0.288	0.298	0.302	0.312	0.300	0.278	0.252	0.167	0.165	
	taud	1.929	2.201	2.257	2.281	2.393	2.534	2.535	2.555	2.593	2.407	1.974	1.937	
	Ebn at Noon	332	672	820	883	909	915	892	872	822	653	307	65	
	Edh at Noon	18	50	78	99	98	88	86	76	58	41	16	4	
All-Sky Solar Radiation	RadAvg	0.09	0.51	1.88	3.73	4.79	4.85	4.53	3.40	1.83	0.67	0.16	0.02	
	RadStd	0.01	0.11	0.24	0.30	0.33	0.45	0.56	0.37	0.23	0.09	0.02	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page