

KLIMPFJALL, Sweden

WMO: 021080

Lat: 65.067N

Lon: 14.800E

Elev: 1946

StdP: 13.69

Time Zone: 1.00 (EUC)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.3	-14.9	-22.7	1.7	-19.2	-18.2	2.2	-14.9	34.2	25.8	33.2	25.6	1.4	320	0.783

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	68.7	55.4	64.9	53.4	61.4	52.0	57.6	65.4	55.1	61.4	53.4	59.1	7.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.4	67.6	58.8	52.2	62.4	56.4	50.5	58.5	55.2	25.6	65.6	24.0	61.8	22.9	59.3	65.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.2	23.1	16.6	-24.6	74.6	7.9	3.3	-30.3	77.0	-34.9	78.9	-39.4	80.7	-45.1	83.1		
(5)			-24.8	59.9	7.8	3.1	-30.4	62.1	-35.0	64.0	-39.4	65.8	-45.1	68.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	31.4	14.0	15.6	21.0	26.6	38.2	47.4	51.0	48.2	40.5	32.0	22.8	18.1
	DBStd	15.69	14.63	12.52	9.14	7.99	5.59	5.71	4.99	5.12	5.04	8.17	9.85	12.20
	HDD50	6962	1117	964	900	701	367	119	49	95	288	559	815	988
	HDD65	12272	1582	1384	1365	1151	830	529	433	520	736	1024	1265	1453
	CDD50	166	0	0	0	0	3	40	81	40	2	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	11	0	0	0	0	0	3	5	3	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.3	6.5	6.7	6.6	5.7	6.0	6.8	6.4	5.4	5.8	6.5	5.9	6.7
Precipitation	PrecAvg	30.7	3.2	2.9	2.2	1.4	1.4	2.5	3.5	3.1	2.5	2.6	2.3	3.1
	PrecMax	38.5	6.2	7.9	5.7	3.1	2.5	4.4	7.6	6.5	4.1	4.6	5.9	5.7
	PrecMin	22.9	0.4	0.3	0.4	0.4	0.5	0.6	1.6	0.9	0.7	1.4	0.5	0.9
	PrecStd	4.5	1.7	2.0	1.3	0.7	0.6	1.0	1.5	1.5	1.0	0.8	1.4	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.4	37.7	40.0	48.1	66.5	73.1	73.2	73.2	59.1	49.0	40.2	37.8
		MCWB	36.0	36.3	36.5	40.0	50.0	57.0	58.4	58.1	49.6	45.2	37.7	36.0
	2%	DB	36.2	35.3	36.8	43.8	58.3	67.2	69.0	64.7	53.8	46.2	37.8	36.4
		MCWB	34.2	33.8	34.0	37.1	46.3	53.1	56.2	55.1	48.4	43.0	35.7	34.9
	5%	DB	33.5	33.0	34.7	40.6	52.1	63.4	65.6	59.8	51.2	44.0	36.1	34.9
		MCWB	31.5	31.5	32.3	35.3	42.6	51.6	54.9	52.0	47.3	41.2	34.4	33.7
	10%	DB	30.9	31.0	32.7	37.6	47.4	59.2	62.4	57.1	48.9	42.0	34.3	32.8
		MCWB	29.4	29.4	30.7	34.3	40.0	49.1	53.4	51.5	44.9	39.7	32.9	31.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.4	36.7	36.8	40.4	50.7	59.0	63.0	59.7	52.0	46.6	38.1	36.5
		MCDB	37.9	37.5	38.8	45.9	64.9	69.1	65.6	69.1	54.6	47.7	39.4	36.9
	2%	WB	34.4	33.9	34.6	38.0	46.4	54.9	58.5	56.1	49.8	43.5	36.1	35.1
		MCDB	36.0	34.8	36.5	42.1	57.4	63.2	66.4	61.9	52.8	45.2	37.4	35.9
	5%	WB	31.7	31.7	32.6	36.3	43.2	52.5	56.1	53.9	47.6	41.4	34.5	33.6
		MCDB	33.2	32.8	34.4	39.4	50.6	61.4	63.0	58.0	50.5	43.4	35.8	34.8
	10%	WB	29.5	29.5	30.8	34.6	40.9	50.1	54.2	52.2	45.5	39.8	33.2	31.7
		MCDB	30.8	30.8	32.6	37.3	45.8	57.9	60.3	55.7	48.4	41.7	34.3	32.8
Mean Daily Temperature Range	5% DB	MDBR	12.6	12.7	13.5	14.6	13.2	14.8	14.7	13.1	11.7	9.6	9.8	11.7
		MCDBR	11.2	9.9	10.3	16.1	22.9	23.7	22.5	18.9	15.6	11.3	7.2	8.9
		MCWBR	10.9	9.9	8.7	10.9	13.5	12.4	10.9	10.3	9.8	9.4	6.8	8.9
	5% WB	MCDBR	10.7	8.7	9.6	11.6	20.5	21.1	18.2	14.7	11.9	9.4	6.7	8.9
		MCWBR	10.5	9.1	8.7	8.4	12.7	11.8	10.5	9.3	8.7	8.8	6.5	8.9
Clear-Sky Solar Irradiance	taub	0.176	0.248	0.280	0.308	0.318	0.318	0.329	0.316	0.293	0.270	N/A	0.178	
	taud	1.926	2.178	2.223	2.239	2.383	2.504	2.498	2.518	2.570	2.406	N/A	1.939	
	Ebn at Noon	112	208	254	273	283	285	278	272	256	204	N/A	31	
	Edh at Noon	7	17	26	33	32	29	29	25	19	14	N/A	2	
All-Sky Solar Radiation	RadAvg	34	180	614	1195	1496	1570	1468	1096	601	229	58	11	
	RadStd	3	37	73	98	113	136	178	114	75	27	8	0	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (36 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page