

KVIKKJOKK ARREJARKA, Sweden

WMO: 021190

Lat: 66.883N

Lon: 18.023E

Elev: 1050

StdP: 14.15

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.1	-25.0	-42.5	0.5	-27.5	-37.7	0.7	-27.9	27.9	32.7	20.1	31.4	1.7	320	0.715

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.2	75.1	58.9	71.3	57.2	67.5	55.8	62.0	71.8	59.8	67.9	58.0	64.6	5.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.6	76.5	63.0	56.8	71.4	61.2	55.0	67.0	60.1	28.2	71.6	26.8	68.0	25.5	64.4	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	14.5	11.5	-36.3	80.3	4.0	4.7	-39.2	83.7	-41.5	86.4	-43.8	89.0	-46.7	92.4
			-37.1	64.6	3.3	3.0	-39.4	66.8	-41.4	68.5	-43.2	70.2	-45.5	72.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	30.7	6.2	8.4	17.8	30.1	40.1	50.3	56.4	52.5	44.2	32.1	18.2	11.1
	DBStd	20.27	16.35	16.17	11.81	7.79	6.19	6.03	5.21	5.46	5.85	7.84	12.05	15.55
	HDD50	7447	1359	1165	1000	596	313	69	7	35	188	556	953	1206
	HDD65	12514	1824	1585	1465	1046	773	441	271	390	624	1021	1403	1671
	CDD50	415	0	0	0	0	6	78	206	111	14	0	0	0
	CDD65	6	0	0	0	0	0	0	5	1	0	0	0	0
	CDH74	157	0	0	0	0	4	23	107	23	0	0	0	0
	CDH80	23	0	0	0	0	0	3	20	0	0	0	0	0
Wind	WSAvg	4.1	3.2	3.5	4.5	4.4	4.9	5.0	4.3	4.0	4.4	3.8	3.4	3.4
Precipitation	PrecAvg	24.5	1.7	1.3	1.1	1.1	1.7	2.8	3.9	3.0	2.2	2.0	1.8	1.7
	PrecMax	34.0	3.6	2.4	2.4	2.3	3.3	5.4	6.0	5.9	5.6	3.9	4.1	4.3
	PrecMin	15.9	0.2	0.2	0.3	0.2	0.4	0.9	1.2	1.1	0.7	0.7	0.6	0.5
	PrecStd	4.4	0.7	0.6	0.5	0.6	0.8	1.2	1.4	1.5	1.2	0.8	1.0	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.0	43.5	45.0	55.5	72.4	76.8	82.8	77.2	64.8	52.2	46.4	43.8
		MCWB	38.4	38.3	38.6	43.3	53.4	57.4	62.1	59.9	54.7	46.2	41.1	38.7
	2%	DB	38.9	39.8	41.2	48.8	63.5	71.5	76.5	72.5	60.2	49.2	40.6	40.5
		MCWB	34.8	35.0	35.8	40.1	50.1	55.8	60.2	59.3	51.5	44.8	38.0	35.7
	5%	DB	33.9	35.5	38.3	45.4	57.5	67.3	72.8	68.0	57.3	46.5	36.5	36.1
		MCWB	31.4	32.2	33.7	38.4	47.5	53.9	58.8	57.8	50.3	42.8	34.0	33.1
	10%	DB	29.3	31.0	35.1	42.3	53.0	63.1	68.9	64.1	54.9	43.6	33.2	31.8
		MCWB	27.5	29.2	31.5	36.2	44.5	52.4	57.0	54.9	49.7	39.9	31.9	30.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.8	38.6	38.9	45.3	54.9	62.1	64.9	64.9	56.7	47.7	41.5	38.6
		MCDB	39.7	43.5	43.8	57.0	69.8	71.5	77.5	71.2	60.7	51.1	45.5	42.9
	2%	WB	34.4	34.9	36.3	41.6	52.2	59.1	62.8	60.9	54.0	45.4	38.6	34.8
		MCDB	37.5	38.6	40.4	48.6	63.6	67.3	73.8	69.6	58.2	48.6	42.1	37.7
	5%	WB	30.2	32.1	34.2	39.4	49.2	56.8	60.8	58.6	52.1	43.2	34.2	32.1
		MCDB	31.8	34.7	38.0	45.6	59.1	64.1	70.1	66.0	55.4	46.7	35.7	33.8
	10%	WB	26.1	29.6	32.1	37.3	46.5	54.0	59.0	56.7	50.8	40.1	31.9	29.4
		MCDB	27.6	31.3	34.9	43.0	54.1	61.4	65.7	63.5	54.2	42.7	32.7	30.9
Mean Daily Temperature Range	5% DB	MDBR	16.3	18.3	21.2	18.6	18.0	17.7	18.2	18.3	15.8	12.1	12.2	15.7
		MCDBR	19.0	19.1	19.3	21.7	29.2	26.2	27.7	27.0	21.1	14.7	13.4	16.2
		MCWBR	22.0	16.6	16.4	15.8	18.3	14.8	14.4	16.6	15.5	12.4	12.1	13.9
	5% WB	MCDBR	21.0	17.7	19.2	22.1	29.6	22.8	24.8	25.4	18.4	15.1	13.3	16.6
		MCWBR	19.7	15.0	15.7	15.8	18.5	12.6	13.2	15.0	13.2	11.8	11.8	14.9
Clear-Sky Solar Irradiance	taub		0.175	0.240	0.278	0.306	0.323	0.328	0.338	0.323	0.293	0.262	0.179	N/A
	taud		1.933	2.148	2.207	2.238	2.386	2.495	2.489	2.512	2.571	2.338	1.972	N/A
	Ebn at Noon		69	194	246	270	278	280	272	265	250	187	61	0
	Edh at Noon		4	16	25	32	31	29	28	25	18	13	3	0
All-Sky Solar Radiation	RadAvg		19	166	616	1217	1562	1595	1464	1088	585	203	42	0
	RadStd		1	25	45	68	139	139	163	111	69	32	4	0

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page