

KVIKKJOKK ARREJARKA, Sweden

WMO: 021190

Lat: 66.883N

Lon: 18.023E

Elev: 320

StdP: 97.54

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.1	-31.6	-41.4	0.1	-33.0	-38.7	0.1	-33.3	12.5	0.4	9.0	-0.3	0.8	320	0.715

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	23.9	14.9	21.9	14.0	19.7	13.2	16.6	22.1	15.5	20.0	14.4	18.1	2.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.8	10.9	17.2	13.8	10.2	16.2	12.8	9.6	15.6	47.8	22.0	44.3	20.0	41.5	18.0	21.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	6.5	5.2	-38.0	26.8	2.2	2.6	-39.6	28.7	-40.9	30.2	-42.1	31.7	-43.7	33.6		
(5)			-38.4	18.1	1.8	1.7	-39.7	19.3	-40.8	20.3	-41.8	21.2	-43.1	22.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.7	-14.3	-13.1	-7.9	-1.0	4.5	10.2	13.6	11.4	6.8	0.0	-7.6	-11.6		
	DBStd	11.26	9.08	8.98	6.56	4.33	3.44	3.35	2.89	3.04	3.25	4.35	6.70	8.64		
	HDD10.0	4137	755	647	556	331	174	38	4	19	104	309	529	670		
	HDD18.3	6952	1013	881	814	581	429	245	151	217	347	567	779	928		
	CDD10.0	231	0	0	0	0	3	43	114	62	8	0	0	0		
	CDD18.3	3	0	0	0	0	0	0	3	1	0	0	0	0		
	CDH23.3	87	0	0	0	0	2	13	59	13	0	0	0	0		
	CDH26.7	13	0	0	0	0	0	2	11	0	0	0	0	0		
	WSAvg	1.8	1.4	1.6	2.0	2.0	2.2	2.2	1.9	1.8	2.0	1.7	1.5	1.5		
	PrecAvg	622	43	32	29	29	43	72	98	77	57	51	46	43		
(15) Precipitation	PrecMax	863	91	60	61	59	85	136	153	149	141	100	104	108		
	PrecMin	405	4	4	8	6	11	24	30	29	19	17	14	13		
	PrecStd	113	19	16	13	15	21	30	35	37	30	21	26	20		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.1	6.4	7.2	13.1	22.5	24.9	28.2	25.1	18.2	11.2	8.0	6.6		
		MCWB	3.6	3.5	3.7	6.3	11.9	14.1	16.7	15.5	12.6	7.9	5.0	3.7		
	2%	DB	3.8	4.3	5.1	9.3	17.5	22.0	24.7	22.5	15.7	9.5	4.8	4.7		
		MCWB	1.6	1.7	2.1	4.5	10.1	13.2	15.7	15.2	10.8	7.1	3.3	2.0		
	5%	DB	1.0	1.9	3.5	7.5	14.2	19.6	22.7	20.0	14.1	8.1	2.5	2.3		
		MCWB	-0.3	0.1	1.0	3.6	8.6	12.1	14.9	14.3	10.2	6.0	1.1	0.6		
	10%	DB	-1.5	-0.5	1.7	5.7	11.7	17.3	20.5	17.9	12.7	6.4	0.7	-0.1		
		MCWB	-2.5	-1.6	-0.3	2.3	6.9	11.4	13.9	12.7	9.8	4.4	0.0	-1.0		
	0.4%	WB	2.6	3.7	3.9	7.4	12.7	16.7	18.3	18.3	13.7	8.7	5.3	3.7		
		MCDB	4.3	6.4	6.5	13.9	21.0	22.0	25.3	21.8	16.0	10.6	7.5	6.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	1.3	1.6	2.4	5.3	11.2	15.0	17.1	16.0	12.2	7.4	3.7	1.5		
		MCDB	3.0	3.7	4.7	9.2	17.6	19.6	23.2	20.9	14.5	9.2	5.6	3.2		
	5%	WB	-1.0	0.1	1.2	4.1	9.5	13.8	16.0	14.8	11.2	6.2	1.2	0.0		
		MCDB	-0.1	1.5	3.3	7.6	15.0	17.8	21.2	18.9	13.0	8.2	2.0	1.0		
	10%	WB	-3.3	-1.4	0.0	3.0	8.1	12.2	15.0	13.7	10.4	4.5	-0.1	-1.4		
		MCDB	-2.5	-0.4	1.6	6.1	12.3	16.3	18.7	17.5	12.4	6.0	0.4	-0.6		
	5% DB	MDBR	9.1	10.2	11.8	10.3	10.0	9.8	10.1	10.2	8.8	6.7	6.8	8.7		
		MCDBR	10.6	10.6	10.7	12.0	16.2	14.6	15.4	15.0	11.7	8.2	7.4	9.0		
		MCWBR	12.2	9.2	9.1	8.8	10.2	8.2	8.0	9.2	8.6	6.9	6.7	7.7		
		MCWBR	11.7	9.8	10.7	12.3	16.4	12.6	13.8	14.1	10.2	8.4	7.4	9.2		
(35) Mean Daily Temperature Range	5% WB	MCWBR	10.9	8.3	8.7	8.8	10.3	7.0	7.4	8.3	7.3	6.6	6.5	8.3		
	Clear-Sky Solar Irradiance	taub	0.175	0.240	0.278	0.306	0.323	0.328	0.338	0.323	0.293	0.262	0.179	N/A		
		taud	1.933	2.148	2.207	2.238	2.386	2.495	2.489	2.512	2.571	2.338	1.972	N/A		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	216	612	777	850	876	882	859	836	787	591	193	0		
		Edh at Noon	13	49	80	102	98	91	89	78	58	40	11	0		
(44) All-Sky Solar Radiation	RadStd		0.06	0.52	1.94	3.83	4.92	5.03	4.62	3.43	1.84	0.64	0.13	0.00		
			0.00	0.08	0.14	0.21	0.44	0.44	0.52	0.35	0.22	0.10	0.01	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page