

MIERKENIS, Sweden

WMO: 021210

Lat: 66.6802N

Lon: 16.1053E

Elev: 615

StdP: 94.15

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -30.4	(c) -27.8	(d) -33.9	(e) 0.2	(f) -30.3	(g) -30.9	(h) 0.2	(i) -27.7	(j) 11.8	(k) -7.6	(l) 10.5	(m) -6.5	(n) 1.7	(o) 300	(p) 0.783

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	21.6	14.1	19.6	13.2	17.5	12.2	15.4	19.5	14.1	17.9	13.0	16.4	3.1	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.7	10.5	16.8	12.5	9.7	15.4	11.3	9.0	14.2	45.1	19.6	41.4	18.1	38.3	16.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.0	(b) 7.8	(c) 6.9	(e) -33.1	(f) 23.9	(g) 3.5	(h) 2.6	(i) -35.6	(j) 25.7	(k) -37.7	(l) 27.2	(m) -39.6	(n) 28.7	(o) -42.1	(p) 30.5		
(a) 9.0	(b) 7.8	(c) 6.9	(e) -34.2	(f) 16.7	(g) 3.0	(h) 1.7	(i) -36.4	(j) 18.0	(k) -38.2	(l) 19.0	(m) -39.9	(n) 19.9	(o) -42.0	(p) 21.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.1	-12.1	-10.7	-8.3	-3.0	2.9	8.0	11.6	9.9	5.4	-1.0	-6.7	-9.2
	DBStd	9.68	7.40	7.63	6.10	4.58	3.55	3.42	2.94	3.05	3.20	4.57	6.06	7.47
	HDD10.0	4160	687	579	568	389	222	80	16	41	141	342	500	595
	HDD18.3	7077	945	813	826	639	479	310	209	263	389	601	750	853
	CDD10.0	125	0	0	0	0	2	20	66	36	2	0	0	0
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH23.3	18	0	0	0	0	0	3	14	1	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	3.2	3.2	3.3	3.5	3.1	3.3	3.2	2.9	2.7	3.1	3.2	3.0	3.3
Precipitation	PrecAvg	636	57	46	43	30	36	50	85	70	65	52	48	53
	PrecMax	860	133	118	87	60	57	90	140	149	110	80	93	133
	PrecMin	498	17	18	8	10	8	4	27	25	29	22	10	12
	PrecStd	90	30	26	26	14	15	26	37	37	25	18	26	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.0	3.9	4.4	9.6	19.2	22.8	25.2	22.5	16.1	9.3	5.8	4.6
		MCWB	2.3	2.2	2.0	5.0	10.4	13.3	16.3	14.7	10.6	7.1	4.6	2.9
	2%	DB	1.8	2.3	2.7	6.9	14.9	19.5	22.5	20.3	13.3	7.6	4.3	2.7
		MCWB	0.7	0.9	1.0	3.1	8.5	11.6	14.7	14.1	10.0	5.8	3.1	1.4
	5%	DB	-0.1	1.2	1.6	4.9	11.7	17.4	20.5	18.0	11.7	6.3	2.8	0.9
		MCWB	-0.9	-0.2	0.0	2.2	6.9	10.6	13.9	13.5	9.2	4.9	1.8	-0.2
	10%	DB	-2.3	-0.5	0.2	3.5	8.7	15.2	18.3	15.8	10.4	5.0	0.7	-0.5
		MCWB	-3.0	-1.4	-1.0	1.4	5.2	9.9	13.1	12.3	8.5	3.8	0.1	-1.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.1	2.4	2.4	5.2	10.8	14.3	17.6	16.5	12.0	7.3	5.0	2.9
		MCDB	3.3	3.6	3.9	9.0	18.2	20.3	22.5	20.1	14.5	8.7	5.7	4.3
	2%	WB	0.5	1.1	1.2	3.7	8.9	12.6	16.1	14.9	10.7	6.0	3.2	1.5
		MCDB	1.3	2.2	2.5	6.4	14.5	17.3	20.5	18.5	12.5	7.3	4.2	2.6
	5%	WB	-1.1	-0.1	0.1	2.6	7.2	11.5	14.8	13.8	9.6	5.1	1.8	-0.1
		MCDB	-0.3	0.9	1.4	4.6	11.2	15.9	18.9	17.3	11.2	6.2	2.7	0.8
	10%	WB	-3.2	-1.5	-1.0	1.5	5.5	10.4	13.6	12.7	8.7	3.9	0.2	-1.3
		MCDB	-2.5	-0.6	0.1	3.3	8.5	14.7	17.2	15.4	10.1	5.0	0.7	-0.6
Mean Daily Temperature Range	5% DB	MDBR	7.9	8.7	9.4	9.0	7.5	8.6	9.1	8.7	7.1	5.7	6.8	7.6
		MCDBR	6.2	7.4	7.4	9.5	13.3	13.9	14.2	12.8	9.8	5.9	6.1	7.4
		MCWBR	6.0	6.8	6.3	6.7	7.8	6.9	7.2	7.4	6.6	4.6	5.4	6.7
	5% WB	MCDBR	6.6	7.5	7.2	8.0	12.4	11.8	11.9	11.5	8.0	5.5	6.0	7.7
		MCWBR	6.3	6.9	6.1	5.7	7.6	6.3	6.6	7.1	5.7	4.5	5.4	7.0
Clear-Sky Solar Irradiance	taub	0.170	0.236	0.273	0.298	0.310	0.314	0.324	0.311	0.284	0.254	0.175	N/A	
	taud	1.919	2.145	2.199	2.229	2.335	2.478	2.494	2.513	2.562	2.318	1.960	N/A	
	Ebn at Noon	237	625	787	861	889	897	875	851	800	607	214	0	
	Edh at Noon	14	49	80	102	103	92	89	78	58	41	12	0	
All-Sky Solar Radiation	RadAvg	0.06	0.48	1.84	3.72	4.88	4.98	4.55	3.40	1.79	0.62	0.14	0.00	
	RadStd	0.00	0.09	0.20	0.26	0.37	0.42	0.53	0.36	0.20	0.10	0.01	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)	+0.37	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page