

BURESJON, Sweden

WMO: 021350

Lat: 65.558N

Lon: 17.855E

Elev: 1289

StdP: 14.02

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.8	-19.4	-31.4	1.0	-25.7	-24.3	1.5	-19.3	18.7	29.7	15.9	29.1	0.8	120	0.689

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.0	75.3	60.6	71.9	59.0	68.4	57.3	63.2	71.5	61.1	68.5	59.0	65.7	4.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.1	81.5	65.7	58.0	75.5	63.7	56.0	69.9	61.5	29.3	72.2	27.7	68.6	26.3	65.7	71.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.6	14.1	12.0	-32.5	78.9	5.5	4.8	-36.5	82.4	-39.7	85.2	-42.8	87.9	-46.8	91.4		
(5)			-32.5	65.6	5.4	2.8	-36.4	67.6	-39.5	69.3	-42.5	70.9	-46.4	72.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	32.8	9.9	12.0	20.0	31.5	42.6	51.7	57.5	53.5	44.6	32.7	21.0	14.9		
	DBStd	18.98	14.16	13.57	10.72	7.24	6.87	6.50	5.51	5.57	5.78	7.82	11.14	14.00		
	HDD50	6796	1243	1065	931	555	247	55	4	26	176	537	870	1087		
	HDD65	11772	1708	1485	1396	1005	693	402	241	358	611	1001	1320	1552		
	CDD50	509	0	0	0	0	19	104	236	134	15	1	0	0		
	CDD65	13	0	0	0	0	0	2	9	2	0	0	0	0		
	CDH74	163	0	0	0	0	5	33	106	19	0	0	0	0		
	CDH80	20	0	0	0	0	0	2	18	0	0	0	0	0		
	WSAvg	4.9	3.7	4.3	5.8	5.6	6.1	6.1	4.9	4.4	4.8	4.8	3.8	4.2		
	PrecAvg	23.0	1.4	1.2	1.0	1.1	1.5	2.4	3.5	3.1	2.2	2.0	1.9	1.5		
(15) Precipitation	PrecMax	32.6	2.5	2.0	2.2	1.9	2.7	5.0	6.0	6.3	5.6	3.5	4.2	2.6		
	PrecMin	17.6	0.1	0.3	0.4	0.4	0.4	0.6	1.2	0.6	0.9	0.5	0.7	0.3		
	PrecStd	4.3	0.6	0.5	0.6	0.4	0.7	1.3	1.5	1.7	1.3	0.9	1.0	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.0	41.4	44.6	57.7	73.4	78.3	82.3	76.5	64.5	52.7	44.8	40.1		
		MCWB	38.7	37.9	39.0	44.9	55.5	59.4	64.3	62.5	55.9	48.1	42.3	37.5		
	2%	DB	36.2	38.3	40.6	51.2	67.3	72.8	76.4	72.6	59.9	48.7	40.6	36.7		
		MCWB	34.4	35.4	35.8	41.8	52.3	57.6	61.4	60.3	53.5	45.5	39.3	34.6		
	5%	DB	32.8	34.4	38.1	46.6	61.2	68.3	72.9	68.6	56.6	46.2	36.6	33.9		
		MCWB	31.4	32.1	34.3	39.5	49.6	55.3	60.3	59.0	51.6	43.5	35.4	32.6		
	10%	DB	29.1	30.9	35.5	43.2	55.9	64.5	69.4	64.5	54.2	43.6	34.3	32.0		
		MCWB	28.2	29.3	32.3	37.5	47.0	53.5	58.7	57.4	50.3	41.5	33.5	31.2		
	0.4%	WB	38.8	38.3	39.0	46.3	56.3	63.2	66.9	64.9	57.6	49.0	43.3	37.8		
		MCDB	41.1	41.0	43.5	56.0	69.5	73.0	74.6	71.5	61.3	50.8	44.7	39.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	34.6	35.6	36.5	42.8	54.0	59.7	64.1	62.2	54.7	46.0	39.1	34.9		
		MCDB	35.9	38.0	40.0	49.5	63.9	69.3	73.2	68.9	58.2	48.1	40.8	36.2		
	5%	WB	31.2	32.4	34.6	40.2	51.0	57.1	62.1	60.1	52.7	43.8	35.6	32.8		
		MCDB	32.3	34.2	37.7	45.4	60.7	65.3	70.5	66.4	55.7	45.9	36.3	33.8		
	10%	WB	28.2	29.3	32.5	37.8	47.6	54.7	60.1	58.0	50.9	41.7	33.5	31.0		
		MCDB	29.0	30.8	35.2	42.7	54.7	62.5	66.9	63.6	53.7	43.4	34.1	31.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.6	16.9	19.2	16.7	17.1	16.7	17.0	16.7	14.5	10.8	11.2	14.1		
		MCDBR	14.7	14.2	17.4	22.5	28.0	22.8	23.9	24.3	18.6	12.9	9.9	13.1		
		MCWBR	13.9	12.8	13.9	14.0	15.2	11.2	11.2	13.2	12.6	10.1	9.1	12.7		
		MCDBR	14.8	14.3	16.2	19.6	26.0	20.9	20.5	20.3	15.9	11.7	8.8	12.8		
	5% WB	MCWBR	14.0	13.2	13.2	12.6	15.0	11.3	11.0	12.0	11.6	9.7	8.3	12.4		
(40) Clear-Sky Solar Irradiance	taub		0.179	0.252	0.284	0.314	0.326	0.327	0.339	0.324	0.297	0.277	0.341	0.183		
	taud		1.943	2.178	2.238	2.310	2.484	2.519	2.495	2.523	2.582	2.431	2.783	1.960		
	Ebn at Noon		99	202	251	271	280	282	274	268	253	198	99	21		
	Edh at Noon		6	17	26	31	29	29	29	25	19	13	6	2		
(44) All-Sky Solar Radiation	RadAvg		32	205	663	1231	1517	1646	1503	1126	628	242	55	7		
	RadStd		2	36	54	76	158	127	166	120	81	38	9	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page