

VAJMAT, Sweden

WMO: 021460

Lat: 66.5050N

Lon: 19.6750E

Elev: 325

StdP: 97.48

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -36.3	(c) -33.7	(d) -38.9	(e) 0.1	(f) -36.1	(g) -36.3	(h) 0.1	(i) -33.6	(j) 9.7	(k) -3.3	(l) 8.4	(m) -5.3	(n) 1.3	(o) 140	(p) 0.714

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.5	(c) 24.7	(d) 14.6	(e) 22.6	(f) 13.3	(g) 20.7	(h) 12.6	(i) 16.9	(j) 21.3	(k) 15.6	(l) 19.1	(m) 14.5	(n) 17.9	(o) 3.1	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	11.2	17.5	14.1	10.4	17.0	13.1	9.7	15.9	48.5	21.5	44.9	19.3	41.7	17.7	20.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.5	7.3	6.4	-40.0	27.0	2.7	2.5	-42.0	28.8	-43.5	30.3	-45.0	31.7	-46.9	33.6
			-39.7	17.6	2.7	1.1	-41.7	18.4	-43.3	19.0	-44.8	19.7	-46.8	20.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.0	-14.7	-13.7	-7.6	-0.6	5.8	11.8	14.7	13.0	7.7	0.4	-6.8	-11.1
	DBStd	11.83	8.85	8.94	6.65	4.48	3.51	3.64	2.80	3.30	3.28	4.94	7.05	9.10
	HDD10.0	4007	766	664	547	319	138	21	1	9	84	299	506	654
	HDD18.3	6715	1024	898	805	569	388	199	117	169	320	557	756	913
	CDD10.0	344	0	0	0	0	7	74	148	102	14	0	0	0
	CDD18.3	11	0	0	0	0	0	2	6	3	0	0	0	0
	CDH23.3	134	0	0	0	0	4	37	60	33	0	0	0	0
	CDH26.7	17	0	0	0	0	0	7	7	3	0	0	0	0
(14) Wind	WSAvg	2.9	2.4	2.6	3.2	3.3	3.3	3.3	3.0	2.7	3.1	2.8	2.4	2.6
(15) Precipitation	PrecAvg	588	36	24	25	23	48	71	101	72	55	47	42	39
	PrecMax	904	81	50	55	51	111	127	138	149	210	104	82	120
	PrecMin	352	0	0	7	5	11	24	28	20	15	14	10	9
	PrecStd	124	17	15	13	14	25	30	32	35	41	22	24	26
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.9	5.2	8.1	13.7	22.8	27.3	27.7	26.6	19.3	12.0	7.3	5.6
		MCWB	3.3	2.0	2.5	6.3	11.4	16.5	17.5	15.4	11.0	7.1	4.3	1.5
	2%	DB	3.3	3.5	5.5	10.3	18.8	23.6	25.0	23.9	16.7	10.2	5.6	4.0
		MCWB	0.8	0.9	1.8	3.7	9.8	12.4	15.5	14.0	10.6	6.7	3.7	0.6
	5%	DB	1.0	1.6	4.1	8.2	15.5	21.2	22.7	21.7	14.6	8.7	3.7	2.5
		MCWB	-1.0	-0.4	1.0	3.0	8.1	12.2	13.9	13.7	10.0	5.9	1.7	0.1
	10%	DB	-1.8	-0.3	2.6	6.6	12.8	18.9	20.6	19.4	13.1	7.4	1.9	0.5
		MCWB	-2.7	-1.8	-0.1	2.0	6.4	11.1	12.6	13.0	9.3	5.1	0.6	-0.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.4	2.6	3.1	6.6	13.3	17.8	18.5	17.9	13.7	8.4	5.5	2.2
		MCDB	5.7	4.9	6.2	12.6	22.4	25.3	25.8	22.1	16.3	10.3	6.3	4.2
	2%	WB	1.3	1.3	2.1	4.6	10.5	15.4	17.3	16.2	11.9	7.4	3.7	1.2
		MCDB	2.9	3.2	5.2	9.0	16.8	19.9	22.0	19.7	13.6	9.5	5.3	3.0
	5%	WB	-0.8	-0.4	1.2	3.4	8.9	13.8	16.1	15.1	11.0	6.3	2.2	0.3
		MCDB	0.8	1.2	3.9	7.3	13.3	18.4	19.7	18.6	13.1	8.4	3.6	2.0
	10%	WB	-2.9	-1.9	0.1	2.5	7.5	12.4	15.0	14.1	10.3	5.2	0.8	-0.7
		MCDB	-1.7	-0.4	2.4	5.9	11.2	16.8	17.5	18.0	12.6	7.1	1.5	0.8
(35) Mean Daily Temperature Range	MDBR		10.7	12.3	13.6	10.5	9.0	8.8	8.5	9.0	7.9	6.7	7.9	9.7
	5% DB	MCDBR	8.9	10.6	11.4	12.2	15.2	13.2	12.5	13.2	10.8	7.4	6.9	8.1
		MCWBR	7.4	8.9	8.5	6.7	7.0	4.7	4.8	5.4	5.8	5.0	5.6	7.0
	5% WB	MCDBR	8.9	10.5	10.8	10.8	12.4	11.0	10.0	10.6	8.0	6.9	6.7	7.7
		MCWBR	7.6	9.1	8.3	6.2	6.9	5.0	5.3	5.3	5.1	5.1	5.6	7.2
(40) Clear-Sky Solar Irradiance	taub		0.179	0.246	0.281	0.310	0.328	0.331	0.341	0.326	0.296	0.272	0.341	0.182
	taud		1.941	2.159	2.229	2.285	2.472	2.508	2.490	2.519	2.580	2.404	2.790	1.958
	Ebn at Noon		240	615	781	851	876	880	857	836	788	599	263	23
	Edh at Noon		15	50	79	98	91	90	89	78	58	40	16	3
(44) All-Sky Solar Radiation	RadAvg		0.07	0.59	2.04	3.87	4.93	5.11	4.71	3.52	1.96	0.70	0.14	0.01
	RadStd		0.00	0.09	0.12	0.20	0.48	0.46	0.52	0.34	0.26	0.11	0.02	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page