

ARVIDSJAUR, Sweden

WMO: 021490

Lat: 65.594N

Lon: 19.264E

Elev: 384

StdP: 96.80

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.6	-26.1	-33.1	0.2	-29.5	-29.2	0.3	-26.0	9.9	-0.4	8.7	-3.0	0.7	300	0.721

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	24.7	15.7	22.6	14.8	20.6	13.9	17.1	22.2	16.1	20.6	15.0	19.4	3.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	11.3	18.5	14.1	10.5	17.7	13.1	9.8	16.5	49.4	22.2	46.3	20.5	43.2	19.5	20.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.0	7.0	-32.8	27.0	3.5	2.6	-35.3	28.9	-37.3	30.4	-39.3	31.9	-41.8	33.8		
(5)			-33.4	18.3	3.0	1.2	-35.5	19.2	-37.3	19.9	-39.0	20.5	-41.2	21.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.1	-11.4	-10.0	-6.0	0.0	6.3	11.2	14.8	12.4	7.6	0.6	-5.4	-8.3
	DBStd	10.27	7.46	7.47	5.63	3.98	4.02	3.66	3.06	3.17	3.34	4.33	5.60	7.10
	HDD10.0	3592	662	561	496	299	130	27	1	12	85	291	461	567
	HDD18.3	6316	921	794	754	549	374	215	117	185	322	548	711	826
	CDD10.0	328	0	0	0	0	14	63	149	87	13	1	0	0
	CDD18.3	11	0	0	0	0	0	2	7	2	0	0	0	0
	CDH23.3	126	0	0	0	0	3	28	78	16	0	0	0	0
	CDH26.7	16	0	0	0	0	0	3	12	1	0	0	0	0
(14) Wind	WSAvg	3.0	2.4	2.6	3.4	3.2	3.4	3.7	3.2	2.9	3.2	2.9	2.4	2.6
(15) Precipitation	PrecAvg	588	36	29	25	28	43	63	89	77	63	50	48	37
	PrecMax	875	58	52	54	50	78	130	147	150	156	97	101	56
	PrecMin	443	16	8	11	10	9	17	19	20	16	16	17	20
	PrecStd	121	12	13	13	12	20	31	33	42	38	25	26	11
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.3	5.4	7.4	14.9	23.2	26.6	28.2	25.3	18.9	11.7	7.1	4.9
		MCWB	3.4	3.1	3.4	7.8	13.1	16.0	17.4	16.9	13.0	8.9	5.5	3.0
	2%	DB	2.5	3.9	5.0	11.1	20.0	23.1	25.5	22.9	16.3	9.6	5.0	3.1
		MCWB	1.1	1.9	2.0	5.0	12.1	13.9	16.2	15.8	11.8	7.4	3.9	1.6
	5%	DB	0.5	1.8	3.7	8.6	17.0	20.5	23.3	20.6	14.5	8.1	3.1	1.8
		MCWB	-0.5	0.1	1.2	4.2	10.4	12.8	15.5	15.0	11.0	6.3	2.0	0.7
	10%	DB	-1.3	-0.1	2.2	6.6	13.8	18.3	21.3	18.3	13.0	6.8	1.6	0.6
		MCWB	-1.9	-1.1	0.1	3.1	8.4	11.7	14.5	13.7	10.4	5.3	0.9	-0.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.4	3.3	3.7	7.9	14.3	16.9	18.7	18.2	14.1	9.4	6.0	3.2
		MCDB	5.1	5.2	6.4	13.8	20.3	23.6	24.4	22.8	16.3	10.7	7.1	4.6
	2%	WB	1.3	2.0	2.4	6.0	12.7	15.3	17.5	16.7	12.7	7.8	4.0	1.9
		MCDB	2.3	3.7	4.7	10.2	18.8	21.1	22.9	21.0	15.1	9.2	5.1	2.8
	5%	WB	-0.4	0.2	1.3	4.5	10.8	13.8	16.5	15.7	11.7	6.6	2.1	0.8
		MCDB	0.3	1.3	3.5	8.0	16.0	18.6	21.4	19.3	13.9	7.9	2.9	1.5
	10%	WB	-1.9	-1.1	0.2	3.2	8.8	12.4	15.5	14.5	10.7	5.5	1.0	-0.3
		MCDB	-1.3	-0.2	1.9	6.4	13.4	17.0	20.1	17.8	12.6	6.7	1.5	0.4
(35) Mean Daily Temperature Range	5% DB	MDBR	7.6	8.1	9.4	8.8	9.2	8.7	8.8	8.3	7.5	5.7	5.8	7.3
		MCDBR	7.2	7.2	8.7	11.8	14.8	12.4	12.3	12.3	9.9	7.0	5.5	7.0
		MCWBR	6.5	6.3	6.8	7.1	7.8	5.2	5.1	6.1	6.3	5.4	5.0	6.5
	5% WB	MCDBR	6.8	7.0	8.4	10.8	13.7	11.2	10.7	10.3	8.5	6.4	5.2	6.6
		MCWBR	6.3	6.2	6.8	6.7	7.7	5.4	5.2	5.6	5.9	5.1	4.9	6.2
(40) Clear-Sky Solar Irradiance	taub	0.179	0.251	0.283	0.313	0.327	0.328	0.340	0.325	0.297	0.277	0.337	N/A	
	taud	1.952	2.182	2.246	2.321	2.484	2.514	2.492	2.522	2.582	2.434	2.773	N/A	
	Ebn at Noon	312	638	792	857	882	887	863	843	798	623	312	N/A	
	Edh at Noon	19	52	80	96	91	91	90	79	60	42	19	N/A	
(44) All-Sky Solar Radiation	RadAvg	0.11	0.69	2.21	4.05	4.93	5.20	4.77	3.61	2.05	0.79	0.18	0.02	
	RadStd	0.01	0.12	0.17	0.22	0.56	0.44	0.52	0.38	0.26	0.13	0.03	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page