

VIDSEL, Sweden

WMO: 021540

Lat: 65.875N

Lon: 20.150E

Elev: 597

StdP: 14.38

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.6	-18.5	-30.0	1.0	-24.6	-23.3	1.6	-18.4	19.7	33.6	15.9	29.5	1.4	280	0.661

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.1	78.3	61.5	74.6	60.2	71.1	58.8	64.5	74.0	62.4	70.8	60.4	68.2	6.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.1	82.1	67.0	58.9	76.0	65.3	57.0	70.9	63.3	29.9	74.4	28.3	70.8	27.0	68.1	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.5	14.4	12.2	-30.4	82.6	5.7	4.4	-34.5	85.8	-37.8	88.3	-41.0	90.8	-45.2	93.9		
			-30.6	66.8	5.7	2.4	-34.7	68.5	-38.0	69.9	-41.2	71.3	-45.4	73.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	34.1	11.0	12.2	21.7	33.3	43.9	53.8	59.5	55.2	46.2	33.6	21.9	15.1		
	DBStd	19.59	14.59	14.99	11.06	7.26	7.21	6.62	5.21	5.99	6.41	8.40	11.58	14.25		
	HDD50	6495	1210	1059	876	501	217	32	1	19	147	508	844	1081		
	HDD65	11312	1675	1479	1341	951	654	342	186	309	563	972	1294	1546		
	CDD50	681	0	0	0	0	28	145	295	179	34	0	0	0		
	CDD65	24	0	0	0	0	0	5	15	4	0	0	0	0		
	CDH74	377	0	0	0	0	14	94	192	77	0	0	0	0		
	CDH80	55	0	0	0	0	0	15	32	8	0	0	0	0		
	WSAvg	4.6	3.4	4.2	5.3	5.1	5.8	6.3	5.1	4.6	4.7	4.2	3.3	3.5		
	PrecAvg	25.2	1.8	1.3	1.3	1.2	1.9	3.1	3.7	3.3	2.4	1.8	1.9	1.7		
Precipitation	PrecMax	50.1	4.4	3.4	2.4	3.4	6.3	7.9	9.2	6.9	7.8	5.8	3.4	5.2		
	PrecMin	14.5	0.1	0.2	0.2	0.2	0.3	0.7	0.7	0.9	0.4	0.4	0.4	0.3		
	PrecStd	7.6	0.9	0.7	0.6	0.7	1.1	1.4	1.7	1.8	1.7	1.1	0.9	1.1		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.3	44.3	48.2	60.9	75.8	81.7	83.9	80.6	69.2	54.5	47.1	43.0		
		MCWB	39.1	39.6	40.9	48.5	56.4	61.3	65.0	64.4	57.8	48.9	43.2	39.1		
	2%	DB	39.4	40.7	43.7	53.9	69.7	76.3	79.2	75.6	63.6	51.1	42.4	39.6		
		MCWB	36.0	36.4	37.7	43.7	55.0	59.0	62.5	61.5	55.4	47.3	40.0	36.5		
	5%	DB	34.8	36.4	40.9	49.6	63.6	71.6	75.3	72.0	60.3	48.8	39.0	36.5		
		MCWB	32.5	33.3	36.1	41.1	51.1	57.2	61.3	60.4	53.6	45.5	37.1	34.4		
	10%	DB	30.8	32.6	38.0	46.0	58.3	67.5	71.7	67.7	57.5	45.8	36.3	33.8		
		MCWB	29.6	30.6	33.8	39.1	47.9	55.3	59.9	58.4	52.2	42.9	34.8	32.5		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.4	39.9	41.1	48.2	59.3	63.9	67.5	66.6	59.3	50.6	43.4	39.4		
		MCDB	43.1	44.0	47.7	59.9	71.6	77.1	75.3	77.5	64.7	52.6	46.2	42.2		
	2%	WB	36.1	36.7	38.2	44.3	55.9	61.2	65.2	63.7	57.0	48.1	40.1	36.7		
		MCDB	38.8	40.2	42.9	52.4	68.0	71.5	74.6	72.2	62.2	50.4	42.2	39.0		
	5%	WB	32.6	33.3	36.2	41.9	51.9	58.8	63.3	61.4	54.8	45.6	37.3	34.6		
		MCDB	34.3	35.9	40.5	48.8	61.6	68.7	71.9	68.9	59.0	48.3	38.8	36.1		
	10%	WB	29.6	30.8	33.9	39.5	48.9	56.5	61.4	59.3	53.0	43.2	35.0	32.5		
		MCDB	30.8	32.6	37.7	45.5	57.0	65.8	69.3	66.3	56.4	45.7	36.1	33.7		
Mean Daily Temperature Range	5% DB	MDBR	16.0	17.8	19.4	17.9	18.3	16.9	17.1	18.3	16.6	12.5	11.8	14.5		
		MCDBR	16.5	16.9	18.3	24.0	29.3	25.0	25.0	26.3	21.6	14.8	11.6	13.9		
		MCWBR	14.4	13.9	13.9	14.9	15.8	11.4	11.1	13.7	14.1	11.4	10.1	12.5		
	5% WB	MCDBR	15.2	15.9	17.2	22.6	27.0	21.2	20.8	21.9	18.6	13.4	10.5	12.9		
		MCWBR	13.5	13.6	13.3	14.4	15.2	10.6	10.8	12.3	12.8	10.7	9.3	11.9		
Clear-Sky Solar Irradiance	taub		0.187	0.258	0.291	0.322	0.336	0.339	0.350	0.334	0.304	0.283	0.338	N/A		
	taud		1.954	2.166	2.232	2.315	2.467	2.492	2.473	2.505	2.569	2.415	2.725	N/A		
	Ebn at Noon		87	195	246	268	276	277	270	263	249	191	89	N/A		
	Edh at Noon		6	16	26	30	29	29	29	25	19	13	6	N/A		
All-Sky Solar Radiation	RadAvg		30	213	696	1276	1563	1667	1544	1151	654	246	53	6		
	RadStd		2	33	54	71	162	137	155	110	90	42	8	0		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page