

ALVSBY, Sweden

WMO: 021730

Lat: 65.6691N

Lon: 21.0620E

Elev: 141

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.7	-22.3	-33.9	0.8	-27.7	-28.1	1.1	-22.2	18.4	34.4	16.1	30.1	0.8	110	0.661

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	79.1	64.5	75.6	62.4	72.1	60.7	66.5	75.3	64.3	72.9	62.3	69.6	7.1	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.3	87.4	70.5	61.0	80.7	67.9	59.0	74.8	65.3	31.2	75.6	29.6	73.0	28.1	69.7	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.6	14.2	12.1	DB	-32.1	83.3	5.0	4.5	-35.7	86.5	-38.6	89.2	-41.5	91.7	-45.1	95.0	(4)
(5)			WB	-32.2	69.4	4.6	2.5	-35.5	71.1	-38.2	72.6	-40.8	74.0	-44.2	75.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	34.0	9.4	10.6	21.4	33.6	45.0	53.5	59.2	55.4	46.6	34.2	22.7	15.1
	DBStd	20.04	15.40	15.55	11.41	7.14	6.69	6.11	5.17	5.89	6.32	8.49	11.75	15.10
	HDD50	6504	1258	1104	886	493	184	31	1	19	137	490	820	1081
	HDD65	11322	1723	1524	1351	943	619	347	190	303	551	955	1270	1546
	CDD50	675	0	0	0	0	30	137	287	185	36	0	0	0
	CDD65	18	0	0	0	0	0	3	11	4	0	0	0	0
	CDH74	474	0	0	0	0	23	99	263	89	0	0	0	0
	CDH80	65	0	0	0	0	1	19	39	6	0	0	0	0
Wind	WSAvg	4.8	3.8	3.9	5.2	5.3	6.1	6.1	5.2	4.6	4.9	4.3	3.8	4.1
Precipitation	PrecAvg	22.3	1.5	1.2	1.1	1.1	1.5	2.2	3.1	2.8	2.3	1.9	1.9	1.6
	PrecMax	29.8	2.8	2.2	2.4	2.2	2.6	3.6	5.7	6.2	7.9	4.1	3.7	3.5
	PrecMin	15.8	0.1	0.4	0.4	0.4	0.3	0.4	0.8	0.8	0.4	0.5	0.6	0.3
	PrecStd	4.3	0.6	0.6	0.6	0.5	0.6	0.8	1.5	1.5	1.9	0.9	0.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.3	45.4	49.0	63.0	77.0	82.5	84.0	80.7	69.0	56.1	47.5	43.4
		MCWB	39.6	40.0	40.9	48.9	57.0	64.0	67.0	67.4	58.6	49.4	43.2	38.8
	2%	DB	38.7	41.4	44.8	55.2	71.6	76.1	80.0	76.4	64.4	52.5	43.6	39.6
		MCWB	35.1	36.7	38.2	45.0	57.2	60.4	65.3	64.2	56.3	47.9	40.8	36.2
	5%	DB	34.2	36.2	41.8	51.2	65.4	71.8	76.8	72.5	61.5	49.6	40.0	36.8
		MCWB	32.5	33.3	36.2	42.4	53.1	58.5	63.7	62.3	54.5	46.5	37.7	34.6
	10%	DB	31.2	32.5	38.4	47.2	60.5	68.0	73.0	68.6	58.4	46.6	37.3	34.5
		MCWB	30.1	30.8	33.7	39.8	49.4	56.6	62.4	60.2	53.3	44.0	35.9	33.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.8	40.3	41.5	49.6	60.8	66.1	69.7	69.4	60.1	51.1	43.9	39.1
		MCDB	44.1	44.9	48.6	61.0	74.0	79.0	80.1	77.8	64.9	54.3	46.2	42.6
	2%	WB	35.6	36.9	38.6	45.6	57.5	62.8	67.3	65.8	57.9	48.8	40.8	37.0
		MCDB	38.1	40.7	43.8	53.9	69.5	72.6	75.9	73.3	62.8	51.7	43.2	39.1
	5%	WB	32.8	33.7	36.6	42.9	53.7	59.8	65.3	63.4	56.0	46.5	38.1	34.8
		MCDB	34.3	35.9	41.3	50.3	64.2	68.5	73.9	70.3	59.6	49.1	39.6	36.4
	10%	WB	30.0	30.9	34.1	40.2	50.6	57.7	63.4	61.1	54.3	44.4	35.9	33.1
		MCDB	31.1	32.6	37.5	46.8	59.2	66.1	71.3	67.3	57.7	46.7	37.0	34.5
Mean Daily Temperature Range	5% DB	MDBR	17.6	20.1	22.4	20.5	21.9	21.2	21.7	21.4	19.2	14.5	12.9	16.0
		MCDBR	18.0	20.2	21.9	26.8	32.7	29.6	29.7	28.1	24.2	18.7	13.9	16.6
		MCWBR	16.3	17.4	16.3	17.2	19.1	15.6	16.0	17.1	16.4	14.2	12.1	15.0
	5% WB	MCDBR	17.0	19.1	20.8	26.1	31.1	24.8	24.9	24.5	20.0	16.6	12.6	14.7
		MCWBR	15.5	16.5	15.8	17.1	18.6	14.2	14.8	16.0	14.4	13.1	11.2	13.6
Clear-Sky Solar Irradiance	taub	N/A	0.269	0.301	0.334	0.343	0.347	0.360	0.344	0.314	0.293	0.338	0.352	
	taud	N/A	2.158	2.234	2.330	2.454	2.479	2.459	2.493	2.558	2.398	2.655	2.678	
	Ebn at Noon	N/A	191	243	264	274	275	266	260	245	187	86	31	
	Edh at Noon	N/A	17	26	30	30	30	30	26	19	14	6	3	
All-Sky Solar Radiation	RadAvg	33	220	710	1280	1559	1694	1576	1170	670	254	55	7	
	RadStd	3	35	59	77	158	136	149	108	95	44	8	0	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page