

ALVSBY, Sweden

WMO: 021730

Lat: 65.6691N

Lon: 21.0620E

Elev: 43

StdP: 100.81

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-33.2	-30.1	-36.6	0.1	-33.1	-33.4	0.2	-30.1	8.2	1.4	7.2	-1.0	0.3	110	0.661

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	26.2	18.0	24.2	16.9	22.3	15.9	19.2	24.1	18.0	22.7	16.8	20.9	3.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	12.5	21.4	16.1	11.5	20.0	15.0	10.7	18.5	54.8	24.2	50.9	22.8	47.4	21.0	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.4	6.3	5.4	-35.6	28.5	2.8	2.5	-37.6	30.3	-39.2	31.8	-40.8	33.2	-42.8	35.0	
			DB												
			WB	-35.7	20.8	2.6	1.4	-37.5	21.7	-39.0	22.5	-40.5	23.3	-42.3	24.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.1	-12.5	-11.9	-5.9	0.9	7.2	12.0	15.1	13.0	8.1	1.2	-5.2	-9.4
	DBStd	11.13	8.56	8.64	6.34	3.96	3.72	3.40	2.87	3.27	3.51	4.72	6.53	8.39
	HDD10.0	3613	699	613	492	274	102	17	1	11	76	272	456	601
	HDD18.3	6290	957	847	751	524	344	193	106	168	306	531	706	859
	CDD10.0	375	0	0	0	0	17	76	159	103	20	0	0	0
	CDD18.3	10	0	0	0	0	0	2	6	2	0	0	0	0
	CDH23.3	263	0	0	0	0	13	55	146	49	0	0	0	0
	CDH26.7	36	0	0	0	0	1	11	22	3	0	0	0	0
Wind	WSAvg	2.1	1.7	1.7	2.3	2.4	2.7	2.7	2.3	2.1	2.2	1.9	1.7	1.8
Precipitation	PrecAvg	566	37	30	27	28	37	55	80	71	59	49	48	41
	PrecMax	758	71	56	61	55	66	91	146	157	200	104	93	88
	PrecMin	402	2	9	11	10	7	9	21	20	11	13	16	8
	PrecStd	109	16	14	15	12	15	21	37	38	48	23	24	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.8	7.4	9.5	17.2	25.0	28.0	28.9	27.0	20.6	13.4	8.6	6.3
		MCWB	4.2	4.4	5.0	9.4	13.9	17.8	19.4	19.7	14.8	9.6	6.2	3.8
	2%	DB	3.7	5.2	7.1	12.9	22.0	24.5	26.7	24.7	18.0	11.4	6.4	4.2
		MCWB	1.7	2.6	3.4	7.2	14.0	15.8	18.5	17.9	13.5	8.8	4.9	2.3
	5%	DB	1.2	2.4	5.4	10.7	18.5	22.1	24.9	22.5	16.4	9.8	4.5	2.7
		MCWB	0.3	0.7	2.3	5.8	11.7	14.7	17.6	16.9	12.5	8.1	3.2	1.5
	10%	DB	-0.5	0.3	3.5	8.5	15.8	20.0	22.8	20.4	14.7	8.1	2.9	1.4
		MCWB	-1.1	-0.6	0.9	4.3	9.7	13.7	16.9	15.7	11.8	6.7	2.1	0.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.3	4.6	5.3	9.8	16.0	18.9	20.9	20.8	15.6	10.6	6.6	3.9
		MCDB	6.7	7.2	9.2	16.1	23.3	26.1	26.7	25.4	18.3	12.4	7.9	5.9
	2%	WB	2.0	2.7	3.7	7.6	14.2	17.1	19.6	18.8	14.4	9.4	4.9	2.8
		MCDB	3.4	4.8	6.6	12.2	20.8	22.6	24.4	22.9	17.1	10.9	6.2	3.9
	5%	WB	0.4	1.0	2.5	6.0	12.1	15.5	18.5	17.5	13.3	8.0	3.4	1.5
		MCDB	1.3	2.2	5.2	10.2	17.9	20.3	23.3	21.3	15.3	9.5	4.2	2.4
	10%	WB	-1.1	-0.6	1.2	4.6	10.3	14.3	17.4	16.2	12.4	6.9	2.1	0.6
		MCDB	-0.5	0.3	3.1	8.2	15.1	18.9	21.8	19.6	14.3	8.2	2.8	1.4
Mean Daily Temperature Range		MDBR	9.8	11.2	12.5	11.4	12.2	11.8	12.1	11.9	10.6	8.0	7.2	8.9
	5% DB	MCDBR	10.0	11.2	12.1	14.9	18.2	16.4	16.5	15.6	13.4	10.4	7.7	9.2
		MCWBR	9.0	9.6	9.1	9.5	10.6	8.7	8.9	9.5	9.1	7.9	6.7	8.3
	5% WB	MCDBR	9.4	10.6	11.5	14.5	17.3	13.8	13.8	13.6	11.1	9.2	7.0	8.2
		MCWBR	8.6	9.2	8.8	9.5	10.3	7.9	8.2	8.9	8.0	7.3	6.2	7.5
Clear-Sky Solar Irradiance	taub	N/A	0.269	0.301	0.334	0.343	0.347	0.360	0.344	0.314	0.293	0.338	0.352	
	taud	N/A	2.158	2.234	2.330	2.454	2.479	2.459	2.493	2.558	2.398	2.655	2.678	
	Ebn at Noon	N/A	601	765	832	863	866	840	820	773	590	271	97	
	Edh at Noon	N/A	54	82	96	94	94	93	82	61	44	18	10	
All-Sky Solar Radiation	RadAvg	0.10	0.69	2.24	4.03	4.92	5.34	4.97	3.69	2.11	0.80	0.17	0.02	
	RadStd	0.01	0.11	0.18	0.24	0.50	0.43	0.47	0.34	0.30	0.14	0.03	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page