

OVERKALIX-SVARTBYN, Sweden

WMO: 021810

Lat: 66.262N

Lon: 22.843E

Elev: 203

StdP: 14.59

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.1	-17.5	-29.3	1.1	-23.1	-23.1	1.5	-17.4	16.4	28.3	14.6	27.8	0.4	330	0.643

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	77.9	62.9	74.4	61.4	71.1	59.9	65.6	73.7	63.5	71.0	61.6	68.4	5.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.7	85.8	68.6	60.4	78.9	66.2	58.5	73.9	64.5	30.5	73.3	28.9	71.1	27.6	68.6	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	11.9	10.1	-29.1	82.7	7.0	4.0	-34.2	85.5	-38.3	87.9	-42.2	90.1	-47.3	93.0		
(5)			-29.6	68.4	6.8	2.1	-34.5	70.0	-38.4	71.2	-42.2	72.4	-47.2	74.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	34.5	10.8	12.1	21.1	32.7	44.4	54.5	60.6	56.2	47.0	34.6	23.1	15.5		
	DBStd	19.74	14.55	14.25	10.59	6.97	7.10	6.08	5.43	5.53	6.48	8.20	11.36	13.69		
	HDD50	6420	1214	1060	896	520	204	24	1	12	133	479	808	1069		
	HDD65	11158	1679	1480	1361	970	640	318	158	275	541	944	1258	1534		
	CDD50	765	0	0	0	0	30	159	329	205	42	0	0	0		
	CDD65	27	0	0	0	0	0	3	21	3	0	0	0	0		
	CDH74	343	0	0	0	0	18	51	240	34	0	0	0	0		
	CDH80	46	0	0	0	0	2	2	41	1	0	0	0	0		
	WSAvg	4.1	3.3	4.0	4.7	4.5	5.0	4.8	4.1	3.7	4.0	3.9	3.6	3.5		
	PrecAvg	22.5	1.6	1.3	1.2	1.2	1.5	2.2	2.9	2.5	2.2	1.9	2.1	1.8		
(15) Precipitation	PrecMax	30.9	3.1	2.9	2.3	3.0	4.8	3.4	4.6	5.5	5.1	3.6	4.0	4.4		
	PrecMin	16.6	0.2	0.2	0.4	0.3	0.2	0.3	1.0	0.6	0.6	0.5	0.7	0.3		
	PrecStd	3.9	0.7	0.7	0.6	0.7	0.9	0.9	0.9	1.1	1.1	0.9	0.9	0.9		
	PrecStd	3.9	0.7	0.7	0.6	0.7	0.9	0.9	0.9	1.1	1.1	0.9	0.9	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.8	42.5	46.3	57.9	75.9	79.8	84.5	77.8	66.1	52.8	44.8	39.9		
		MCWB	37.1	37.8	38.9	46.6	59.4	62.5	66.2	64.1	57.2	48.2	42.2	36.8		
	2%	DB	34.9	36.5	41.9	51.7	68.5	75.0	79.9	74.1	62.7	50.3	41.4	36.1		
		MCWB	32.9	33.7	35.8	42.5	54.5	59.3	64.3	62.4	55.0	47.8	40.1	35.1		
	5%	DB	32.5	33.2	38.5	47.4	62.7	71.3	76.2	70.6	59.9	48.2	38.5	34.3		
		MCWB	31.8	32.0	33.7	39.9	50.7	57.6	63.1	60.8	54.1	46.1	37.5	33.5		
	10%	DB	30.5	31.3	34.9	43.8	58.0	67.3	72.6	67.2	57.3	45.5	36.2	32.9		
		MCWB	29.7	30.5	31.9	37.5	48.1	55.8	61.5	59.3	52.9	43.7	35.4	32.2		
	0.4%	WB	37.2	38.1	39.5	46.9	60.1	64.9	69.2	67.0	59.0	50.4	43.1	37.6		
		MCDB	40.4	41.9	45.8	56.7	73.1	75.4	79.2	74.1	62.8	51.4	43.9	39.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	33.5	34.1	36.4	43.1	55.5	61.8	66.7	64.4	57.0	48.3	40.2	35.4		
		MCDB	34.3	35.8	41.0	50.4	65.5	70.7	75.6	70.6	60.6	49.8	41.3	36.1		
	5%	WB	31.9	32.2	34.2	40.4	52.0	59.2	64.7	62.2	55.5	46.3	37.7	33.7		
		MCDB	32.5	33.2	37.1	46.5	60.9	68.2	72.8	67.8	58.5	48.0	38.5	34.3		
	10%	WB	29.7	30.3	32.5	38.2	49.1	57.2	62.8	60.2	53.7	43.9	35.5	32.2		
		MCDB	30.5	31.3	34.5	43.1	56.6	64.9	70.4	65.8	56.5	45.5	36.1	32.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.8	14.9	17.5	16.4	17.8	17.0	17.6	16.9	14.8	10.5	10.3	13.1		
		MCDBR	12.3	12.6	17.9	21.8	27.0	24.4	24.7	22.6	17.9	12.3	8.2	9.6		
		MCWBR	11.6	10.9	13.3	13.5	14.3	11.2	11.1	12.0	11.3	9.7	7.5	8.9		
		MCDBR	11.3	12.0	15.4	20.4	25.0	20.7	20.8	19.1	14.5	10.8	7.9	8.9		
	5% WB	MCWBR	10.9	10.6	11.8	13.1	13.9	10.8	10.9	11.0	9.9	9.1	7.4	8.5		
		MCWBR	10.9	10.6	11.8	13.1	13.9	10.8	10.9	11.0	9.9	9.1	7.4	8.5		
(40) Clear-Sky Solar Irradiance	taub		0.198	0.267	0.298	0.332	0.343	0.346	0.359	0.343	0.315	0.291	0.341	0.355		
	taud		1.944	2.125	2.200	2.280	2.452	2.474	2.454	2.488	2.545	2.373	2.649	2.674		
	Ebn at Noon		71	184	240	262	273	274	266	259	242	181	74	21		
	Edh at Noon		5	17	26	31	30	30	30	26	19	14	5	3		
(44) All-Sky Solar Radiation	RadAvg		24	191	666	1225	1558	1699	1590	1164	632	228	44	3		
	RadStd		2	31	65	74	155	135	146	97	85	42	6	0		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (41 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page