

PAHAROVA, Sweden

WMO: 021840

Lat: 66.809N

Lon: 22.331E

Elev: 747

StdP: 14.30

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.1	-10.7	-25.2	1.4	-15.1	-17.3	2.2	-10.6	14.4	23.2	13.1	22.7	1.0	60	0.664

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	77.1	61.9	73.4	59.9	70.0	58.5	64.6	73.5	62.4	69.7	60.3	67.0	5.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.3	83.4	67.5	59.3	77.4	65.1	57.4	72.2	63.2	30.1	73.5	28.4	69.6	27.0	67.0	71.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
13.6	11.8	10.1	DB	-21.3	81.1	6.2	5.2	-25.8	84.8	-29.4	87.9	-32.9	90.8	-37.4	94.6	
			WB	-21.3	67.3	6.3	2.8	-25.9	69.4	-29.6	71.0	-33.1	72.6	-37.8	74.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	34.2	11.2	12.2	21.7	33.1	44.8	53.5	59.7	55.3	45.8	32.5	21.8	16.8
	DBStd	18.84	12.09	12.16	9.13	6.86	7.95	7.00	6.17	6.14	6.30	8.04	9.74	10.81
	HDD50	6479	1201	1058	877	506	204	40	3	19	154	542	845	1030
	HDD65	11286	1666	1478	1342	956	627	350	189	306	575	1007	1295	1495
	CDD50	705	0	0	0	0	43	146	303	183	30	0	0	0
	CDD65	35	0	0	0	0	1	6	23	5	0	0	0	0
	CDH74	273	0	0	0	0	18	57	165	33	0	0	0	0
	CDH80	36	0	0	0	0	0	10	24	2	0	0	0	0
Wind	WSAvg	4.5	3.2	3.6	5.3	5.3	5.5	5.2	4.8	4.6	4.9	4.6	3.7	3.7
Precipitation	PrecAvg	22.2	1.5	1.2	1.1	1.2	1.7	2.4	3.0	2.4	2.1	2.0	1.9	1.6
	PrecMax	27.9	2.8	2.0	2.0	2.8	2.6	3.6	4.9	4.2	5.9	3.6	3.1	3.2
	PrecMin	14.8	0.2	0.4	0.4	0.1	0.4	0.0	1.2	0.9	0.8	1.0	0.7	0.3
	PrecStd	3.8	0.6	0.4	0.5	0.7	0.6	1.0	1.1	0.9	1.3	0.7	0.7	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.4	40.3	45.7	58.9	76.4	80.6	83.4	78.1	64.7	51.7	42.8	38.2
		MCWB	33.9	36.6	38.2	45.7	56.2	63.9	65.2	64.9	56.2	47.4	41.4	35.7
	2%	DB	32.9	35.1	41.5	51.5	70.6	74.0	78.3	73.3	61.0	48.3	39.6	34.3
		MCWB	31.6	32.4	35.5	41.6	55.7	58.3	62.9	61.9	54.2	46.1	38.2	33.4
	5%	DB	30.4	31.4	37.9	48.0	63.7	69.9	74.8	69.5	58.0	45.8	36.0	32.4
		MCWB	29.5	30.3	33.3	40.1	51.5	55.9	61.3	60.1	53.1	43.8	35.1	31.8
	10%	DB	27.5	29.0	34.3	44.4	58.4	66.0	71.1	65.5	55.3	43.2	33.6	31.1
		MCWB	27.0	28.0	31.1	37.4	47.9	54.4	60.1	58.4	51.7	41.7	32.9	30.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.0	37.0	38.7	46.0	59.0	65.1	67.7	67.6	58.0	48.9	42.1	36.0
		MCDB	38.3	40.0	46.1	56.6	72.1	77.4	77.0	75.1	61.7	49.9	42.4	37.3
	2%	WB	32.1	32.7	35.8	42.9	56.1	61.1	65.3	63.8	55.8	46.3	38.2	33.6
		MCDB	32.6	34.5	40.3	50.3	69.2	69.4	74.9	70.2	59.1	48.1	39.4	34.2
	5%	WB	29.6	30.4	33.8	40.2	52.1	58.0	63.2	61.4	54.0	44.3	35.4	32.0
		MCDB	30.2	31.4	37.3	46.8	62.1	65.9	71.3	67.0	56.8	45.8	36.1	32.4
	10%	WB	27.0	28.0	31.6	38.1	48.9	55.6	61.3	59.1	52.3	41.9	32.9	30.5
		MCDB	27.6	29.1	33.8	43.9	57.1	63.3	68.7	63.9	54.9	43.2	33.4	31.0
Mean Daily Temperature Range	5% DB	MDBR	10.8	11.8	14.8	14.6	15.9	16.4	16.0	15.2	13.1	9.3	8.9	10.3
		MCDBR	9.9	10.9	16.2	18.8	24.1	21.4	21.0	20.4	16.6	11.1	7.7	8.8
		MCWBR	9.8	10.0	11.6	11.2	12.5	10.1	10.0	10.3	10.5	8.7	7.2	8.7
	5% WB	MCDBR	9.9	10.5	14.9	18.0	22.5	18.7	18.4	17.6	13.6	10.0	7.7	8.5
		MCWBR	9.8	9.8	11.2	11.0	12.4	10.1	10.0	10.1	9.2	8.2	7.3	8.4
Clear-Sky Solar Irradiance	taub	0.187	0.253	0.287	0.318	0.333	0.338	0.347	0.331	0.302	0.277	0.340	N/A	
	taud	1.939	2.136	2.220	2.284	2.468	2.486	2.472	2.503	2.562	2.385	2.732	N/A	
	Ebn at Noon	64	187	244	266	276	276	269	262	246	184	72	0	
	Edh at Noon	4	16	25	31	29	29	29	25	19	13	5	0	
All-Sky Solar Radiation	RadAvg	21	185	660	1236	1535	1637	1538	1126	613	217	41	0	
	RadStd	2	27	56	67	155	125	148	91	83	38	5	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page