

PAHAROVA, Sweden

WMO: 021840

Lat: 66.809N

Lon: 22.331E

Elev: 228

StdP: 98.62

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -26.7	(c) -23.7	(d) -31.8	(e) 0.2	(f) -26.2	(g) -27.4	(h) 0.3	(i) -23.7	(j) 6.4	(k) -4.9	(l) 5.8	(m) -5.1	(n) 0.5	(o) 60	(p) 0.664

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.9	(c) 25.1	(d) 16.6	(e) 23.0	(f) 15.5	(g) 21.1	(h) 14.7	(i) 18.1	(j) 23.1	(k) 16.9	(l) 20.9	(m) 15.7	(n) 19.4	(o) 2.5	(p) 170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.3	11.9	19.7	15.2	11.1	18.4	14.1	10.3	17.3	52.0	23.0	48.2	20.9	44.8	19.5	22.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.1	(b) 5.3	(c) 4.5	(e) -29.6	(f) 27.3	(g) 3.4	(h) 2.9	(i) -32.1	(j) 29.4	(k) -34.1	(l) 31.0	(m) -36.0	(n) 32.7	(o) -38.5	(p) 34.8		
(a) 6.1	(b) 5.3	(c) 4.5	(e) -29.6	(f) 19.6	(g) 3.5	(h) 1.6	(i) -32.2	(j) 20.8	(k) -34.2	(l) 21.7	(m) -36.2	(n) 22.5	(o) -38.8	(p) 23.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.2	-11.5	-11.0	-5.7	0.6	7.1	12.0	15.4	12.9	7.7	0.3	-5.6	-8.5		
	DBStd	10.46	6.72	6.76	5.07	3.81	4.42	3.89	3.43	3.41	3.50	4.47	5.41	6.00		
	HDD10.0	3599	667	588	487	281	113	22	2	11	86	301	469	572		
	HDD18.3	6270	926	821	746	531	348	194	105	170	319	559	719	831		
	CDD10.0	392	0	0	0	0	24	81	168	102	17	0	0	0		
	CDD18.3	19	0	0	0	0	1	3	13	3	0	0	0	0		
	CDH23.3	152	0	0	0	0	10	32	92	18	0	0	0	0		
	CDH26.7	20	0	0	0	0	0	6	13	1	0	0	0	0		
	WSAvg	2.0	1.4	1.6	2.4	2.3	2.5	2.3	2.2	2.0	2.2	2.1	1.6	1.6		
	PrecAvg	565	37	31	28	31	43	60	77	60	53	50	47	40		
(15) Precipitation	PrecMax	708	70	50	51	71	65	92	124	106	150	91	79	81		
	PrecMin	376	5	10	10	3	11	1	30	24	21	25	19	7		
	PrecStd	97	16	11	12	17	15	25	28	23	32	17	19	19		
	PrecStd	97	16	11	12	17	15	25	28	23	32	17	19	19		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.6	4.6	7.6	15.0	24.6	27.0	28.5	25.6	18.1	10.9	6.0	3.4		
		MCWB	1.0	2.6	3.5	7.6	13.4	17.7	18.4	18.3	13.5	8.6	5.2	2.0		
	2%	DB	0.5	1.7	5.3	10.8	21.5	23.3	25.7	22.9	16.1	9.1	4.2	1.3		
		MCWB	-0.2	0.2	1.9	5.3	13.1	14.6	17.2	16.6	12.3	7.8	3.4	0.8		
	5%	DB	-0.9	-0.3	3.3	8.9	17.6	21.0	23.8	20.9	14.4	7.7	2.2	0.2		
		MCWB	-1.4	-0.9	0.7	4.5	10.8	13.3	16.3	15.6	11.7	6.6	1.7	-0.1		
	10%	DB	-2.5	-1.7	1.3	6.9	14.7	18.9	21.7	18.6	12.9	6.2	0.9	-0.5		
		MCWB	-2.8	-2.2	-0.5	3.0	8.8	12.4	15.6	14.7	10.9	5.4	0.5	-0.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.2	2.8	3.7	7.8	15.0	18.4	19.8	19.8	14.4	9.4	5.6	2.2		
		MCDB	3.5	4.4	7.8	13.7	22.3	25.2	25.0	24.0	16.5	10.0	5.8	3.0		
	2%	WB	0.1	0.4	2.1	6.0	13.4	16.2	18.5	17.7	13.2	7.9	3.4	0.9		
		MCDB	0.3	1.4	4.6	10.1	20.7	20.8	23.8	21.2	15.1	8.9	4.1	1.2		
	5%	WB	-1.3	-0.9	1.0	4.6	11.2	14.5	17.3	16.3	12.2	6.8	1.9	0.0		
		MCDB	-1.0	-0.4	2.9	8.2	16.7	18.8	21.8	19.5	13.8	7.7	2.3	0.2		
	10%	WB	-2.8	-2.2	-0.2	3.4	9.4	13.1	16.3	15.1	11.3	5.5	0.5	-0.8		
		MCDB	-2.4	-1.6	1.0	6.6	14.0	17.4	20.4	17.7	12.7	6.2	0.8	-0.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.0	6.6	8.2	8.1	8.9	9.1	8.9	8.5	7.3	5.2	4.9	5.7		
		MCDBR	5.5	6.1	9.0	10.4	13.4	11.9	11.7	11.3	9.2	6.2	4.3	4.9		
		MCWBR	5.5	5.5	6.4	6.2	7.0	5.6	5.6	5.7	5.8	4.9	4.0	4.8		
	5% WB	MCDBR	5.5	5.8	8.3	10.0	12.5	10.4	10.2	9.8	7.6	5.6	4.3	4.7		
		MCWBR	5.5	5.4	6.2	6.1	6.9	5.6	5.6	5.6	5.1	4.6	4.1	4.6		
(40) Clear-Sky Solar Irradiance	taub		0.187	0.253	0.287	0.318	0.333	0.338	0.347	0.331	0.302	0.277	0.340	N/A		
	taud		1.939	2.136	2.220	2.284	2.468	2.486	2.472	2.503	2.562	2.385	2.732	N/A		
	Ebn at Noon		201	589	768	840	869	871	849	827	775	579	228	0		
	Edh at Noon		14	50	79	98	91	92	91	79	59	40	15	0		
(44) All-Sky Solar Radiation	RadAvg		0.07	0.58	2.08	3.90	4.84	5.16	4.85	3.55	1.93	0.69	0.13	0.00		
	RadStd		0.01	0.09	0.18	0.21	0.49	0.39	0.47	0.29	0.26	0.12	0.02	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (44 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page