

RODKALLEN, Sweden

WMO: 021880

Lat: 65.312N

Lon: 22.371E

Elev: 2

StdP: 101.30

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-23.2	-20.1	-25.7	0.4	-23.2	-22.3	0.5	-20.0	16.5	-1.3	15.4	-2.4	3.4	350	0.821

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.1	21.5	18.7	19.9	17.4	18.6	16.5	19.2	21.0	17.9	19.4	16.8	18.3	4.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	13.3	20.5	17.2	12.3	19.0	16.1	11.5	17.9	54.6	21.0	50.6	19.5	47.3	18.4	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.9	13.3	11.9	-25.1	22.7	3.9	2.6	-27.9	24.5	-30.2	26.0	-32.4	27.5	-35.2	29.4		
			-24.5	19.5	3.6	1.8	-27.1	20.8	-29.2	21.9	-31.2	22.9	-33.9	24.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.4	-6.3	-7.9	-5.3	-0.6	5.3	11.3	15.8	15.0	10.9	5.1	-0.1	-3.1
	DBStd	9.04	6.05	6.93	5.11	2.80	2.95	2.48	2.55	2.37	2.63	3.09	3.84	5.01
	HDD10.0	2848	505	502	476	319	149	14	0	1	22	151	303	407
	HDD18.3	5461	763	735	734	569	404	211	87	107	223	409	553	665
	CDD10.0	441	0	0	0	0	3	53	180	156	49	1	0	0
	CDD18.3	12	0	0	0	0	0	0	9	3	0	0	0	0
	CDH23.3	6	0	0	0	0	0	0	6	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.9	6.2	6.0	5.8	5.0	5.1	5.2	4.9	5.8	6.4	6.7	6.8	6.9
Precipitation	PrecAvg	497	36	27	21	29	36	51	57	53	51	50	50	38
	PrecMax	744	93	47	53	67	105	114	128	124	146	147	105	84
	PrecMin	270	12	6	7	7	7	2	18	11	11	7	12	11
	PrecStd	127	18	11	13	19	21	30	28	30	30	32	26	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.1	3.3	3.8	6.2	15.3	19.6	23.9	22.1	16.9	11.3	7.7	4.9
		MCWB	1.9	1.8	1.7	3.5	11.0	14.8	20.2	19.3	14.4	9.7	6.5	4.1
	2%	DB	2.1	2.2	2.8	4.7	12.6	17.1	22.5	20.6	15.6	10.5	6.6	3.8
		MCWB	1.3	1.1	1.2	2.9	9.5	13.7	19.5	18.3	13.5	9.4	5.9	3.1
	5%	DB	1.4	1.1	1.9	3.5	10.7	15.8	20.8	19.3	14.9	9.9	5.4	3.1
		MCWB	0.8	0.5	0.7	2.1	8.3	12.9	18.1	17.1	13.2	9.0	4.7	2.4
	10%	DB	0.6	0.3	1.0	2.6	9.3	14.7	19.4	18.4	14.3	9.2	4.7	2.4
		MCWB	0.2	-0.1	0.3	1.5	7.3	12.3	17.1	16.3	12.9	8.2	4.0	1.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.2	2.1	2.2	4.1	12.0	15.5	21.1	20.1	15.1	10.4	7.0	4.4
		MCDB	2.6	2.9	3.1	5.7	13.8	18.2	23.3	21.7	16.2	10.7	7.4	4.7
	2%	WB	1.5	1.2	1.5	3.1	9.5	14.5	19.9	18.6	14.3	9.8	5.6	3.2
		MCDB	1.8	1.8	2.3	4.3	11.5	16.3	22.0	20.1	15.1	10.2	6.0	3.6
	5%	WB	0.9	0.6	0.9	2.3	8.4	13.5	18.7	17.5	13.7	9.2	4.7	2.5
		MCDB	1.3	1.1	1.5	3.2	10.4	15.1	20.5	18.9	14.5	9.8	5.0	3.0
	10%	WB	0.2	0.0	0.4	1.6	7.3	12.7	17.5	16.6	13.2	8.3	4.0	1.8
		MCDB	0.6	0.4	1.0	2.3	9.0	14.2	19.1	18.0	14.1	9.1	4.6	2.3
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.8	6.0	4.4	3.7	3.5	3.1	2.8	2.8	2.7	3.2	3.8
		MCDBR	3.2	4.4	4.2	4.5	6.1	4.9	4.0	3.4	3.0	2.3	2.7	2.6
		MCWBR	3.1	4.2	3.6	3.3	3.7	3.0	2.8	2.5	2.5	2.3	2.9	2.6
	5% WB	MCDBR	3.3	3.9	3.8	4.0	5.5	4.4	3.5	2.8	2.2	2.2	2.7	2.7
		MCWBR	3.3	3.8	3.4	3.0	3.7	3.0	2.8	2.3	2.0	2.4	2.9	2.7
Clear-Sky Solar Irradiance	taub	N/A	0.274	0.301	0.336	0.344	0.349	0.365	0.351	0.323	0.302	0.340	0.349	
	taud	N/A	2.113	2.166	2.213	2.430	2.498	2.474	2.503	2.552	2.374	2.581	2.602	
	Ebn at Noon	N/A	595	762	826	863	866	838	815	764	582	267	101	
	Edh at Noon	N/A	58	88	108	96	93	93	82	63	46	20	11	
All-Sky Solar Radiation	RadAvg	0.09	0.65	2.20	4.00	5.16	5.80	5.31	3.91	2.13	0.78	0.15	0.02	
	RadStd	0.01	0.12	0.21	0.25	0.45	0.45	0.46	0.34	0.27	0.14	0.03	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page