

YLINENJARVI, Sweden

WMO: 021990

Lat: 66.622N

Lon: 23.463E

Elev: 433

StdP: 14.47

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.7	-19.4	-31.5	0.9	-24.5	-25.5	1.4	-19.3	21.6	25.3	18.8	24.9	0.7	300	0.689

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	77.6	62.8	73.9	60.6	70.4	59.3	65.3	74.1	63.1	70.8	61.0	67.5	8.1	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.1	84.8	68.5	59.9	78.3	65.9	58.0	73.1	63.9	30.4	74.1	28.8	70.8	27.3	67.7	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
17.3	15.1	13.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-31.3	80.5	5.0	4.2	-34.9	83.5	-37.8	85.9	-40.7	88.3	-44.3	91.3
			-31.1	68.6	4.9	2.4	-34.7	70.3	-37.6	71.7	-40.4	73.1	-43.9	74.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	32.9	8.3	10.0	19.8	31.8	43.7	52.6	58.6	54.1	45.3	32.4	21.9	15.2
	DBStd	19.67	14.00	14.12	10.53	7.34	7.27	6.38	5.69	6.00	6.51	8.89	11.36	13.25
	HDD50	6831	1292	1120	938	546	224	44	4	29	169	545	843	1077
	HDD65	11716	1757	1540	1403	996	661	374	210	339	591	1010	1293	1542
	CDD50	606	0	0	0	0	28	122	271	157	28	0	0	0
	CDD65	16	0	0	0	0	0	2	12	2	0	0	0	0
	CDH74	298	0	0	0	0	13	42	204	39	0	0	0	0
	CDH80	35	0	0	0	0	0	4	29	2	0	0	0	0
Wind	WSAvg	5.3	4.3	4.8	5.8	5.8	6.3	6.3	5.6	5.2	5.4	5.0	4.7	4.8
Precipitation	PrecAvg	21.2	1.5	1.1	1.3	1.1	1.4	2.0	2.9	2.5	2.0	1.9	1.9	1.6
	PrecMax	28.4	2.7	2.5	2.5	2.8	2.3	3.5	5.0	5.4	4.6	3.7	3.5	4.1
	PrecMin	16.2	0.4	0.2	0.3	0.4	0.1	0.2	0.9	0.6	0.6	0.8	0.9	0.3
	PrecStd	3.5	0.5	0.6	0.6	0.6	0.6	0.9	1.2	1.0	1.1	0.8	0.7	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.0	41.8	46.1	59.0	75.9	78.8	83.8	78.3	64.8	52.6	44.1	39.1
		MCWB	37.0	36.9	38.4	46.0	56.0	62.4	65.7	64.7	55.8	48.1	41.8	36.8
	2%	DB	33.5	35.9	42.1	52.1	70.5	73.7	79.2	73.8	61.7	49.6	41.1	35.7
		MCWB	32.4	33.5	35.8	42.2	55.9	58.1	64.3	61.5	54.6	46.4	39.3	34.6
	5%	DB	31.3	32.4	38.2	48.3	63.6	69.5	75.8	70.0	59.0	47.3	37.6	33.7
		MCWB	30.7	31.3	33.2	40.2	51.4	56.4	62.6	60.7	53.8	44.9	36.6	32.9
	10%	DB	28.1	29.8	34.5	44.4	58.5	65.8	72.0	66.1	56.4	44.5	35.3	32.3
		MCWB	27.5	28.7	31.4	37.4	48.3	55.0	61.0	58.8	52.4	42.5	34.6	31.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.1	37.5	39.2	47.2	59.3	64.6	69.0	67.1	58.5	49.5	42.7	37.2
		MCDB	39.0	41.3	45.7	57.9	71.0	76.4	78.3	75.5	61.4	51.4	43.2	38.4
	2%	WB	32.6	33.4	36.2	43.2	56.3	61.1	66.2	64.3	56.3	47.0	39.2	34.9
		MCDB	33.2	35.2	41.0	50.5	68.7	69.7	76.0	70.8	59.5	49.0	40.7	35.6
	5%	WB	30.6	31.5	33.9	40.4	52.3	58.4	64.3	61.7	54.8	44.9	36.6	33.0
		MCDB	31.1	32.6	36.9	47.4	62.0	65.6	72.7	66.9	57.9	47.0	37.6	33.5
	10%	WB	27.5	28.8	32.1	37.9	49.1	56.4	62.4	59.5	53.0	42.5	34.6	31.8
		MCDB	28.1	29.9	34.1	43.8	57.4	63.8	70.1	64.5	56.1	44.3	35.2	32.3
Mean Daily Temperature Range	5% DB	MDBR	16.3	18.2	20.7	18.3	18.6	18.0	19.4	18.8	16.0	12.4	11.6	14.5
		MCDBR	13.0	13.7	20.8	23.7	29.9	24.7	27.0	26.3	20.7	14.1	8.6	11.2
		MCWBR	12.8	12.0	15.7	14.9	16.3	12.0	13.9	15.8	14.4	11.5	8.0	11.0
	5% WB	MCDBR	13.1	12.8	17.5	22.4	27.2	20.3	22.8	20.8	16.0	12.9	8.4	11.0
		MCWBR	12.9	11.3	13.7	14.5	15.6	11.3	13.1	13.5	11.6	11.1	8.1	10.8
Clear-Sky Solar Irradiance	taub	0.195	0.262	0.294	0.327	0.340	0.343	0.355	0.338	0.311	0.285	0.343	N/A	
	taud	1.937	2.119	2.195	2.268	2.456	2.474	2.457	2.488	2.545	2.365	2.677	N/A	
	Ebn at Noon	64	183	240	263	273	275	267	260	242	180	70	0	
	Edh at Noon	5	16	26	32	30	30	29	26	19	13	5	0	
All-Sky Solar Radiation	RadAvg	23	187	658	1219	1531	1647	1551	1136	618	221	42	0	
	RadStd	2	29	62	73	159	130	147	92	83	40	5	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	Regional (44 neighbors)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page