

GADDEDE 2, Sweden

WMO: 022190

Lat: 64.5044N

Lon: 14.2207E

Elev: 1814

StdP: 13.76

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.7	(c) -3.3	(d) -11.7	(e) 3.1	(f) -7.3	(g) -7.4	(h) 3.9	(i) -2.9	(j) 23.0	(k) 20.1	(l) 21.1	(m) 19.6	(n) 3.8	(o) 100	(p) 0.727

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.9	73.8	58.7	69.5	57.6	65.6	56.2	61.3	69.3	59.3	67.2	57.4	64.1	6.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.4	78.0	63.8	56.2	72.1	61.6	54.2	66.8	59.8	28.1	69.6	26.7	67.2	25.4	64.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 18.5	(b) 16.2	(c) 14.2	(e) -13.4	(f) 77.9	(g) 3.1	(h) 4.6	(i) -15.6	(j) 81.2	(k) -17.4	(l) 83.9	(m) -19.1	(n) 86.5	(o) -21.4	(p) 89.8		
(4) 18.5	(5) 16.2	(6) 14.2	(7) -13.3	(8) 64.6	(9) 3.4	(10) 2.3	(11) -15.8	(12) 66.2	(13) -17.8	(14) 67.6	(15) -19.7	(16) 68.8	(17) -22.2	(18) 70.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	34.9	18.0	18.7	23.1	32.2	41.6	48.8	55.2	52.0	45.1	34.5	26.4	21.7		
	DBStd	15.01	10.14	10.27	8.19	6.62	7.82	6.67	6.54	5.06	5.27	5.74	8.52	9.50		
	HDD50	5907	994	877	834	534	285	101	21	36	161	480	707	877		
	HDD65	11006	1459	1297	1299	984	725	486	312	405	596	944	1157	1342		
	CDD50	386	0	0	0	0	26	66	182	97	14	1	0	0		
	CDD65	10	0	0	0	0	0	1	8	1	0	0	0	0		
	CDH74	107	0	0	0	0	3	17	83	4	0	0	0	0		
	CDH80	7	0	0	0	0	0	0	7	0	0	0	0	0		
	WSAvg	6.9	7.7	7.4	7.6	6.5	6.7	6.9	6.2	6.0	6.6	6.9	6.9	7.2		
	PrecAvg	34.7	3.7	3.0	2.7	1.8	1.7	2.6	3.5	3.2	3.1	3.0	2.8	3.3		
(15) Precipitation	PrecMax	49.8	8.0	9.3	5.8	3.9	3.6	4.3	8.0	7.6	7.4	5.6	6.4	7.4		
	PrecMin	24.6	0.4	0.4	0.3	0.6	0.4	0.3	1.2	1.4	1.0	0.9	0.6	0.7		
	PrecStd	5.9	1.9	2.2	1.6	0.8	0.8	1.0	1.6	1.5	1.6	1.1	1.6	1.8		
	PrecStd	5.9	1.9	2.2	1.6	0.8	0.8	1.0	1.6	1.5	1.6	1.1	1.6	1.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.2	39.3	40.9	57.2	72.3	76.9	80.8	72.3	63.5	52.8	44.7	39.2		
		MCWB	35.3	37.2	34.5	45.7	54.9	58.1	62.0	59.0	55.0	50.0	44.3	38.3		
	2%	DB	35.0	35.9	37.7	50.7	66.2	70.6	76.0	68.0	59.2	47.0	40.9	37.1		
		MCWB	34.1	34.8	35.1	40.9	52.1	56.6	60.7	57.4	52.7	44.9	39.9	36.1		
	5%	DB	33.3	34.1	36.0	45.9	60.8	64.8	71.7	64.6	55.9	44.6	38.0	34.7		
		MCWB	32.9	33.3	34.0	38.5	49.6	53.6	59.2	57.2	51.7	42.9	37.4	33.6		
	10%	DB	31.0	32.0	34.1	41.7	55.4	60.6	67.3	61.6	53.2	42.3	35.7	32.8		
		MCWB	30.5	31.1	32.6	36.4	47.8	51.2	57.4	55.7	49.9	40.9	35.1	31.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.3	37.5	37.3	45.5	56.4	60.4	66.0	62.7	56.9	49.9	44.2	38.9		
		MCDB	36.9	38.8	38.1	56.0	69.2	70.5	75.1	69.3	61.2	51.9	44.5	39.1		
	2%	WB	34.1	35.1	35.9	42.2	53.9	57.9	62.9	60.2	54.1	45.7	40.2	36.0		
		MCDB	34.3	35.7	37.1	49.1	62.7	67.5	71.2	65.2	57.4	46.6	40.7	36.3		
	5%	WB	32.6	33.6	34.3	39.4	51.5	55.7	60.5	58.1	52.0	43.0	37.9	33.5		
		MCDB	32.8	34.2	35.6	44.7	59.9	63.9	69.6	63.0	55.2	44.3	38.3	34.2		
	10%	WB	30.4	31.2	32.7	37.1	48.5	53.0	58.5	56.1	49.9	41.2	35.3	31.8		
		MCDB	30.8	31.9	34.1	40.5	56.3	59.2	66.7	61.0	52.6	42.4	35.7	32.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	10.3	12.8	13.3	14.9	15.3	15.9	14.5	11.1	7.9	7.6	9.3		
		MCDBR	7.8	8.5	11.4	19.1	24.7	22.0	22.6	19.2	16.3	10.3	8.2	8.6		
		MCWBR	7.6	7.7	9.3	11.2	13.0	10.9	10.1	10.4	10.3	7.8	7.3	8.0		
		MCDBR	7.9	8.4	9.8	16.4	22.0	19.0	20.1	16.4	14.1	9.4	8.2	8.3		
	5% WB	MCWBR	7.9	7.9	8.3	10.0	12.5	10.4	10.1	9.7	9.7	8.0	7.5	7.9		
		MCWBR	7.9	7.9	8.3	10.0	12.5	10.4	10.1	9.7	9.7	8.0	7.5	7.9		
(40) Clear-Sky Solar Irradiance	taub		0.186	0.256	0.286	0.318	0.326	0.324	0.334	0.322	0.299	0.280	0.348	0.185		
	taud		1.942	2.173	2.222	2.288	2.454	2.509	2.494	2.515	2.569	2.430	2.769	1.944		
	Ebn at Noon		118	208	253	272	281	284	277	270	255	205	113	41		
	Edh at Noon		8	18	27	32	30	29	29	26	20	14	7	3		
(44) All-Sky Solar Radiation	RadAvg		39	189	609	1188	1479	1593	1481	1111	615	247	62	16		
	RadStd		4	36	80	103	112	142	177	114	74	30	9	1		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page