

KORSVATTNET, Sweden

WMO: 022210

Lat: 63.839N

Lon: 13.501E

Elev: 717

StdP: 93.00

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.0	-19.3	-24.9	0.4	-21.4	-22.3	0.6	-18.7	15.5	-2.4	13.9	-2.6	3.4	30	0.790

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	21.8	14.5	19.7	13.6	17.6	12.7	15.8	20.0	14.6	18.2	13.4	16.7	3.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	10.9	17.5	12.9	10.1	16.2	11.7	9.4	14.9	46.8	20.1	43.1	18.2	39.9	16.9	19.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.9	11.0	9.4	-25.9	24.6	2.3	2.4	-27.6	26.3	-28.9	27.7	-30.2	29.0	-31.8	30.7		
(5)			DB	WB	-26.3	16.8	2.6	1.7	-28.2	18.0	-29.7	19.0	-31.2	20.0	-33.1	21.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.9	-7.7	-7.6	-6.2	-1.5	3.4	8.6	12.1	10.6	6.7	1.0	-3.5	-6.1
	DBStd	8.15	5.34	5.53	4.81	3.64	3.78	3.84	3.59	3.14	3.14	3.42	4.12	5.04
	HDD10.0	3505	547	492	503	344	207	72	19	30	106	279	406	499
	HDD18.3	6377	806	725	761	594	462	293	196	241	349	538	656	758
	CDD10.0	172	0	0	0	0	4	29	83	48	7	0	0	0
	CDD18.3	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH23.3	22	0	0	0	0	0	2	20	1	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
(14) Wind	WSAvg	4.0	4.5	4.5	5.0	4.3	4.0	4.1	3.5	3.3	3.6	3.6	3.4	4.2
(15) Precipitation	PrecAvg	843	72	59	59	44	49	67	89	77	87	79	73	79
	PrecMax	1071	126	174	143	90	119	101	169	139	183	131	139	146
	PrecMin	699	25	5	11	23	20	7	23	39	39	34	19	39
	PrecStd	110	32	36	29	15	24	24	35	31	35	26	36	32
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.8	3.3	3.3	8.5	19.5	22.7	25.8	22.7	17.6	11.1	6.7	4.2
		MCWB	1.7	1.8	1.6	4.6	10.7	13.7	17.0	15.7	12.6	8.3	5.7	3.6
	2%	DB	1.5	1.6	2.1	6.0	15.3	20.0	22.9	20.2	14.9	8.4	4.6	2.5
		MCWB	0.8	0.8	1.1	3.3	9.2	12.1	15.5	14.5	10.9	7.0	3.9	1.8
	5%	DB	0.4	0.7	1.1	4.5	11.7	17.5	20.5	17.9	12.8	6.8	2.8	1.3
		MCWB	-0.2	0.2	0.3	2.5	7.3	11.3	14.4	13.6	10.3	5.7	2.2	0.7
	10%	DB	-0.8	-0.6	0.1	3.4	9.0	15.3	18.3	15.9	11.1	5.6	1.6	0.2
		MCWB	-1.3	-1.1	-0.5	1.8	5.9	10.4	13.5	12.9	9.5	4.7	1.0	-0.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.9	2.2	2.2	5.0	11.7	15.0	17.8	16.8	13.2	9.5	6.0	3.8
		MCDB	2.4	2.7	2.7	7.7	17.2	19.5	23.4	20.8	16.1	10.2	6.4	4.1
	2%	WB	0.8	1.0	1.3	3.7	9.5	13.4	16.5	15.4	11.8	7.2	3.9	2.0
		MCDB	1.3	1.4	1.9	5.5	14.1	18.4	21.2	18.6	14.0	8.0	4.6	2.4
	5%	WB	-0.1	0.2	0.4	2.8	7.7	12.0	15.2	14.2	10.7	6.0	2.3	0.7
		MCDB	0.3	0.6	1.0	4.2	11.3	16.1	19.5	17.1	12.4	6.8	2.7	1.2
	10%	WB	-1.3	-1.1	-0.5	2.0	6.2	10.8	13.9	13.1	9.6	4.7	1.1	-0.3
		MCDB	-1.0	-0.7	0.1	3.2	8.7	14.6	17.4	15.7	11.0	5.6	1.5	0.2
(35) Mean Daily Temperature Range	MDBR		5.2	5.5	6.1	5.7	6.4	7.5	7.7	7.1	5.5	4.0	4.2	5.2
	5% DB	MCDBR	4.4	4.9	5.7	6.7	10.9	11.9	11.5	10.4	8.9	5.8	4.7	5.1
		MCWBR	4.4	4.5	5.1	4.8	6.3	6.1	5.4	5.7	5.4	4.3	4.3	4.9
	5% WB	MCDBR	4.5	4.4	5.2	5.6	10.1	10.7	10.3	9.2	7.6	5.4	4.6	5.0
		MCWBR	4.4	4.2	4.9	4.1	6.2	6.0	5.3	5.3	5.2	4.3	4.3	4.9
(40) Clear-Sky Solar Irradiance	taub		0.185	0.248	0.277	0.305	0.315	0.314	0.324	0.313	0.291	0.272	0.191	0.176
	taud		1.987	2.227	2.277	2.338	2.469	2.533	2.517	2.536	2.588	2.474	2.050	1.955
	Ebn at Noon		431	697	825	877	902	909	887	868	824	680	412	199
	Edh at Noon		27	56	81	97	94	90	89	80	62	45	24	12
(44) All-Sky Solar Radiation	RadAvg		0.15	0.65	1.96	3.81	4.61	4.82	4.66	3.53	2.04	0.86	0.23	0.07
	RadStd		0.02	0.10	0.26	0.32	0.33	0.49	0.55	0.36	0.20	0.09	0.03	0.00

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	-142	-178	N/A	N/A

Nomenclature: See separate page