

FOLLINGE, Sweden

WMO: 022310

Lat: 63.6761N

Lon: 14.6048E

Elev: 1188

StdP: 14.08

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.3	-5.8	-16.3	2.4	-11.3	-10.4	3.3	-5.4	21.2	33.3	18.2	32.9	1.2	290	0.667

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	76.8	60.8	73.2	59.9	69.4	58.3	63.8	72.4	61.6	69.4	59.7	67.0	5.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.4	81.8	66.7	58.4	76.1	65.0	56.4	70.8	63.1	29.7	72.5	28.1	69.8	26.7	67.0	70.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 18.3	15.6	13.4		-17.6	80.6	4.7	3.7	-21.0	83.3	-23.7	85.4	-26.3	87.5	-29.7	90.2	
(5)				-17.7	65.7	4.6	2.6	-21.1	67.6	-23.8	69.1	-26.3	70.5	-29.7	72.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.9	18.0	19.4	25.9	35.9	45.3	52.6	58.3	55.1	46.8	36.1	26.7	21.1		
	DBStd	16.19	11.62	11.39	8.59	6.10	7.13	6.31	6.02	5.46	5.34	6.62	8.34	11.42		
	HDD50	5409	992	857	746	422	187	40	3	13	121	433	698	897		
	HDD65	10287	1457	1277	1211	872	612	374	223	309	545	897	1148	1362		
	CDD50	619	0	0	0	1	40	118	261	172	26	1	0	0		
	CDD65	21	0	0	0	0	0	2	16	3	0	0	0	0		
	CDH74	241	0	0	0	0	7	40	163	31	0	0	0	0		
	CDH80	25	0	0	0	0	0	0	24	1	0	0	0	0		
	WSAvg	5.4	4.8	5.2	6.3	5.9	6.3	6.4	5.5	5.0	5.4	5.4	4.4	4.7		
	PrecAvg	23.4	1.6	1.1	1.3	1.3	1.7	2.4	3.5	2.9	2.2	2.0	1.9	1.6		
(15) Precipitation	PrecMax	31.1	3.5	2.8	2.2	3.5	4.2	4.7	7.4	5.5	4.3	5.7	4.0	3.8		
	PrecMin	17.2	0.3	0.0	0.4	0.1	0.3	0.3	0.8	1.3	0.8	0.8	0.6	0.4		
	PrecStd	3.9	0.8	0.6	0.5	0.7	1.0	1.2	1.9	1.1	1.0	1.1	0.8	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.1	41.6	45.9	62.4	74.6	78.0	83.3	77.9	66.3	55.9	48.3	42.5		
		MCWB	37.5	37.8	39.2	48.4	57.9	58.6	64.9	62.3	57.3	50.3	46.4	39.8		
	2%	DB	38.5	39.6	42.3	56.1	69.1	74.6	78.6	73.4	61.6	50.8	42.9	39.3		
		MCWB	35.9	36.4	37.6	45.0	53.9	57.7	62.9	61.2	54.9	47.2	41.7	36.4		
	5%	DB	35.6	37.2	39.9	50.7	64.2	69.2	74.5	69.5	58.4	48.2	39.4	37.0		
		MCWB	33.4	34.9	36.1	41.6	52.1	56.4	61.3	59.8	53.4	45.5	38.0	35.2		
	10%	DB	32.4	33.9	37.7	46.4	58.5	64.9	70.6	65.7	55.4	45.9	37.0	34.6		
		MCWB	31.0	31.9	34.4	39.6	49.3	54.4	59.6	58.2	51.2	43.6	35.9	33.2		
	0.4%	WB	38.0	38.5	40.5	48.9	58.2	63.0	67.3	65.1	58.8	51.5	46.5	40.0		
		MCDB	40.7	41.0	44.4	60.5	69.4	71.3	77.6	73.2	63.4	54.5	48.4	42.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	36.0	36.7	38.3	45.7	55.3	60.0	64.8	62.8	56.2	47.7	42.0	36.9		
		MCDB	38.2	39.1	41.9	54.9	63.6	69.0	74.0	69.8	60.0	49.7	43.0	38.6		
	5%	WB	33.7	34.9	36.5	42.8	52.4	57.6	62.8	60.8	53.9	45.8	38.3	35.3		
		MCDB	35.4	37.3	39.5	49.0	60.8	67.4	71.8	67.2	57.6	48.0	39.2	36.8		
	10%	WB	31.1	32.1	34.7	40.4	49.3	55.2	60.7	58.9	51.8	43.5	35.9	33.2		
		MCDB	32.4	33.7	37.6	45.8	56.8	63.9	68.6	65.1	54.9	45.6	36.9	34.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	11.3	13.9	14.7	16.6	16.5	17.2	16.3	13.3	10.2	8.1	10.1		
		MCDBR	10.6	10.4	13.7	23.1	25.5	23.3	23.4	21.9	18.2	13.7	10.0	9.7		
		MCWBR	9.8	8.8	10.2	13.2	12.9	11.8	11.0	11.7	12.3	10.5	9.1	8.9		
		MCDBR	10.8	10.0	13.0	20.2	21.1	20.9	20.8	19.2	16.9	12.7	9.5	9.8		
	5% WB	MCWBR	10.2	8.8	10.1	12.3	12.2	11.4	10.8	11.1	12.0	10.1	8.9	9.1		
(40) Clear-Sky Solar Irradiance	taub		0.200	0.264	0.294	0.327	0.333	0.329	0.342	0.332	0.304	0.288	N/A	N/A		
	taud		2.014	2.224	2.298	2.382	2.470	2.511	2.488	2.508	2.573	2.469	N/A	N/A		
	Ebn at Noon		131	213	255	271	280	283	275	268	256	209	N/A	N/A		
	Edh at Noon		9	18	26	30	30	29	29	26	20	15	N/A	N/A		
(44) All-Sky Solar Radiation	RadAvg		50	230	654	1192	1478	1679	1562	1161	679	288	76	23		
	RadStd		5	30	69	102	141	121	168	99	71	42	11	1		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (47 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-221	N/A	N/A	N/A

Nomenclature: See separate page