

FOLLINGE, Sweden

WMO: 022310

Lat: 63.6761N

Lon: 14.6048E

Elev: 362

StdP: 97.05

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.0	-21.0	-26.8	0.3	-24.0	-23.5	0.5	-20.8	9.5	0.7	8.1	0.5	0.5	290	0.667

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	24.9	16.0	22.9	15.5	20.8	14.6	17.7	22.5	16.5	20.8	15.4	19.4	2.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.8	11.7	19.3	14.7	10.9	18.3	13.6	10.1	17.3	51.2	22.5	47.4	21.0	44.3	19.4	21.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.0	6.0	-27.6	27.0	2.6	2.1	-29.4	28.5	-31.0	29.7	-32.4	30.8	-34.3	32.3		
(5)			-27.6	18.7	2.6	1.4	-29.5	19.8	-31.0	20.6	-32.4	21.4	-34.3	22.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.7	-7.8	-7.0	-3.4	2.2	7.4	11.4	14.6	12.8	8.2	2.3	-2.9	-6.1	(6)
(7)		DBStd	9.00	6.46	6.33	4.77	3.39	3.96	3.51	3.34	3.03	2.97	3.68	4.64	6.35	(7)
(8)		HDD10.0	3005	551	476	414	234	104	22	2	7	67	241	388	498	(8)
(9)		HDD18.3	5715	809	709	673	484	340	208	124	172	303	498	638	757	(9)
(10)		CDD10.0	344	0	0	0	1	22	66	145	96	14	1	0	0	(10)
(11)		CDD18.3	12	0	0	0	0	0	1	9	2	0	0	0	0	(11)
(12)		CDH23.3	134	0	0	0	0	4	22	91	17	0	0	0	0	(12)
(13)		CDH26.7	14	0	0	0	0	0	0	13	1	0	0	0	0	(13)
(14)	Wind	WSAvg	2.4	2.2	2.3	2.8	2.6	2.8	2.9	2.4	2.2	2.4	2.4	2.0	2.1	(14)
(15)	Precipitation	PrecAvg	595	41	29	32	32	43	61	89	73	56	51	48	40	(15)
(16)		PrecMax	790	88	71	57	89	106	120	187	139	109	146	102	97	(16)
(17)		PrecMin	436	7	0	10	3	7	8	21	34	21	20	16	11	(17)
(18)		PrecStd	98	21	16	12	18	26	30	47	29	25	29	20	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.1	5.4	7.7	16.9	23.7	25.6	28.5	25.5	19.1	13.3	9.1	5.8	(19)
(20)			MCWB	3.1	3.2	4.0	9.1	14.4	14.8	18.3	16.8	14.1	10.2	8.0	4.3	(20)
(21)		2%	DB	3.6	4.2	5.7	13.4	20.6	23.7	25.9	23.0	16.5	10.4	6.1	4.0	(21)
(22)			MCWB	2.2	2.5	3.1	7.2	12.2	14.3	17.2	16.2	12.7	8.5	5.4	2.4	(22)
(23)		5%	DB	2.0	2.9	4.4	10.4	17.9	20.7	23.6	20.8	14.7	9.0	4.1	2.8	(23)
(24)			MCWB	0.8	1.6	2.3	5.4	11.2	13.6	16.3	15.4	11.9	7.5	3.4	1.8	(24)
(25)		10%	DB	0.2	1.1	3.2	8.0	14.7	18.3	21.4	18.7	13.0	7.7	2.8	1.5	(25)
(26)			MCWB	-0.6	0.0	1.4	4.2	9.6	12.5	15.4	14.6	10.7	6.5	2.2	0.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.3	3.6	4.7	9.4	14.6	17.2	19.6	18.4	14.9	10.8	8.0	4.5	(27)
(28)			MCDWB	4.8	5.0	6.9	15.9	20.8	21.8	25.3	22.9	17.5	12.5	9.1	5.5	(28)
(29)		2%	WB	2.2	2.6	3.5	7.6	13.0	15.6	18.2	17.1	13.4	8.7	5.6	2.7	(29)
(30)			MCDWB	3.5	4.0	5.5	12.7	17.5	20.6	23.3	21.0	15.5	9.8	6.1	3.7	(30)
(31)		5%	WB	0.9	1.6	2.5	6.0	11.4	14.2	17.1	16.0	12.2	7.7	3.5	1.8	(31)
(32)			MCDWB	1.9	2.9	4.2	9.4	16.0	19.6	22.1	19.5	14.2	8.9	4.0	2.7	(32)
(33)		10%	WB	-0.5	0.1	1.5	4.7	9.6	12.9	15.9	15.0	11.0	6.4	2.2	0.7	(33)
(34)			MCDWB	0.2	1.0	3.1	7.7	13.8	17.7	20.4	18.4	12.7	7.6	2.7	1.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.0	6.3	7.7	8.2	9.2	9.2	9.5	9.0	7.4	5.6	4.5	5.6	(35)
(36)			MCDBR	5.9	5.8	7.6	12.9	14.2	13.0	13.0	12.2	10.1	7.6	5.5	5.4	(36)
(37)			MCWBR	5.4	4.9	5.7	7.3	7.2	6.6	6.1	6.5	6.8	5.8	5.1	4.9	(37)
(38)		5% WB	MCDBR	6.0	5.6	7.2	11.2	11.7	11.6	11.5	10.6	9.4	7.1	5.3	5.5	(38)
(39)			MCWBR	5.7	4.9	5.6	6.8	6.8	6.4	6.0	6.2	6.7	5.6	5.0	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.200	0.264	0.294	0.327	0.333	0.329	0.342	0.332	0.304	0.288	N/A	N/A	(40)	
(41)		taud	2.014	2.224	2.298	2.382	2.470	2.511	2.488	2.508	2.573	2.469	N/A	N/A	(41)	
(42)		Ebn at Noon	414	673	805	855	883	892	867	846	807	659	N/A	N/A	(42)	
(43)		Edh at Noon	28	57	81	94	94	92	92	83	63	46	N/A	N/A	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.16	0.72	2.06	3.76	4.66	5.29	4.92	3.66	2.14	0.91	0.24	0.07	(44)	
(45)		RadStd	0.01	0.10	0.22	0.32	0.44	0.38	0.53	0.31	0.22	0.13	0.04	0.00	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (47 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-123	N/A	N/A	N/A	

Nomenclature: See separate page