

SAXNAS V, Sweden

WMO: 022330

Lat: 64.9678N

Lon: 15.3791E

Elev: 1788

StdP: 13.77

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.5	-12.3	-22.4	1.7	-18.5	-16.3	2.4	-12.1	18.4	17.8	16.4	19.0	1.8	230	0.698

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.6	74.2	57.7	70.3	56.3	66.9	54.9	61.0	67.8	58.6	65.4	56.7	63.5	5.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.2	77.3	64.0	56.1	71.5	60.8	54.0	66.2	58.7	27.9	68.7	26.2	65.6	25.0	63.5	68.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
15.5	13.4	11.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-27.3	78.3	4.7	3.4	-30.6	80.7	-33.3	82.7	-36.0	84.7	-39.3	87.2		
			-27.5	61.5	4.4	2.2	-30.6	63.1	-33.2	64.4	-35.7	65.6	-38.9	67.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	34.0	14.4	15.5	21.7	31.6	40.4	50.4	56.3	54.1	44.7	34.2	25.0	18.3		
	DBStd	16.92	12.67	12.43	9.51	6.39	5.90	6.35	5.36	5.17	5.71	6.81	9.30	12.62		
	HDD50	6299	1104	967	878	552	307	70	7	17	174	491	751	981		
	HDD65	11328	1569	1387	1343	1002	764	438	273	339	610	956	1201	1446		
	CDD50	453	0	0	0	0	9	83	203	143	15	0	0	0		
	CDD65	5	0	0	0	0	0	0	5	0	0	0	0	0		
	CDH74	92	0	0	0	0	3	21	58	10	0	0	0	0		
	CDH80	2	0	0	0	0	0	0	2	0	0	0	0	0		
	WSAvg	5.3	5.0	5.2	5.5	5.3	5.4	5.5	5.2	4.9	5.3	5.9	4.9	5.0		
	PrecAvg	30.3	2.7	2.0	1.8	1.5	1.7	2.8	4.0	3.5	2.8	2.6	2.4	2.4		
(15) Precipitation	PrecMax	40.9	5.0	5.0	3.2	3.4	3.4	5.0	8.2	7.5	7.5	4.8	5.6	5.4		
	PrecMin	21.8	0.5	0.3	0.3	0.4	0.2	0.5	0.8	1.3	1.1	1.1	0.9	1.0		
	PrecStd	5.1	1.1	1.1	0.7	0.6	0.9	1.1	1.9	1.9	1.5	1.0	1.3	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.0	38.7	43.7	53.1	69.1	76.7	79.5	75.7	64.0	50.2	45.6	39.2		
		MCWB	36.1	36.0	36.5	42.8	53.6	55.2	63.5	58.5	53.4	45.1	42.0	36.3		
	2%	DB	36.7	36.7	39.0	48.3	61.8	72.1	75.1	72.1	58.4	47.5	41.1	37.4		
		MCWB	34.0	34.4	34.9	39.1	48.3	53.8	60.5	57.7	51.1	44.1	38.4	34.8		
	5%	DB	34.2	34.3	37.2	44.0	56.3	67.2	70.9	68.5	55.4	45.6	38.5	35.7		
		MCWB	32.1	32.0	33.9	37.0	44.9	53.1	57.4	56.7	49.8	42.8	36.4	33.2		
	10%	DB	30.7	31.8	35.3	41.1	50.9	62.3	67.3	64.8	53.0	43.6	35.8	33.7		
		MCWB	29.2	29.5	32.5	35.6	42.6	51.4	55.4	55.0	48.6	41.2	34.0	31.8		
	0.4%	WB	36.2	36.4	37.5	43.1	55.7	58.2	65.6	63.0	56.1	47.1	42.7	36.7		
		MCDB	38.3	38.3	41.6	51.7	67.8	68.4	77.5	68.4	60.1	49.1	44.8	38.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	34.2	34.6	35.7	40.2	50.0	56.3	62.7	59.7	53.1	44.8	38.9	35.1		
		MCDB	36.2	36.5	38.5	45.8	57.9	65.8	71.8	67.1	56.4	46.4	40.3	37.0		
	5%	WB	32.1	32.2	34.2	38.3	46.2	54.3	60.1	57.9	51.3	43.3	36.4	33.6		
		MCDB	34.3	34.0	36.8	42.7	53.7	64.1	66.1	65.2	54.1	45.2	38.2	35.3		
	10%	WB	29.2	29.8	32.5	36.6	43.7	52.6	57.7	56.3	49.6	41.3	34.1	31.9		
		MCDB	30.6	31.7	35.0	40.4	49.8	61.3	63.4	62.7	52.1	43.6	35.4	33.5		
	5% DB	MDBR	13.2	15.1	17.2	15.2	15.1	15.6	15.6	15.3	11.4	8.7	9.3	11.3		
		MCDBR	9.4	12.0	15.7	19.4	25.9	24.3	23.4	22.6	16.3	10.3	8.8	8.8		
		MCWBR	8.6	10.7	12.0	11.4	13.3	9.6	9.8	9.4	7.7	7.6	8.1			
		MCWBR	10.3	11.7	14.2	16.1	22.3	20.7	19.4	20.1	13.7	9.6	8.3	8.7		
(35) Mean Daily Temperature Range	5% WB	MCWBR	9.6	10.8	11.4	9.9	12.9	9.2	9.9	9.9	9.4	7.9	7.6	8.1		
	Clear-Sky Solar Irradiance	taub	0.175	0.249	0.280	0.310	0.319	0.319	0.330	0.318	0.293	0.272	0.345	0.179		
		taud	1.935	2.190	2.243	2.276	2.444	2.521	2.504	2.523	2.578	2.429	2.811	1.951		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	115	209	255	273	283	285	278	271	256	205	110	34		
		Edh at Noon	7	17	26	32	30	29	28	25	19	14	7	2		
(44) All-Sky Solar Radiation	RadStd		35	182	615	1195	1493	1580	1472	1099	604	232	58	12		
			3	37	73	98	114	134	178	113	75	28	8	1		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page