

JUNSELE, Sweden

WMO: 022430

Lat: 63.6839N

Lon: 16.9500E

Elev: 718

StdP: 14.32

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.5	-14.1	-24.2	1.5	-19.4	-18.3	2.1	-14.1	15.3	30.4	12.1	29.4	1.1	80	0.628

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	78.6	61.7	75.0	60.5	71.4	58.6	64.4	74.0	62.3	71.2	60.4	68.4	4.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.1	82.5	66.2	59.0	76.6	64.5	57.2	71.6	63.0	29.8	73.9	28.3	71.2	27.0	68.1	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.7	8.5	-25.1	82.8	5.6	3.4	-29.2	85.3	-32.5	87.3	-35.6	89.2	-39.7	91.7		
(5)			-25.4	66.8	5.6	2.7	-29.4	68.8	-32.6	70.4	-35.8	71.9	-39.8	73.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.5	14.1	16.9	25.5	35.6	45.8	54.1	59.4	56.5	48.0	36.5	26.3	18.5		
	DBStd	17.88	13.76	12.92	9.67	6.28	6.91	5.73	5.39	5.38	5.70	6.75	9.58	12.82		
	HDD50	5643	1113	926	761	433	170	22	1	8	105	419	710	975		
	HDD65	10414	1578	1346	1226	883	597	331	189	270	511	883	1160	1440		
	CDD50	728	0	0	0	0	39	144	293	208	43	1	0	0		
	CDD65	23	0	0	0	0	0	2	16	5	0	0	0	0		
	CDH74	404	0	0	0	0	21	81	233	68	1	0	0	0		
	CDH80	54	0	0	0	0	0	10	41	3	0	0	0	0		
	WSAvg	3.6	3.1	3.3	4.0	4.0	4.4	4.3	3.8	3.4	3.6	3.5	3.1	3.1		
	PrecAvg	22.6	1.5	1.1	1.1	1.3	1.5	2.2	3.4	2.6	2.2	2.0	1.9	1.7		
(15) Precipitation	PrecMax	30.2	3.3	2.6	2.4	3.1	3.2	5.9	6.7	6.7	5.6	4.6	4.4	4.0		
	PrecMin	16.2	0.2	0.2	0.1	0.2	0.4	0.5	0.8	0.4	0.6	0.7	0.5	0.3		
	PrecStd	3.7	0.7	0.6	0.6	0.7	0.7	1.1	1.6	1.5	1.0	1.0	0.9	0.7		
	PrecStd	3.7	0.7	0.6	0.6	0.7	0.7	1.1	1.6	1.5	1.0	1.0	0.9	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.8	43.6	48.0	62.0	77.1	81.3	84.9	79.7	68.8	56.0	48.9	41.5		
		MCWB	37.4	38.6	40.4	48.5	57.5	61.1	64.2	63.1	58.1	50.2	45.8	38.5		
	2%	DB	37.0	40.2	44.3	55.5	71.1	76.1	79.9	75.8	64.6	52.0	43.9	38.8		
		MCWB	35.1	36.5	38.0	44.5	55.3	59.1	62.9	61.7	56.0	48.7	42.7	36.8		
	5%	DB	33.8	36.8	41.5	51.3	65.9	71.0	76.1	72.1	61.1	49.4	40.2	36.4		
		MCWB	32.7	34.3	36.3	42.1	52.7	56.6	61.6	60.2	54.4	46.7	39.0	35.0		
	10%	DB	31.8	33.6	38.9	47.5	60.4	67.1	72.1	68.1	58.3	47.0	37.6	34.0		
		MCWB	31.0	32.0	34.8	40.0	49.8	54.9	60.0	58.8	53.1	44.5	36.6	33.0		
	0.4%	WB	37.5	39.0	41.4	49.4	59.8	63.2	67.8	66.3	60.1	52.2	46.3	39.4		
		MCDB	39.6	42.7	46.8	60.0	70.8	75.5	75.7	73.7	66.0	54.2	48.0	40.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.3	37.0	38.8	45.6	56.8	60.4	65.1	63.6	57.6	49.6	42.4	37.0		
		MCDB	36.7	39.8	43.4	53.7	68.8	71.7	74.8	71.8	62.3	51.4	43.5	38.4		
	5%	WB	32.9	34.5	36.9	43.1	53.6	58.3	63.4	61.5	55.7	47.2	39.3	35.0		
		MCDB	33.7	36.3	40.7	49.6	65.0	67.8	73.0	68.8	60.0	49.1	39.9	36.0		
	10%	WB	31.0	32.2	35.0	40.7	50.5	56.3	61.4	59.7	53.7	44.7	36.6	33.0		
		MCDB	31.7	33.4	38.6	46.5	59.3	65.0	69.8	66.5	57.4	46.8	37.4	33.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.1	15.7	18.5	18.1	20.2	19.0	18.9	18.6	16.2	12.1	9.7	12.9		
		MCDBR	13.2	14.3	17.7	25.9	30.9	27.0	26.8	25.5	21.2	15.4	10.3	12.3		
		MCWBR	12.3	11.5	12.3	15.8	16.4	12.8	11.9	12.4	13.2	11.7	9.2	11.2		
		MCDBR	13.2	13.2	16.5	23.2	29.0	23.4	22.7	20.6	18.5	13.9	10.0	11.7		
	5% WB	MCWBR	12.4	11.0	12.0	14.8	15.9	11.9	11.3	11.1	12.4	11.3	9.1	10.9		
		MCWBR	12.4	11.0	12.0	14.8	15.9	11.9	11.3	11.1	12.4	11.3	9.1	10.9		
(40) Clear-Sky Solar Irradiance	taub		0.208	0.273	0.299	0.336	0.339	0.337	0.351	0.340	0.311	0.295	0.355	0.348		
	taud		2.027	2.217	2.290	2.376	2.465	2.496	2.473	2.495	2.563	2.460	2.768	2.718		
	Ebn at Noon		128	209	253	268	278	280	272	265	253	205	122	72		
	Edh at Noon		9	18	26	30	30	30	30	27	20	15	8	5		
(44) All-Sky Solar Radiation	RadAvg		52	251	705	1220	1503	1706	1555	1177	705	299	78	23		
	RadStd		6	39	76	97	172	123	169	108	80	49	15	2		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-241	N/A	N/A	N/A

Nomenclature: See separate page