

SKAGSUDD, Sweden

WMO: 022690

Lat: 63.1881N

Lon: 19.0161E

Elev: 9

StdP: 101.21

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-18.4	-15.4	-20.9	0.6	-17.7	-18.2	0.8	-14.6	15.4	-0.3	14.2	-0.4	4.1	320	0.725

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.1	21.6	18.4	20.5	17.3	19.3	16.3	19.1	20.8	18.0	19.6	16.9	18.4	4.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.3	13.2	20.4	17.2	12.3	19.1	16.1	11.5	17.9	54.4	21.0	50.8	19.7	47.4	18.5	22.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.7	12.1	10.5	DB	-19.7	23.7	4.0	1.9	-22.6	25.0	-24.9	26.1	-27.1	27.1	-30.0	28.5	(4)
(5)			WB	-19.6	19.1	3.8	1.5	-22.3	20.2	-24.5	21.0	-26.6	21.8	-29.4	22.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.0	-3.9	-4.3	-1.7	2.2	7.2	12.0	16.0	15.1	11.2	5.6	1.3	-1.8	(6)
(7)		DBStd	7.97	5.37	5.61	4.10	2.70	3.11	2.59	2.29	2.33	2.70	3.13	4.05	4.95	(7)
(8)		HDD10.0	2322	431	401	363	236	99	9	0	1	18	138	261	366	(8)
(9)		HDD18.3	4891	689	634	621	486	346	191	79	103	213	394	511	624	(9)
(10)		CDD10.0	484	0	0	0	0	11	69	187	159	56	2	0	0	(10)
(11)		CDD18.3	12	0	0	0	0	0	1	8	3	0	0	0	0	(11)
(12)		CDH23.3	7	0	0	0	0	1	0	6	1	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.8	5.5	5.3	4.7	4.0	4.1	3.9	4.4	4.7	5.2	5.5	5.8	(14)	
(15)	Precipitation	PrecAvg	557	38	24	28	28	37	47	70	76	58	60	51	37	(15)
(16)		PrecMax	847	87	52	65	76	79	89	174	158	147	173	132	84	(16)
(17)		PrecMin	387	8	4	8	4	5	26	15	17	19	18	10	6	(17)
(18)		PrecStd	92	19	13	14	18	17	16	38	40	33	34	32	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.8	6.4	8.7	11.6	17.7	21.0	24.1	22.3	18.2	12.8	10.0	7.1	(19)
(20)			MCWB	3.6	3.7	4.9	6.7	11.9	14.4	18.8	19.0	13.9	10.6	7.3	5.3	(20)
(21)		2%	DB	4.1	4.6	6.3	9.0	15.0	18.7	22.3	21.2	16.9	11.6	8.1	5.6	(21)
(22)			MCWB	2.6	2.5	3.0	4.9	10.0	14.0	18.7	18.1	14.5	10.3	7.0	4.5	(22)
(23)		5%	DB	3.2	3.0	4.5	7.2	13.1	17.2	21.1	20.1	16.0	10.9	7.2	4.7	(23)
(24)			MCWB	2.2	1.6	2.0	4.1	8.8	13.2	17.9	17.5	13.9	9.9	6.2	3.8	(24)
(25)		10%	DB	2.4	1.9	3.0	5.8	11.7	15.8	19.9	18.9	15.1	10.1	6.3	4.0	(25)
(26)			MCWB	1.6	1.1	1.2	3.6	8.2	12.5	16.9	16.4	13.3	8.9	5.4	3.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	3.9	5.4	7.4	12.5	17.1	20.8	20.2	16.2	11.5	8.0	5.7	(27)
(28)			MCDWB	5.1	6.1	8.6	10.7	16.0	19.0	22.5	21.8	16.9	11.8	8.8	6.4	(28)
(29)		2%	WB	3.1	2.8	3.4	5.6	10.6	15.1	19.5	18.9	15.4	10.8	7.2	4.8	(29)
(30)			MCDWB	3.8	4.3	5.7	8.1	13.3	17.4	21.3	20.5	16.2	11.3	7.9	5.4	(30)
(31)		5%	WB	2.4	1.9	2.3	4.6	9.5	14.1	18.4	18.0	14.6	10.0	6.3	4.0	(31)
(32)			MCDWB	3.1	2.7	4.0	6.6	11.8	16.0	20.2	19.5	15.5	10.7	6.9	4.6	(32)
(33)		10%	WB	1.6	1.2	1.6	3.8	8.4	13.3	17.3	16.9	13.7	9.0	5.5	3.2	(33)
(34)			MCDWB	2.3	1.8	2.8	5.5	10.6	15.2	19.0	18.3	14.7	9.9	6.1	3.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.6	4.8	5.0	4.4	4.6	4.4	4.1	4.3	4.2	3.9	3.6	4.3	(35)
(36)			MCDBR	4.1	4.9	6.4	7.0	7.0	6.6	5.5	5.3	5.0	4.0	3.1	4.0	(36)
(37)			MCWBR	3.8	4.0	4.1	4.2	3.9	3.7	3.6	3.6	3.5	3.2	3.1	3.7	(37)
(38)		5% WB	MCDWR	3.8	4.4	5.6	6.4	6.1	5.1	4.4	4.0	3.8	3.1	2.9	3.7	(38)
(39)			MCWBR	3.6	3.8	3.8	4.2	3.9	3.6	3.5	3.2	3.2	3.0	3.0	3.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.233	0.291	0.313	0.352	0.352	0.348	0.367	0.358	0.327	0.312	0.373	0.346	(40)	
(41)		taud	2.074	2.214	2.295	2.350	2.453	2.498	2.467	2.486	2.554	2.424	2.701	2.605	(41)	
(42)		Ebn at Noon	395	641	785	829	865	874	844	820	782	628	368	223	(42)	
(43)		Edh at Noon	30	61	83	98	96	94	95	86	66	50	28	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.15	0.72	2.21	3.77	5.06	5.76	5.29	4.01	2.43	0.98	0.25	0.08	(44)	
(45)		RadStd	0.02	0.14	0.25	0.36	0.53	0.37	0.51	0.33	0.26	0.17	0.05	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-116	N/A	N/A	N/A

Nomenclature: See separate page