

NORSJO, Sweden

WMO: 022710

Lat: 64.9253N

Lon: 19.3744E

Elev: 310

StdP: 97.66

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.7	-24.3	-31.3	0.2	-27.8	-27.0	0.3	-24.2	7.2	-2.7	6.4	-4.0	0.3	330	0.667

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	24.5	15.9	22.6	15.3	20.7	14.4	17.5	22.0	16.4	20.8	15.3	19.3	2.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.8	11.6	18.9	14.7	10.8	17.9	13.6	10.1	16.9	50.5	22.2	47.0	20.6	44.0	19.2	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.5	5.8	5.2	-31.5	26.4	4.0	2.5	-34.4	28.2	-36.7	29.7	-39.0	31.1	-41.9	32.9		
(5)			-31.6	18.6	3.9	1.3	-34.3	19.5	-36.6	20.2	-38.7	21.0	-41.5	21.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.9	-10.0	-9.5	-4.9	0.9	7.0	11.6	14.8	12.9	7.9	1.6	-3.8	-7.1		
	DBStd	9.80	6.96	7.16	5.31	3.68	3.95	3.58	2.90	3.20	3.07	3.96	5.00	6.46		
	HDD10.0	3321	619	545	463	272	111	22	1	9	76	260	414	529		
	HDD18.3	6023	877	778	722	522	352	203	116	171	312	518	664	788		
	CDD10.0	351	0	0	0	0	18	70	150	99	13	1	0	0		
	CDD18.3	11	0	0	0	0	0	2	6	2	0	0	0	0		
	CDH23.3	115	0	0	0	0	2	32	61	20	0	0	0	0		
	CDH26.7	13	0	0	0	0	0	4	8	1	0	0	0	0		
(14) Wind	WSAvg	2.4	2.2	2.3	2.7	2.6	2.7	2.7	2.3	2.2	2.4	2.5	2.2	2.3		
(15) Precipitation	PrecAvg	613	39	31	32	33	41	62	99	74	57	51	51	44		
	PrecMax	806	70	80	64	58	73	102	189	157	127	95	101	101		
	PrecMin	464	3	6	12	10	12	22	26	21	17	18	20	9		
	PrecStd	92	14	17	14	14	17	21	38	37	29	21	23	20		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.9	5.6	7.9	15.8	23.1	26.7	27.7	25.6	18.5	12.2	7.8	4.4		
		MCWB	3.0	3.2	4.2	8.4	13.1	15.9	18.0	17.7	13.4	9.5	6.6	3.0		
	2%	DB	2.4	3.9	5.6	11.6	20.3	23.4	24.9	23.2	16.0	9.8	5.7	2.8		
		MCWB	1.2	2.0	2.5	6.2	12.3	14.5	16.2	16.1	12.4	8.1	4.8	1.8		
	5%	DB	0.7	1.8	4.1	9.1	17.3	20.7	23.0	21.1	14.3	8.4	3.7	1.6		
		MCWB	-0.1	0.3	1.5	4.6	10.5	13.6	15.9	15.6	11.1	7.0	2.9	0.9		
	10%	DB	-0.8	-0.1	2.6	7.1	14.4	18.6	21.1	18.8	12.9	7.2	2.3	0.7		
		MCWB	-1.3	-1.0	0.4	3.2	8.8	12.2	15.0	14.5	10.5	6.1	1.7	0.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.1	3.5	4.3	8.7	14.4	17.1	19.7	18.8	14.4	9.9	7.0	3.0		
		MCDB	4.7	5.3	7.3	14.8	20.7	24.3	24.6	23.4	16.4	11.1	7.9	3.8		
	2%	WB	1.3	2.1	2.9	6.7	12.8	15.5	17.9	17.3	13.0	8.4	4.9	1.9		
		MCDB	2.3	3.7	5.1	11.2	19.0	21.4	22.0	21.3	15.4	9.5	5.6	2.5		
	5%	WB	0.0	0.5	1.7	5.0	11.0	14.3	16.8	16.2	11.9	7.2	3.1	1.0		
		MCDB	0.6	1.6	3.8	8.2	16.5	19.3	21.3	19.8	13.5	8.2	3.6	1.5		
	10%	WB	-1.3	-1.0	0.5	3.7	9.2	13.0	15.8	15.0	10.9	6.1	1.7	0.1		
		MCDB	-0.8	-0.2	2.2	6.7	13.6	17.4	19.9	18.0	12.4	7.2	2.2	0.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.2	7.6	8.7	8.4	9.4	9.0	9.0	8.3	7.2	5.0	4.7	6.3		
		MCDBR	6.5	6.6	8.8	11.8	14.5	12.5	12.0	11.9	9.1	6.6	4.6	5.6		
	5% WB	MCWBR	6.0	5.6	6.4	7.1	7.7	5.9	5.5	5.9	5.0	4.1	5.3			
		MCWBR	6.6	6.3	8.4	10.9	13.8	11.5	10.7	7.9	6.1	4.4	5.5			
(40) Clear-Sky Solar Irradiance	taub	0.184	0.260	0.289	0.321	0.330	0.332	0.344	0.331	0.302	0.285	0.335	0.351			
	taud	1.957	2.197	2.258	2.348	2.486	2.505	2.486	2.513	2.577	2.444	2.735	2.771			
	Ebn at Noon	353	644	792	853	881	885	861	840	798	631	337	165			
	Edh at Noon	22	54	81	95	92	92	91	81	61	44	20	13			
(44) All-Sky Solar Radiation	RadAvg	0.13	0.74	2.27	4.02	4.82	5.23	4.82	3.65	2.14	0.85	0.20	0.04			
	RadStd	0.01	0.12	0.19	0.26	0.58	0.44	0.54	0.37	0.27	0.14	0.04	0.00			

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page