

HOLMON, Sweden

WMO: 022870

Lat: 63.792N

Lon: 20.861E

Elev: 15

StdP: 101.14

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-18.9	-15.9	-20.8	0.6	-18.6	-17.9	0.8	-15.8	14.9	-3.8	13.8	-4.3	3.3	40	0.744

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	23.3	18.8	21.2	17.6	19.8	16.5	19.6	22.4	18.2	20.6	17.1	19.2	4.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.3	21.4	17.1	12.2	19.8	16.1	11.4	18.4	56.1	22.3	51.4	20.6	48.1	19.1	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 13.3	11.5	10.2		-20.2	25.8	4.6	2.6	-23.5	27.7	-26.2	29.2	-28.8	30.6	-32.2		
(5)				-20.4	20.2	4.6	1.5	-23.7	21.3	-26.4	22.2	-29.0	23.1	-32.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.9	-4.7	-5.7	-2.7	1.9	7.2	12.1	16.4	15.6	11.3	5.7	1.7	-1.2
	DBStd	8.24	4.71	5.98	4.36	2.69	2.96	2.51	2.71	2.46	2.58	2.88	3.11	3.94
	HDD10.0	2381	455	439	394	242	96	9	0	0	17	134	249	346
	HDD18.3	4929	713	672	653	492	344	188	72	90	210	391	499	604
	CDD10.0	513	0	0	0	0	10	71	199	174	57	2	0	0
	CDD18.3	19	0	0	0	0	0	0	14	6	0	0	0	0
	CDH23.3	62	0	0	0	0	1	0	46	16	0	0	0	0
	CDH26.7	6	0	0	0	0	0	0	4	1	0	0	0	0
Wind	WSAvg	4.9	5.3	5.0	4.8	4.7	4.7	4.6	4.3	4.5	4.6	5.4	5.7	5.5
Precipitation	PrecAvg	623	52	40	35	34	41	48	61	70	56	62	67	57
	PrecMax	916	118	83	64	93	92	95	132	132	111	126	131	108
	PrecMin	412	10	3	8	8	3	15	10	12	10	6	18	13
	PrecStd	112	22	23	15	22	20	23	33	34	28	31	32	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.7	4.5	6.4	10.9	18.5	21.0	27.2	25.3	18.2	12.5	8.2	5.7
		MCWB	2.9	2.6	3.2	6.5	12.1	14.5	20.1	19.8	14.9	10.5	7.3	4.6
	2%	DB	2.8	3.0	4.5	8.9	15.2	18.8	24.4	22.0	16.8	11.3	7.6	4.8
		MCWB	2.0	1.7	2.1	5.3	10.3	13.9	19.7	18.3	14.1	10.1	6.8	4.0
	5%	DB	2.0	1.9	3.3	7.1	13.3	17.5	22.4	20.6	15.8	10.5	6.8	4.1
		MCWB	1.3	1.2	1.5	4.3	9.3	13.0	18.5	17.3	13.6	9.4	6.1	3.4
	10%	DB	1.2	1.1	2.3	5.7	11.7	16.3	20.7	19.3	14.9	9.7	5.9	3.5
		MCWB	0.6	0.6	1.0	3.4	8.4	12.4	17.4	16.4	13.1	8.6	5.2	2.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.2	2.8	3.6	7.2	12.7	15.7	21.6	21.3	16.0	11.4	7.7	5.1
		MCDB	3.4	4.1	5.7	10.1	16.9	19.0	25.0	24.3	17.4	11.8	8.0	5.4
	2%	WB	2.3	1.9	2.5	5.7	10.8	14.5	20.3	18.9	14.9	10.5	7.0	4.2
		MCDB	2.7	2.6	3.8	8.3	14.3	17.6	23.3	21.1	16.1	11.1	7.5	4.6
	5%	WB	1.4	1.3	1.9	4.6	9.7	13.7	19.1	17.8	14.1	9.6	6.2	3.6
		MCDB	1.9	1.8	2.9	6.8	12.8	16.6	21.8	19.8	15.2	10.3	6.7	4.1
	10%	WB	0.7	0.6	1.2	3.6	8.7	13.0	17.8	16.9	13.4	8.7	5.4	2.8
		MCDB	1.2	1.1	2.1	5.3	11.2	15.6	20.4	18.8	14.5	9.4	5.8	3.4
Mean Daily Temperature Range	5% DB	MDBR	4.3	5.2	5.9	5.6	6.1	6.3	6.2	5.4	4.9	3.8	3.2	3.5
		MCDBR	3.7	3.9	5.9	7.8	8.9	8.0	8.2	6.9	5.9	4.2	3.2	3.5
		MCWBR	3.6	3.4	4.2	4.9	4.9	4.3	4.0	3.9	3.7	3.4	3.0	3.3
	5% WB	MCDBR	3.7	3.6	4.9	7.4	8.3	7.1	7.1	6.0	5.0	3.6	3.1	3.5
		MCWBR	3.6	3.1	3.8	4.8	4.9	4.1	4.0	3.6	3.4	3.3	3.1	3.4
Clear-Sky Solar Irradiance	taub	0.226	0.287	0.311	0.348	0.350	0.350	0.368	0.357	0.329	0.312	0.362	0.351	
	taud	2.023	2.161	2.232	2.298	2.451	2.493	2.465	2.492	2.548	2.389	2.628	2.587	
	Ebn at Noon	359	624	775	827	864	871	840	817	773	608	333	181	
	Edh at Noon	28	61	86	102	96	94	95	84	66	50	26	16	
All-Sky Solar Radiation	RadAvg	0.13	0.70	2.20	3.82	5.14	5.80	5.30	4.01	2.34	0.88	0.21	0.06	
	RadStd	0.01	0.14	0.25	0.36	0.48	0.46	0.48	0.36	0.24	0.17	0.04	0.01	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page