

HOLMOGADDS FYR, SwedenWMO: **022880**Lat: **63.594N**Lon: **20.752E**Elev: **6**StdP: **101.25**Time Zone: **1.00 (EUC)**Period: **94-07**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.3	-15.1	-19.8	0.6	-17.1	-17.6	0.8	-14.9	17.6	-0.5	15.5	-1.1	3.6	0	0.747

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.7	21.2	17.4	20.0	17.0	18.8	16.2	18.5	20.3	17.6	19.3	16.7	18.4	3.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.7	12.7	19.6	16.7	11.9	18.8	15.8	11.2	17.8	52.3	20.5	49.5	19.3	46.8	18.5	21.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	12.3	10.9	DB	-18.7	23.0	3.7	1.2	-21.4	23.8	-23.5	24.5	-25.6	25.1	-28.2	25.9	(4)
(5)			WB	-18.8	19.2	3.5	1.1	-21.4	20.0	-23.4	20.7	-25.4	21.3	-28.0	22.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.5	-3.5	-5.4	-3.4	1.2	5.6	11.2	15.5	15.5	11.1	6.0	1.3	-1.5	(6)	
	DBStd	7.92	4.97	5.31	4.04	2.24	2.23	2.48	2.21	2.36	2.53	3.00	3.37	4.31	(7)	
	HDD10.0	2439	418	432	414	263	138	14	0	0	17	126	261	356	(8)	
	HDD18.3	5045	676	665	673	513	396	213	92	93	217	382	511	614	(9)	
	CDD10.0	446	0	0	0	0	1	51	171	171	50	2	0	0	(10)	
	CDD18.3	9	0	0	0	0	0	0	4	6	0	0	0	0	(11)	
	CDH23.3	1	0	0	0	0	0	0	1	1	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	5.1	6.0	5.8	5.0	4.5	4.2	4.2	4.0	4.4	5.1	5.9	6.5	6.0	(14)	
(15) Precipitation	PrecAvg	572	47	36	37	31	37	39	49	64	62	55	65	52	(15)	
	PrecMax	787	125	84	102	85	90	106	108	188	142	112	133	131	(16)	
	PrecMin	400	5	2	3	3	3	4	6	10	11	17	12	18	(17)	
	PrecStd	96	26	22	21	20	21	23	28	35	28	24	28	25	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.6	3.3	4.1	8.3	13.6	20.3	22.7	22.9	17.6	12.0	8.3	6.4	(19)	
		MCWB	2.5	1.5	1.8	4.7	8.6	14.6	17.8	18.7	14.9	11.0	7.1	5.6	(20)	
	2%	DB	2.9	2.3	2.6	6.2	11.3	17.7	21.2	21.4	16.5	11.3	7.5	5.2	(21)	
		MCWB	1.8	0.9	1.0	3.7	7.4	12.9	17.0	18.0	14.1	10.4	6.6	4.4	(22)	
	5%	DB	2.4	1.5	1.9	5.1	9.7	16.3	20.1	20.3	15.7	10.7	6.9	4.5	(23)	
		MCWB	1.5	0.5	0.8	3.1	6.8	12.4	16.7	17.6	13.7	9.9	6.1	3.8	(24)	
	10%	DB	1.7	0.8	1.2	4.1	8.7	15.2	19.0	19.1	14.8	10.0	6.2	3.7	(25)	
		MCWB	1.0	0.2	0.2	2.5	6.4	12.0	16.3	16.7	13.0	9.1	5.3	3.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.0	1.8	2.2	5.4	9.5	15.7	19.0	19.7	15.9	11.5	7.7	5.8	(27)	
		MCDB	3.1	2.6	3.1	7.5	11.9	18.6	21.0	21.5	16.8	11.6	8.0	6.3	(28)	
	2%	WB	2.1	1.2	1.5	4.2	8.2	13.9	18.1	19.0	14.8	10.7	6.9	4.7	(29)	
		MCDB	2.6	1.8	2.2	5.6	10.0	16.1	20.1	20.8	15.8	11.1	7.4	5.0	(30)	
	5%	WB	1.6	0.8	0.9	3.4	7.5	13.2	17.4	18.1	14.2	10.0	6.2	3.9	(31)	
		MCDB	2.1	1.2	1.6	4.7	9.0	15.3	19.4	19.6	15.3	10.6	6.8	4.3	(32)	
	10%	WB	1.1	0.3	0.4	2.7	6.8	12.5	16.7	17.2	13.3	9.2	5.3	3.1	(33)	
		MCDB	1.7	0.8	1.1	3.9	8.3	14.6	18.6	18.7	14.4	9.9	6.1	3.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.6	4.2	4.2	3.5	3.9	4.1	3.7	3.6	3.1	2.5	2.9	3.2	(35)	
		MCDBR	3.0	4.0	3.3	4.8	5.4	5.9	5.0	4.2	3.7	2.2	2.1	2.6	(36)	
	5% WB	MCWBR	2.9	3.7	2.6	3.0	3.0	3.4	3.0	2.7	3.0	2.1	2.4	2.5	(37)	
		MCWBR	2.8	3.5	3.0	4.3	4.4	4.9	4.3	4.0	3.1	2.1	2.2	2.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.230	0.288	0.312	0.350	0.351	0.350	0.369	0.358	0.331	0.314	0.367	0.351	(40)	
		taud	2.033	2.161	2.230	2.297	2.451	2.497	2.467	2.493	2.547	2.390	2.640	2.581	(41)	
	Ebn at Noon		367	626	776	826	864	871	840	817	773	611	340	190	(42)	
		Edh at Noon	29	62	87	102	96	94	95	85	66	51	26	16	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.13	0.70	2.22	3.84	5.19	5.88	5.37	4.06	2.37	0.89	0.21	0.06	(44)	
	RadStd		0.01	0.14	0.26	0.37	0.48	0.46	0.48	0.36	0.23	0.17	0.04	0.01	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (39 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page