

STORBO, Sweden

WMO: 023020

Lat: 61.8403N

Lon: 12.2880E

Elev: 2169

StdP: 13.58

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.2	-17.8	-27.5	1.3	-23.1	-21.8	1.8	-17.6	20.7	31.6	18.5	30.6	1.6	270	0.700

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.6	73.6	56.7	70.4	56.0	66.7	54.3	59.6	67.6	58.0	65.5	56.4	63.3	6.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
56.9	74.7	60.7	55.1	70.0	59.6	53.4	65.8	58.6	27.1	68.4	26.0	65.3	24.9	63.7	67.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	14.4	12.5	-31.2	77.3	3.6	4.1	-33.8	80.2	-36.0	82.6	-38.0	84.9	-40.6	87.9
			-30.9	61.2	4.9	3.0	-34.4	63.3	-37.2	65.1	-39.9	66.8	-43.5	69.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	34.0	13.6	15.0	22.6	32.6	41.9	51.2	55.7	53.5	45.1	34.9	25.1	15.7
	DBStd	17.42	13.25	11.50	10.61	6.72	6.48	6.16	4.98	5.07	5.71	7.72	9.95	14.22
	HDD50	6269	1128	980	849	521	263	55	7	23	164	469	746	1064
	HDD65	11313	1593	1400	1314	971	715	415	291	358	598	933	1196	1529
	CDD50	434	0	0	0	0	14	90	183	130	16	1	0	0
	CDD65	3	0	0	0	0	0	1	2	0	0	0	0	0
	CDH74	79	0	0	0	0	0	36	41	2	0	0	0	0
	CDH80	3	0	0	0	0	0	0	3	0	0	0	0	0
	WSAvg	5.3	4.9	4.7	5.8	5.5	6.1	5.7	5.2	4.9	5.7	5.4	4.8	4.4
	PrecAvg	25.5	1.8	1.1	1.2	1.5	2.0	2.9	3.0	3.4	2.5	2.4	2.2	1.5
(15) Precipitation	PrecMax	36.0	3.3	2.3	2.4	3.9	4.4	5.9	5.5	5.7	3.6	5.5	6.3	2.6
	PrecMin	20.9	0.4	0.2	0.3	0.2	0.4	0.3	0.9	1.2	1.1	0.6	1.0	0.2
	PrecStd	3.5	0.8	0.5	0.6	0.9	1.2	1.2	1.1	1.4	0.9	1.3	1.2	0.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.2	39.8	48.2	56.3	71.5	77.8	78.7	73.9	65.5	55.0	46.8	41.6
		MCWB	35.4	34.9	39.3	44.0	52.6	56.0	57.9	59.5	51.0	46.0	43.7	37.8
	2%	DB	36.3	36.9	43.5	52.1	64.9	73.7	74.1	70.9	61.2	51.2	43.1	39.1
		MCWB	33.6	33.9	36.7	41.6	49.7	55.4	56.9	58.4	49.8	45.0	40.6	35.8
	5%	DB	33.9	34.4	40.4	48.8	59.3	69.6	70.3	67.1	57.8	48.6	40.2	36.9
		MCWB	31.5	31.7	34.8	40.0	47.0	54.2	56.0	56.3	50.3	44.0	37.9	34.3
	10%	DB	31.7	31.6	37.4	45.2	53.9	64.7	66.4	63.4	54.8	46.3	37.4	34.1
		MCWB	29.4	29.2	33.1	38.0	44.6	52.4	55.0	55.0	48.6	42.9	35.1	31.6
	0.4%	WB	35.9	36.0	39.8	46.3	53.8	59.2	62.5	62.1	55.6	49.1	44.2	38.7
		MCDB	38.2	38.3	45.5	52.2	67.1	70.8	70.7	68.8	58.7	52.2	46.6	40.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	34.0	34.2	37.4	42.8	51.0	57.4	60.0	59.5	53.0	46.6	41.0	36.0
		MCDB	35.8	36.9	43.2	50.7	60.9	68.7	67.9	67.0	58.3	49.4	43.0	38.3
	5%	WB	31.8	31.8	35.2	40.5	48.5	55.4	58.2	58.0	51.1	44.8	38.4	34.4
		MCDB	33.6	34.0	39.6	47.4	57.0	66.1	65.1	64.6	55.3	47.8	40.1	36.9
	10%	WB	29.5	29.2	33.3	38.5	46.0	53.3	56.5	56.4	49.3	43.0	35.3	31.8
		MCDB	31.6	31.4	37.0	44.0	53.3	62.7	63.5	61.6	53.6	45.9	37.0	33.8
(35) Mean Daily Temperature Range	5% DB	MDBR	17.1	20.6	21.2	17.9	16.3	16.8	15.6	14.7	14.6	12.8	12.4	15.7
		MCDBR	13.3	17.2	20.9	24.1	27.3	26.7	22.9	21.8	20.5	16.1	12.3	13.0
		MCWBR	12.0	14.5	14.9	14.4	13.2	10.1	8.6	10.6	11.3	11.1	10.8	11.9
		MCDBR	13.4	15.8	18.5	21.1	22.9	21.9	18.0	17.8	14.1	12.5	11.4	12.7
	5% WB	MCWBR	12.5	13.7	13.4	13.1	12.2	9.2	8.8	9.9	9.8	9.7	10.3	11.9
(40) Clear-Sky Solar Irradiance	taub		0.203	0.254	0.284	0.318	0.328	0.323	0.339	0.329	0.300	0.284	0.218	N/A
	taud		2.102	2.255	2.257	2.304	2.457	2.508	2.473	2.487	2.555	2.485	2.178	N/A
	Ebn at Noon		168	233	265	277	284	287	279	272	263	224	159	N/A
	Edh at Noon		11	19	28	33	31	30	30	27	21	16	10	N/A
(44) All-Sky Solar Radiation	RadAvg		85	291	781	1322	1501	1632	1489	1154	744	331	103	45
	RadStd		10	53	71	120	130	142	187	104	87	53	23	4

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page