

HOGFJALLSHOTELLET, Sweden

WMO: 023110

Lat: 61.1583N

Lon: 13.1138E

Elev: 751

StdP: 92.62

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.0	-16.1	-21.0	0.6	-15.5	-19.0	0.8	-14.8	9.7	-0.7	8.9	-1.8	1.2	50	0.724

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	22.2	14.1	20.5	13.2	18.6	12.5	15.6	19.9	14.5	18.3	13.6	16.9	3.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.9	10.9	16.7	13.0	10.2	15.6	12.1	9.6	15.0	46.1	19.8	43.1	18.4	40.5	16.9	19.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.4	7.5	6.8	-20.3	24.7	2.7	1.7	-22.2	25.9	-23.8	26.8	-25.3	27.8	-27.3	29.0
			-20.5	16.4	2.3	1.7	-22.1	17.6	-23.5	18.6	-24.8	19.6	-26.5	20.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.5	-6.7	-6.4	-3.3	1.5	6.3	10.8	13.3	11.9	7.4	2.1	-2.2	-5.4	(6)
(7)		DBStd	8.03	4.36	4.41	4.22	3.57	3.86	3.75	3.03	2.89	3.09	3.80	4.17	4.81	(7)
(8)		HDD10.0	2999	516	459	413	254	129	31	4	13	89	246	367	477	(8)
(9)		HDD18.3	5787	774	692	671	504	374	227	160	199	328	504	617	736	(9)
(10)		CDD10.0	259	0	0	0	0	14	57	106	72	10	1	0	0	(10)
(11)		CDD18.3	4	0	0	0	0	0	2	3	0	0	0	0	0	(11)
(12)		CDH23.3	17	0	0	0	0	0	7	10	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	3.3	2.8	2.9	3.6	3.5	3.4	3.3	3.2	3.1	3.7	3.7	3.4	2.9	(14)
(15)	Precipitation	PrecAvg	743	49	32	31	43	60	85	88	101	71	72	61	48	(15)
(16)		PrecMax	1029	112	57	68	112	160	164	161	160	128	165	174	90	(16)
(17)		PrecMin	617	10	5	4	5	10	6	21	37	21	13	18	5	(17)
(18)		PrecStd	91	25	14	16	30	34	35	30	36	30	37	35	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.2	3.6	8.6	13.5	20.9	24.1	24.6	21.9	17.2	10.9	8.0	4.8	(19)
(20)			MCWB	0.9	0.5	4.1	8.2	12.1	15.0	16.1	13.6	11.3	7.5	6.4	2.6	(20)
(21)		2%	DB	1.1	1.8	6.0	11.1	17.5	22.2	22.6	20.2	15.0	9.4	5.9	3.1	(21)
(22)			MCWB	0.1	0.4	1.9	6.2	10.2	13.7	15.0	13.0	10.5	7.7	5.0	1.7	(22)
(23)		5%	DB	0.1	0.6	4.1	9.0	15.1	19.9	20.7	18.4	13.3	8.2	4.5	2.0	(23)
(24)			MCWB	-0.6	-0.6	1.2	4.9	8.8	12.2	14.0	12.6	9.8	6.7	3.7	0.8	(24)
(25)		10%	DB	-0.7	-0.5	2.4	7.2	12.5	17.5	18.8	16.6	11.8	7.2	3.2	0.8	(25)
(26)			MCWB	-1.4	-1.5	0.2	3.6	7.3	11.3	13.2	12.1	9.1	6.0	2.5	-0.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.5	2.0	4.2	8.8	13.2	16.0	17.7	16.1	12.9	9.7	6.8	3.7	(27)
(28)			MDCB	1.7	2.5	7.8	12.2	18.1	22.1	22.7	18.8	15.9	9.9	7.4	4.0	(28)
(29)		2%	WB	0.4	0.7	2.8	6.9	11.3	14.7	16.0	14.8	11.5	8.3	5.2	2.1	(29)
(30)			MDCB	0.7	1.3	5.3	10.1	15.7	20.0	20.7	17.5	13.5	8.8	5.8	2.6	(30)
(31)		5%	WB	-0.3	-0.4	1.5	5.4	9.7	13.3	14.9	13.9	10.5	7.1	3.9	1.0	(31)
(32)			MDCB	0.1	0.4	3.4	8.0	13.7	18.2	19.0	16.0	12.3	7.7	4.5	1.7	(32)
(33)		10%	WB	-1.4	-1.4	0.4	3.9	8.3	11.8	14.0	12.9	9.7	6.1	2.6	-0.1	(33)
(34)			MDCB	-0.8	-0.6	2.0	6.5	11.6	16.5	17.7	15.5	11.3	7.0	3.1	0.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.2	4.8	5.5	6.2	7.4	7.8	7.1	6.2	5.8	4.6	3.9	4.3	(35)
(36)			MCDBR	4.1	5.2	7.2	8.7	10.3	10.2	9.7	8.5	7.4	5.6	5.1	5.1	(36)
(37)			MCWBR	4.1	4.6	4.7	5.2	5.5	5.1	4.5	3.9	4.4	4.3	4.6	4.6	(37)
(38)		5% WB	MCDBR	4.0	4.8	6.2	8.6	9.3	9.3	8.3	6.7	6.3	4.6	4.7	4.8	(38)
(39)			MCWBR	4.2	4.6	4.7	5.5	5.5	5.3	4.5	4.0	4.5	4.3	4.6	4.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.212	0.258	0.284	0.320	0.326	0.320	0.337	0.328	0.299	0.285	0.230	N/A	(40)	
(41)		taud	2.167	2.297	2.317	2.388	2.480	2.519	2.476	2.493	2.564	2.511	2.251	N/A	(41)	
(42)		Ebn at Noon	560	748	846	879	900	910	882	863	835	720	528	N/A	(42)	
(43)		Edh at Noon	35	60	84	96	95	93	95	86	67	50	32	N/A	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.28	0.94	2.48	4.01	4.70	5.25	4.74	3.69	2.42	1.09	0.34	0.16	(44)	
(45)		RadStd	0.04	0.18	0.26	0.43	0.45	0.41	0.64	0.35	0.30	0.20	0.09	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (49 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page