

KLOVSJOHOJDEN, Sweden

WMO: 023250

Lat: 62.4952N

Lon: 14.1542E

Elev: 2635

StdP: 13.35

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.4	1.7	-7.2	4.1	1.9	-3.2	5.1	6.1	31.3	31.0	28.4	29.0	6.1	350	0.777

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	71.9	57.1	68.6	55.9	65.1	54.8	59.9	67.7	58.1	65.0	56.3	62.3	7.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.0	76.5	61.5	55.2	71.4	59.9	53.5	67.1	58.6	27.5	67.9	26.2	65.0	25.0	62.1	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.1	22.9	20.2	DB	-6.2	75.8	5.1	3.9	-9.9	78.6	-12.9	80.9	-15.8	83.1	-19.5	86.0	(4)
(5)			WB	-6.4	62.6	4.9	4.3	-9.8	65.7	-12.7	68.2	-15.4	70.6	-18.9	73.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	35.3	20.0	19.9	24.2	32.9	41.7	49.6	55.0	52.3	44.2	34.3	26.4	22.5	(6)
(7)		DBStd	14.45	8.26	8.93	7.71	6.92	8.10	7.19	6.60	5.91	5.76	6.92	7.65	8.51	(7)
(8)		HDD50	5764	931	841	799	513	284	93	23	41	189	489	709	852	(8)
(9)		HDD65	10837	1396	1261	1264	962	722	465	318	397	623	953	1159	1317	(9)
(10)		CDD50	412	0	0	0	0	27	79	178	111	16	1	0	0	(10)
(11)		CDD65	11	0	0	0	0	0	1	8	2	0	0	0	0	(11)
(12)		CDH74	31	0	0	0	0	0	4	25	2	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	9.9	11.1	11.1	11.0	9.7	8.9	8.8	7.8	7.9	9.4	10.3	10.8	11.8	(14)
(15)	Precipitation	PrecAvg	26.4	1.3	1.1	1.3	1.5	2.1	3.3	3.7	3.4	2.6	2.4	1.9	1.4	(15)
(16)		PrecMax	34.5	3.0	2.2	2.4	3.2	3.6	5.7	7.4	5.5	5.9	6.1	5.3	2.4	(16)
(17)		PrecMin	19.6	0.1	0.4	0.3	0.4	0.5	0.9	1.3	1.8	1.1	0.7	0.8	0.3	(17)
(18)		PrecStd	4.2	0.7	0.5	0.6	0.7	0.9	1.2	1.7	1.2	1.3	1.6	1.1	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.3	40.9	44.4	55.2	71.0	73.9	77.0	72.8	62.5	54.7	45.8	41.1	(19)
(20)			MCWB	34.1	33.7	36.1	44.1	52.5	55.8	60.3	59.3	52.6	50.1	40.9	37.3	(20)
(21)		2%	DB	35.1	36.6	40.3	50.5	64.6	70.2	73.2	68.5	58.7	49.0	42.6	37.9	(21)
(22)			MCWB	32.7	32.3	35.3	41.2	50.8	53.8	59.3	57.7	51.2	45.1	38.3	35.6	(22)
(23)		5%	DB	33.3	34.0	37.3	46.4	59.4	65.9	69.5	64.6	55.4	46.6	39.1	35.5	(23)
(24)			MCWB	31.3	31.2	33.5	39.0	48.4	53.1	57.6	55.6	50.4	43.5	37.4	33.2	(24)
(25)		10%	DB	30.9	31.7	34.7	43.1	54.9	61.4	66.0	61.3	52.5	43.8	36.2	33.2	(25)
(26)			MCWB	28.8	29.7	31.6	37.1	46.4	51.0	56.1	54.6	48.6	41.3	34.8	31.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.0	36.0	38.0	45.9	54.8	59.3	62.9	61.4	55.3	51.3	43.1	38.6	(27)
(28)			MCDWB	36.8	38.5	41.4	53.7	65.0	67.9	72.1	68.3	59.0	53.6	44.3	39.6	(28)
(29)		2%	WB	33.2	33.2	35.8	42.2	52.3	56.3	60.7	59.2	52.8	46.2	39.6	35.7	(29)
(30)			MCDWB	34.7	35.3	39.5	48.7	61.7	64.2	69.3	65.2	56.3	48.3	41.2	37.5	(30)
(31)		5%	WB	31.6	31.4	33.8	39.7	49.8	54.1	59.0	57.3	51.0	43.9	37.3	33.6	(31)
(32)			MCDWB	33.2	33.8	36.9	45.3	58.1	63.2	67.3	62.3	54.2	45.8	39.2	35.0	(32)
(33)		10%	WB	29.3	29.6	31.7	37.6	47.0	52.3	57.3	55.5	49.1	41.7	35.0	31.5	(33)
(34)			MCDWB	30.7	31.7	34.4	42.3	54.3	61.0	64.4	60.2	52.1	43.7	36.1	32.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.5	8.1	9.0	10.4	12.8	13.9	13.1	11.4	9.7	7.5	6.5	6.9	(35)
(36)			MCDBR	7.9	9.4	10.3	13.7	18.7	18.7	16.9	15.0	13.4	11.1	8.4	9.2	(36)
(37)			MCWBR	7.1	8.0	7.5	7.8	9.4	8.8	7.7	7.6	8.1	7.9	7.0	8.7	(37)
(38)		5% WB	MCDWB	7.7	8.7	10.1	13.1	17.3	17.0	15.5	13.1	12.0	10.0	8.1	8.6	(38)
(39)			MCWBR	7.3	7.7	7.9	7.9	10.1	9.1	8.2	7.8	8.2	7.9	7.4	8.6	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.194	0.249	0.276	0.307	0.315	0.312	0.325	0.316	0.288	0.273	0.207	0.337	(40)
(41)		taud		2.105	2.304	2.364	2.450	2.509	2.545	2.513	2.528	2.592	2.512	2.178	2.892	(41)
(42)		Ebn at Noon		165	234	269	282	288	290	283	276	266	226	156	113	(42)
(43)		Edh at Noon		10	18	25	28	29	29	29	26	20	15	9	6	(43)
(44)	All-Sky Solar Radiation	RadAvg		69	264	726	1261	1486	1660	1511	1160	731	322	95	35	(44)
(45)		RadStd		6	39	66	102	136	134	184	104	83	49	17	3	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (45 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page