

HARJEDALEN SVEG, Sweden

WMO: 023270

Lat: 62.0462N

Lon: 14.4069E

Elev: 362

StdP: 97.05

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -28.1	(c) -24.4	(d) -30.6	(e) 0.2	(f) -28.0	(g) -26.7	(h) 0.3	(i) -24.4	(j) 10.1	(k) -0.7	(l) 8.5	(m) -1.3	(n) 1.3	(o) 280	(p) 0.662

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.2	(c) 25.9	(d) 16.4	(e) 23.9	(f) 15.3	(g) 21.8	(h) 14.4	(i) 17.5	(j) 23.3	(k) 16.5	(l) 21.8	(m) 15.4	(n) 20.1	(o) 3.2	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.6	11.6	18.4	14.4	10.7	17.8	13.3	10.0	17.1	50.6	23.6	47.4	21.5	44.3	20.2	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.6	7.1	6.0	-32.7	28.4	3.6	2.1	-35.3	29.9	-37.5	31.2	-39.5	32.4	-42.1	33.9
			-33.0	18.5	3.4	1.9	-35.4	19.8	-37.4	20.9	-39.3	21.9	-41.7	23.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.7	-8.7	-7.1	-3.0	2.3	7.6	11.7	15.0	12.9	8.7	2.6	-2.9	-7.2
	DBStd	9.50	7.38	6.90	5.31	3.79	4.10	3.28	3.28	3.09	3.28	3.88	5.25	7.26
	HDD10.0	3033	579	480	403	231	99	18	2	8	61	232	388	533
	HDD18.3	5713	837	713	661	479	334	199	112	170	289	488	638	792
	CDD10.0	373	0	0	0	1	24	69	157	98	22	2	0	0
	CDD18.3	12	0	0	0	0	0	1	8	2	0	0	0	0
	CDH23.3	224	0	0	0	0	12	25	152	35	0	0	0	0
	CDH26.7	30	0	0	0	0	0	3	26	2	0	0	0	0
	CDH27.7	3	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	2.4	2.1	2.3	2.7	2.5	2.7	3.0	2.5	2.3	2.4	2.3	2.1	2.1
(15) Precipitation	PrecAvg	631	36	28	33	41	49	69	90	75	64	53	50	43
	PrecMax	918	84	76	79	108	100	179	224	183	142	137	101	122
	PrecMin	456	2	6	1	4	9	10	13	21	14	10	16	5
	PrecStd	106	20	16	18	26	24	37	48	38	31	31	24	25
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.7	6.1	10.2	17.7	25.1	26.5	29.2	26.4	20.5	14.8	9.8	6.5
		MCWB	2.6	3.0	5.2	9.5	13.6	15.4	17.4	16.6	13.5	11.3	7.7	4.7
	2%	DB	3.5	4.6	7.5	14.5	21.9	23.6	26.9	24.1	18.2	12.0	7.5	4.7
		MCWB	1.8	2.1	3.6	7.8	12.7	14.5	17.2	16.0	12.8	9.1	5.9	3.0
	5%	DB	2.2	3.1	5.8	11.7	18.8	21.1	25.0	22.0	16.3	10.2	5.2	3.3
		MCWB	0.8	1.2	2.5	6.3	11.5	13.3	16.3	14.8	12.0	7.8	4.0	1.8
	10%	DB	0.7	1.7	4.4	9.3	15.9	18.8	22.7	19.7	14.6	8.7	3.6	2.1
		MCWB	-0.5	0.0	1.6	4.7	9.7	12.2	15.3	14.2	11.0	6.8	2.5	0.8
	0.4%	WB	3.1	3.6	5.7	10.3	14.9	16.9	19.3	18.4	15.0	11.7	8.1	4.9
		MCDB	4.3	5.5	9.3	15.9	21.4	23.6	25.1	22.7	18.3	13.9	9.6	6.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	2.0	2.2	4.0	8.2	13.3	15.2	18.1	16.9	13.6	9.5	6.0	3.2
		MCDB	3.2	4.1	6.9	13.7	19.9	21.0	24.5	21.2	16.8	11.3	7.4	4.4
	5%	WB	1.0	1.3	2.9	6.6	11.9	14.1	17.1	15.9	12.5	8.2	4.2	2.0
		MCDB	2.1	2.9	5.3	11.1	17.9	19.5	23.2	20.4	15.5	9.9	5.2	3.1
	10%	WB	-0.4	0.2	1.7	5.2	10.2	12.9	16.1	14.8	11.5	7.0	2.6	0.9
		MCDB	0.7	1.5	4.2	8.8	15.4	18.1	21.5	18.6	14.0	8.5	3.4	1.8
	5% DB	MDBR	8.2	8.7	10.2	10.2	11.0	10.3	11.2	10.8	9.0	7.1	5.9	7.4
		MCDBR	7.1	7.3	10.1	14.9	16.8	14.9	16.1	15.4	12.6	9.3	6.8	7.4
		MCWBR	6.2	5.8	7.0	9.0	8.8	7.2	7.3	7.8	7.5	6.9	6.0	6.7
		MCWBR	7.0	7.2	9.7	13.6	15.2	13.0	14.5	12.3	10.3	8.2	6.7	7.4
(35) Mean Daily Temperature Range	5% WB	MCWBR	6.4	6.0	7.0	8.4	8.2	6.8	7.1	6.8	6.8	6.4	6.1	6.8
		MCWBR	6.4	6.0	7.0	8.4	8.2	6.8	7.1	6.8	6.8	6.4	6.1	6.8
	Clear-Sky Solar Irradiance	taub	0.218	0.271	0.300	0.335	0.342	0.337	0.353	0.343	0.311	0.296	0.234	0.341
		taud	2.125	2.271	2.328	2.392	2.449	2.490	2.458	2.476	2.552	2.479	2.198	2.766
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	495	705	817	857	879	890	863	841	812	682	466	336
		Edh at Noon	33	60	82	95	98	96	97	87	67	50	30	20
(44) All-Sky Solar Radiation	RadStd	RadAvg	0.24	0.89	2.40	3.97	4.67	5.30	4.83	3.69	2.36	1.06	0.31	0.12
		RadStd	0.03	0.14	0.23	0.36	0.48	0.41	0.59	0.33	0.29	0.17	0.07	0.01

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (45 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page