

EDSBY, Sweden

WMO: 023380

Lat: 61.3607N

Lon: 15.7144E

Elev: 607

StdP: 14.38

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.7	-6.4	-16.1	2.3	-11.3	-10.4	3.2	-5.9	21.7	34.6	16.3	33.5	3.6	220	0.622

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.9	78.6	63.2	75.3	61.7	71.9	60.2	65.6	74.4	63.7	72.1	61.8	69.1	6.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.5	86.5	67.9	60.5	80.4	66.7	58.6	75.2	64.8	30.7	74.3	29.3	72.2	27.9	69.2	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.6	13.1	11.4	DB	-18.7	82.9	6.1	3.1	-23.1	85.1	-26.7	86.9	-30.1	88.6	-34.5	90.9	(4)
(5)			WB	-18.5	68.1	5.6	2.6	-22.6	70.0	-25.9	71.5	-29.1	72.9	-33.2	74.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	39.0	19.8	21.8	28.0	37.6	47.1	54.4	59.6	56.8	49.0	39.2	30.5	23.2	(6)
(7)		DBStd	16.02	12.08	11.37	9.39	6.07	6.57	5.70	4.79	5.46	5.86	6.98	8.51	11.98	(7)
(8)		HDD50	4793	936	791	683	374	135	21	1	8	86	341	586	831	(8)
(9)		HDD65	9509	1401	1211	1148	822	555	320	180	260	479	801	1036	1296	(9)
(10)		CDD50	777	0	0	0	2	45	152	297	219	57	5	0	0	(10)
(11)		CDD65	18	0	0	0	0	0	2	11	5	0	0	0	0	(11)
(12)		CDH74	408	0	0	0	0	20	75	223	90	0	0	0	0	(12)
(13)		CDH80	43	0	0	0	0	0	6	30	7	0	0	0	0	(13)
(14)	Wind	WSAvg	4.8	4.9	4.9	5.5	5.2	5.3	4.9	4.4	4.3	4.7	4.7	4.5	4.8	(14)
(15)	Precipitation	PrecAvg	23.5	1.4	1.1	1.0	1.3	1.9	2.7	3.3	3.0	2.0	2.1	2.0	1.5	(15)
(16)		PrecMax	37.3	2.6	2.1	2.0	3.3	3.9	5.6	9.6	5.6	5.0	5.5	5.7	3.0	(16)
(17)		PrecMin	16.6	0.3	0.4	0.1	0.3	0.6	0.9	1.3	1.4	0.8	0.0	0.6	0.2	(17)
(18)		PrecStd	4.4	0.7	0.5	0.5	0.7	0.9	1.1	1.9	1.1	1.1	1.4	1.2	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.5	44.9	53.6	65.5	77.0	80.5	83.4	80.8	70.6	58.7	51.4	47.0	(19)
(20)			MCWB	39.1	39.3	43.6	51.6	59.1	60.9	65.9	64.6	59.4	53.0	48.4	43.9	(20)
(21)		2%	DB	40.0	41.7	47.7	59.4	71.7	76.0	79.7	76.6	66.6	55.2	48.1	42.9	(21)
(22)			MCWB	37.3	37.7	40.0	48.1	56.3	60.0	64.9	63.4	57.6	50.6	45.5	40.8	(22)
(23)		5%	DB	37.6	39.3	44.1	54.7	66.7	71.8	76.1	72.5	63.0	52.7	44.6	40.3	(23)
(24)			MCWB	35.5	36.0	37.8	45.2	53.9	58.4	63.2	61.6	55.9	49.2	42.7	37.9	(24)
(25)		10%	DB	35.2	36.6	41.1	50.5	61.9	67.7	72.5	68.9	60.0	50.4	41.9	37.6	(25)
(26)			MCWB	33.4	33.9	36.1	42.6	51.1	56.7	61.6	59.8	54.3	47.5	40.3	35.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.2	40.4	44.1	53.2	60.8	64.6	68.9	67.2	61.5	54.4	48.9	44.3	(27)
(28)			MCDWB	42.2	43.3	52.2	63.4	72.3	75.0	77.3	74.1	67.8	57.2	51.0	46.6	(28)
(29)		2%	WB	37.7	38.2	41.1	48.9	57.9	61.8	66.5	64.8	59.0	52.0	45.6	40.9	(29)
(30)			MCDWB	39.5	41.2	46.5	58.2	69.2	71.2	75.6	73.1	64.5	54.2	47.7	42.7	(30)
(31)		5%	WB	35.8	36.3	38.8	45.9	54.8	59.7	64.6	63.0	57.2	49.8	42.9	38.1	(31)
(32)			MCDWB	37.5	39.0	43.3	53.1	65.0	69.1	73.6	70.3	61.9	52.1	44.4	39.8	(32)
(33)		10%	WB	33.5	34.2	36.4	43.3	52.1	57.8	62.8	61.2	55.2	47.6	40.5	35.7	(33)
(34)			MCDWB	34.9	36.4	40.7	49.3	61.0	66.5	70.5	67.5	58.9	50.1	41.8	37.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.3	15.8	18.3	19.0	20.7	19.4	19.9	19.8	18.0	13.4	10.1	11.6	(35)
(36)			MCDBR	11.1	14.3	20.2	28.6	31.3	28.7	28.5	26.4	22.7	15.6	12.0	10.8	(36)
(37)			MCWBR	9.9	11.3	13.6	17.6	17.3	14.4	14.6	14.7	14.6	11.9	10.9	9.7	(37)
(38)		5% WB	MCDWB	10.6	13.3	18.8	25.5	27.6	24.1	24.4	22.8	19.5	13.6	11.3	10.2	(38)
(39)			MCWBR	9.8	10.9	13.1	16.3	15.7	13.0	13.4	13.2	13.4	11.2	10.4	9.4	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.238	0.289	0.314	0.349	0.352	0.347	0.365	0.358	0.324	0.310	0.259	0.348	(40)
(41)		taud		2.162	2.283	2.350	2.385	2.435	2.478	2.441	2.457	2.535	2.468	2.231	2.698	(41)
(42)		Ebn at Noon		158	220	256	268	276	279	270	263	254	214	147	109	(42)
(43)		Edh at Noon		11	20	26	31	32	31	31	29	22	17	10	7	(43)
(44)	All-Sky Solar Radiation	RadAvg		83	296	797	1268	1507	1703	1567	1199	778	357	106	47	(44)
(45)		RadStd		13	54	80	128	160	126	183	111	105	59	27	5	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page