

NAVEN, Sweden

WMO: 024030

Lat: 58.700N

Lon: 13.111E

Elev: 174

StdP: 14.60

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.6	16.1	8.4	8.5	14.2	11.9	10.1	17.3	27.8	34.2	25.2	34.8	6.3	70	0.618

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	77.3	66.0	74.2	64.8	71.4	63.0	67.7	74.4	66.1	72.2	64.5	69.8	6.2	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.4	94.4	70.6	63.6	88.6	69.4	62.1	83.8	68.0	32.2	74.3	30.9	72.1	29.7	70.1	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.3	22.3	19.6	DB	6.6	82.0	9.1	2.6	0.0	83.9	-5.3	85.5	-10.4	86.9	-17.1	88.8	(4)
(5)			WB	7.1	69.8	8.4	2.2	1.0	71.4	-3.9	72.7	-8.5	73.9	-14.6	75.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	46.1	30.6	30.1	34.6	42.3	51.8	59.7	64.3	62.8	56.2	46.9	39.4	33.6	(6)
(7)		DBStd	13.34	6.60	7.29	6.00	4.74	5.35	4.59	4.53	4.02	4.27	5.23	5.26	6.96	(7)
(8)		HDD50	2862	600	558	476	234	39	0	0	0	5	123	318	509	(8)
(9)		HDD65	6971	1065	978	941	680	409	169	69	92	265	561	768	974	(9)
(10)		CDD50	1453	0	0	0	4	96	293	444	397	191	27	1	0	(10)
(11)		CDD65	86	0	0	0	0	1	12	48	24	1	0	0	0	(11)
(12)		CDH74	289	0	0	0	0	5	54	172	56	2	0	0	0	(12)
(13)		CDH80	26	0	0	0	0	0	7	16	3	0	0	0	0	(13)
(14)	Wind	WSAvg	9.2	9.9	9.5	9.2	8.4	8.3	8.4	8.2	8.4	9.3	9.9	10.4	10.3	(14)
(15)	Precipitation	PrecAvg	25.6	1.8	1.6	1.2	1.6	1.8	2.8	3.0	2.8	2.4	2.5	2.2	2.0	(15)
(16)		PrecMax	32.0	3.2	3.1	2.7	3.6	3.5	6.3	7.2	5.4	5.9	5.4	3.7	4.4	(16)
(17)		PrecMin	19.6	0.3	0.3	0.2	0.3	0.4	0.2	0.3	0.7	0.4	0.4	0.4	0.6	(17)
(18)		PrecStd	3.2	0.9	0.7	0.6	1.1	1.0	1.3	1.7	1.3	1.5	1.2	0.9	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.7	44.8	51.2	61.2	73.5	80.0	82.0	78.6	71.2	60.9	52.9	47.3	(19)
(20)			MCWB	42.5	43.0	44.3	50.1	59.4	64.8	68.2	66.6	62.0	55.7	51.5	46.2	(20)
(21)		2%	DB	41.7	42.2	46.7	55.2	68.2	74.3	78.6	75.2	67.5	57.2	50.0	45.2	(21)
(22)			MCWB	40.6	41.0	42.0	47.9	57.6	63.3	67.1	66.0	60.8	54.4	48.2	43.9	(22)
(23)		5%	DB	40.1	40.1	44.1	51.9	63.8	70.4	75.4	72.3	64.7	55.5	48.4	43.5	(23)
(24)			MCWB	39.1	38.7	40.8	45.9	55.7	60.6	65.6	64.3	59.4	53.4	47.0	42.2	(24)
(25)		10%	DB	38.8	38.5	41.8	49.5	60.3	67.5	72.2	69.9	62.5	53.9	46.7	42.0	(25)
(26)			MCWB	37.8	37.3	39.3	44.4	53.6	58.9	64.3	63.2	58.0	51.9	45.4	40.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.0	43.2	45.0	51.8	61.6	66.8	70.5	69.3	64.1	57.5	51.8	46.7	(27)
(28)			MCD B	43.4	43.9	48.5	57.8	70.5	76.7	78.4	74.9	69.1	59.7	52.4	47.1	(28)
(29)		2%	WB	41.0	41.2	42.9	48.8	58.7	64.3	68.5	67.2	62.0	55.3	48.6	44.4	(29)
(30)			MCD B	41.3	42.3	45.7	54.0	66.0	72.4	75.6	72.7	65.8	56.6	49.4	45.2	(30)
(31)		5%	WB	39.3	39.0	41.2	46.8	56.6	62.1	66.9	65.5	60.1	53.8	47.2	42.4	(31)
(32)			MCD B	39.8	39.7	43.6	50.8	62.8	68.6	73.4	70.4	63.9	55.1	48.1	43.1	(32)
(33)		10%	WB	37.8	37.6	39.6	45.0	54.6	60.2	65.3	64.0	58.5	52.2	45.7	41.1	(33)
(34)			MCD B	38.6	38.6	41.4	48.5	59.3	65.6	71.1	68.8	61.9	53.7	46.6	41.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.8	6.4	9.2	11.3	12.5	13.3	12.4	11.6	9.6	7.1	5.5	5.6	(35)
(36)			MCDBR	5.8	6.3	11.8	14.9	17.7	17.8	16.9	15.0	12.5	8.3	6.6	5.9	(36)
(37)			MCWBR	6.0	5.2	8.0	9.0	9.8	9.4	7.8	7.4	6.2	6.6	6.3	(37)	
(38)		5% WB	MCD BR	5.9	5.7	11.0	13.2	15.5	16.2	14.9	12.9	12.0	7.6	6.2	5.9	(38)
(39)			MCWBR	6.1	5.1	7.8	8.7	9.4	9.2	7.9	7.5	7.5	6.2	6.4	6.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.266	0.303	0.326	0.366	0.362	0.353	0.373	0.368	0.339	0.326	0.291	0.249	(40)	
(41)		taud	2.225	2.308	2.401	2.361	2.429	2.479	2.438	2.451	2.516	2.474	2.318	2.155	(41)	
(42)		Ebn at Noon	180	230	261	267	276	280	271	264	255	222	169	142	(42)	
(43)		Edh at Noon	14	22	27	33	33	31	32	30	24	19	13	11	(43)	
(44)	All-Sky Solar Radiation	RadAvg	106	285	771	1236	1627	1842	1643	1295	876	393	138	72	(44)	
(45)		RadStd	19	50	75	155	141	100	207	119	105	64	27	7	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (59 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page