

KARLSTAD AP, Sweden

WMO: 024180

Lat: 59.445N

Lon: 13.337E

Elev: 107

StdP: 100.04

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.1	-14.2	-19.2	0.7	-16.1	-16.5	0.9	-12.6	10.2	3.2	9.2	2.9	1.7	0	0.606

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	26.2	17.5	24.7	17.0	22.9	16.2	19.2	23.7	18.2	22.5	17.2	21.3	3.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.8	12.9	20.8	16.7	12.0	19.7	15.6	11.2	18.9	55.0	23.6	51.6	22.5	48.8	21.2	22.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.6	7.5	6.7	DB	-20.0	28.4	3.4	1.9	-22.4	29.8	-24.4	30.9	-26.3	32.0	-28.8	33.4	(4)
			WB	-20.2	20.3	3.3	1.3	-22.6	21.2	-24.6	22.0	-26.4	22.7	-28.8	23.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.3	-3.0	-2.7	0.5	5.3	10.1	14.2	16.9	15.8	11.6	6.4	2.0	-1.7	(6)
(7)		DBStd	8.03	5.20	5.01	4.04	3.40	3.64	2.69	2.72	2.68	2.95	3.64	4.01	5.55	(7)
(8)		HDD10.0	1984	404	355	296	146	42	1	0	1	18	120	241	362	(8)
(9)		HDD18.3	4409	662	588	554	390	254	128	63	88	201	370	491	620	(9)
(10)		CDD10.0	645	0	0	0	6	47	126	213	179	67	8	0	0	(10)
(11)		CDD18.3	29	0	0	0	0	1	3	17	8	0	0	0	0	(11)
(12)		CDH23.3	294	0	0	0	0	12	50	174	58	0	0	0	0	(12)
(13)		CDH26.7	37	0	0	0	0	1	6	29	2	0	0	0	0	(13)
(14)	Wind	WSAvg	3.2	3.2	3.3	3.3	3.2	3.2	3.1	2.9	2.9	3.2	3.2	3.3	3.2	(14)
(15)	Precipitation	PrecAvg	708	56	40	37	48	54	68	63	80	68	76	72	57	(15)
(16)		PrecMax	980	120	82	99	119	102	125	121	149	139	184	177	107	(16)
(17)		PrecMin	524	10	14	4	12	7	10	9	30	19	26	28	17	(17)
(18)		PrecStd	111	30	19	21	27	29	33	27	38	34	40	36	25	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.1	8.1	13.9	19.9	25.0	27.3	29.4	26.6	22.0	15.6	11.6	9.7	(19)
(20)		MCWB	5.7	5.7	7.8	11.8	15.4	17.1	18.4	18.0	16.5	12.6	10.2	8.4	(20)	
(21)		2%	DB	5.6	6.2	10.1	16.8	22.2	24.8	27.1	25.0	19.7	13.9	10.1	7.7	(21)
(22)		MCWB	4.6	4.3	5.9	10.2	13.7	15.9	17.9	17.7	15.0	11.9	9.0	6.9	(22)	
(23)		5%	DB	4.4	4.8	7.9	14.0	20.0	22.2	25.2	23.2	18.0	12.9	8.9	6.4	(23)
(24)		MCWB	3.6	3.5	4.6	8.5	12.8	14.8	17.4	17.3	14.3	11.4	8.0	5.6	(24)	
(25)		10%	DB	3.3	3.7	6.0	11.8	17.4	20.2	23.3	21.4	16.6	11.8	7.7	5.2	(25)
(26)		MCWB	2.5	2.7	3.3	7.1	11.7	13.9	16.7	16.4	13.5	10.5	7.0	4.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	6.2	8.5	13.1	17.0	18.5	20.5	17.6	13.7	10.7	8.5	(27)	
(28)		MADB	6.6	7.4	12.6	17.7	22.4	24.2	25.1	23.8	20.0	14.5	11.4	9.2	(28)	
(29)		2%	WB	4.8	4.7	6.4	10.5	15.1	17.1	19.4	19.2	16.0	12.6	9.2	7.0	(29)
(30)		MADB	5.2	5.5	9.4	15.3	19.4	22.4	24.6	22.6	18.6	13.4	9.8	7.5	(30)	
(31)		5%	WB	3.7	3.7	5.0	9.2	13.6	15.8	18.5	18.1	14.9	11.6	8.0	5.6	(31)
(32)		MADB	4.2	4.5	7.3	13.3	18.4	20.7	23.3	21.6	17.1	12.6	8.6	6.2	(32)	
(33)		10%	WB	2.7	2.7	3.8	7.8	12.2	14.9	17.5	17.1	14.0	10.7	6.9	4.5	(33)
(34)		MADB	3.2	3.5	5.5	10.8	17.0	19.0	22.0	20.4	16.1	11.6	7.5	5.0	(34)	
(35)	Mean Daily Temperature Range	MDBR	5.0	5.8	7.4	9.4	9.9	9.4	9.4	9.0	8.1	6.3	4.7	4.9	(35)	
(36)		5% DB	MADB	5.0	5.9	10.2	13.4	14.0	13.2	13.1	11.7	10.1	6.6	5.8	4.7	(36)
(37)		MCWBR	4.8	4.6	6.8	7.6	7.0	6.2	5.6	5.8	6.1	5.0	5.4	4.7	(37)	
(38)		5% WB	MADB	4.6	5.4	9.2	11.7	11.8	11.3	11.2	9.9	8.3	5.6	5.5	4.8	(38)
(39)		MCWBR	4.6	4.6	6.5	7.0	6.4	6.0	5.4	5.5	5.5	4.8	5.3	4.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.261	0.302	0.325	0.362	0.360	0.351	0.371	0.363	0.334	0.323	0.284	0.239	(40)	
(41)		taud	2.219	2.313	2.396	2.370	2.436	2.483	2.442	2.458	2.527	2.472	2.304	2.137	(41)	
(42)		Ebn at Noon	547	715	816	841	870	883	853	833	804	691	516	424	(42)	
(43)		Edh at Noon	42	66	83	101	101	99	100	92	73	57	39	30	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.30	0.88	2.43	3.82	4.97	5.74	5.13	4.03	2.69	1.19	0.40	0.21	(44)	
(45)		RadStd	0.06	0.17	0.25	0.51	0.48	0.34	0.64	0.41	0.32	0.22	0.10	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (67 neighbors)	N/A	+2.12	+2.54	N/A	N/A	N/A	-138	N/A	N/A	N/A
		+0.41	N/A	N/A	N/A	N/A	N/A	-131	N/A	N/A	N/A

Nomenclature: See separate page