

ENKOPING, Sweden

WMO: 024430

Lat: 59.656N

Lon: 17.112E

Elev: 85

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.9	(c) 3.8	(d) -7.8	(e) 3.6	(f) -3.8	(g) 0.1	(h) 5.5	(i) 4.2	(j) 15.3	(k) 34.4	(l) 14.0	(m) 34.5	(n) 0.6	(o) 320	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.8	(c) 81.7	(d) 66.2	(e) 78.3	(f) 64.0	(g) 75.1	(h) 62.5	(i) 68.4	(j) 77.8	(k) 66.2	(l) 75.6	(m) 64.3	(n) 72.5	(o) 6.4	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.8	92.2	72.1	62.8	85.8	70.1	60.8	79.8	68.1	32.7	77.7	30.9	75.4	29.5	72.5	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
13.4	11.8	10.5		-10.4	84.9	10.0	3.1	-17.6	87.2	-23.4	89.0	-29.0	90.7	-36.2	93.0	
				-8.0	69.9	10.7	3.3	-15.7	72.3	-22.0	74.3	-28.0	76.1	-35.8	78.5	
				DB												
				WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.6	25.5	26.3	32.1	41.9	51.6	58.5	63.7	60.8	53.0	43.2	36.4	29.4	(6)	(7)
	DBStd	15.12	10.07	10.01	7.96	6.49	7.21	5.81	5.38	4.89	5.49	6.34	7.20	9.84	(7)	(8)
	HDD50	3610	758	663	554	255	69	0	0	33	227	408	637		(8)	(9)
	HDD65	7878	1223	1083	1019	694	418	207	90	148	361	676	857	1102	(9)	(10)
	CDD50	1286	0	0	0	11	117	261	424	334	122	16	1	0	(10)	(11)
	CDD65	81	0	0	0	0	1	13	49	17	1	0	0	0	(11)	(12)
	CDH74	918	0	0	0	0	46	183	552	135	2	0	0	0	(12)	(13)
	CDH80	173	0	0	0	0	1	17	135	20	0	0	0	0	(13)	(14)
	WSAvg	5.0	4.8	4.8	5.3	5.3	5.4	5.2	5.0	4.6	4.6	4.9	5.2	4.9	(14)	(15)
(15) Precipitation	PrecAvg	21.5	1.3	1.1	1.0	1.3	1.5	2.4	2.6	2.6	2.0	1.9	1.9	1.5	(15)	(16)
	PrecMax	25.7	2.6	2.4	2.0	3.2	3.1	4.3	5.8	6.0	5.2	4.3	5.0	3.7	(16)	(17)
	PrecMin	16.7	0.4	0.2	0.1	0.2	0.6	0.7	0.5	0.2	0.4	0.0	0.5	0.4	(17)	(18)
	PrecStd	2.4	0.7	0.5	0.5	0.8	0.6	1.0	1.5	1.4	1.1	0.9	1.0	0.8	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.5	46.9	56.5	68.2	78.5	82.6	87.3	82.6	72.9	61.7	53.4	50.7	(19)	(20)
		MCWB	41.4	42.1	48.3	52.8	60.5	64.1	68.1	69.7	61.8	55.8	51.2	47.8	(20)	(21)
	2%	DB	41.3	43.6	50.9	63.8	74.9	79.1	84.0	77.5	68.8	58.0	50.1	47.2	(21)	(22)
		MCWB	39.3	39.5	43.7	50.1	59.1	63.4	67.3	64.8	60.0	54.3	48.3	44.9	(22)	(23)
	5%	DB	39.6	40.8	46.7	59.4	71.4	75.7	80.2	74.0	65.4	55.7	47.9	43.5	(23)	(24)
		MCWB	38.1	38.4	40.9	48.8	57.6	62.0	65.9	63.1	58.1	52.4	46.3	41.4	(24)	(25)
	10%	DB	37.1	38.6	43.0	54.7	66.7	71.4	76.4	71.2	62.9	53.4	45.9	40.9	(25)	(26)
		MCWB	35.5	36.6	38.7	45.6	55.5	59.2	64.0	61.7	56.6	50.4	44.2	39.5	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.0	43.1	48.5	54.4	63.8	67.7	71.6	71.7	63.8	57.3	51.5	48.4	(27)	(28)
		MCDB	42.9	46.5	55.6	65.5	74.4	77.5	80.2	79.9	70.1	60.3	52.8	50.2	(28)	(29)
	2%	WB	39.5	40.3	44.4	51.3	61.3	65.0	69.3	67.2	61.0	54.9	48.5	45.0	(29)	(30)
		MCDB	40.9	42.3	49.7	61.7	70.6	75.5	79.2	74.4	66.6	57.3	49.8	46.6	(30)	(31)
	5%	WB	38.0	38.6	41.5	49.1	58.4	63.0	67.4	64.9	59.2	53.1	46.4	41.5	(31)	(32)
		MCDB	39.4	40.6	45.6	58.4	68.9	73.0	77.5	71.0	64.3	55.2	47.7	42.7	(32)	(33)
	10%	WB	35.7	36.7	39.2	46.5	56.1	60.8	65.4	63.0	57.5	50.9	44.6	39.3	(33)	(34)
		MCDB	36.9	38.4	42.3	53.3	65.8	69.6	75.1	69.0	61.8	52.8	45.6	40.6	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	12.5	14.9	19.1	20.7	19.5	19.8	17.7	16.6	12.9	8.3	9.1	(35)	(36)
		MCDBR	8.5	11.9	18.7	26.8	28.4	26.7	26.5	22.2	20.0	14.4	10.1	9.7	(36)	(37)
	5% WB	MCWBR	8.1	9.2	12.8	15.6	15.4	13.6	12.0	11.3	12.5	10.8	9.2	9.2	(37)	(38)
		MCWBR	8.2	11.1	16.8	24.2	24.9	22.5	22.4	18.3	18.2	12.3	10.1	9.5	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.273	0.315	0.336	0.372	0.369	0.359	0.384	0.377	0.343	0.331	0.299	0.256	(39)	(40)
		taud	2.203	2.274	2.356	2.329	2.397	2.446	2.397	2.413	2.497	2.429	2.259	2.129	(40)	(41)
	Ebn at Noon		164	218	253	263	273	277	266	259	251	213	151	121	(41)	(42)
		Edh at Noon	13	22	27	33	33	32	33	30	24	19	13	10	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		98	301	780	1244	1608	1797	1649	1303	854	383	124	64	(43)	(44)
	RadStd		15	43	98	122	150	115	164	131	98	63	28	6	(44)	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)		+0.67	N/A	N/A	N/A	N/A	N/A	-214	-265	N/A	N/A

Nomenclature: See separate page