

FOLKARNA, Sweden

WMO: 024440

Lat: 60.167N

Lon: 16.317E

Elev: 70

StdP: 100.49

Time Zone: 1.00 (EUC)

Period: 82-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -22.8	(c) -19.2	(d) -24.8	(e) 0.4	(f) -22.6	(g) -21.2	(h) 0.6	(i) -19.0	(j) 15.3	(k) 0.8	(l) 12.3	(m) 0.7	(n) 1.0	(o) 20	(p) 0.596

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	26.9	17.5	24.9	16.6	22.9	15.5	18.5	24.7	17.5	23.0	16.4	21.5	2.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.4	11.8	20.1	15.1	10.8	19.4	14.1	10.1	18.4	52.4	24.1	49.4	22.9	46.3	21.6	21.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.9	(b) 7.2	(c) 5.5	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 9.9	(b) 7.2	(c) 5.5	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.1	-4.6	-4.6	-1.8	3.6	9.9	13.6	16.3	14.6	9.6	6.1	0.3	-2.9		
	DBStd	8.62	7.01	6.52	5.04	3.82	3.46	3.46	2.77	2.88	2.89	3.28	4.29	4.97		
	HDD10.0	2331	453	410	366	194	44	8	0	2	40	126	290	399		
	HDD18.3	4858	711	643	624	441	260	147	75	120	261	379	540	657		
	CDD10.0	537	0	0	0	4	42	114	197	146	29	5	0	0		
	CDD18.3	23	0	0	0	0	0	4	13	6	0	0	0	0		
	CDH23.3	361	0	0	0	2	22	74	195	67	2	0	0	0		
	CDH26.7	66	0	0	0	0	1	9	44	12	0	0	0	0		
(14) Wind	WSAvg	2.1	2.5	2.2	2.2	2.3	2.4	2.0	1.9	1.8	2.0	2.0	2.0	2.3		
(15) Precipitation	PrecAvg	602	40	31	30	34	42	64	74	72	55	55	56	47		
	PrecMax	763	78	65	62	92	77	122	160	158	137	140	127	86		
	PrecMin	504	7	3	5	5	12	29	16	23	6	18	22	10		
	PrecStd	65	20	15	15	21	18	27	34	32	32	30	28	20		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.9	9.3	12.7	20.9	25.9	28.1	30.8	28.5	21.2	16.0	10.6	7.8		
		MCWB	5.1	6.4	7.6	13.7	16.0	18.1	19.7	18.4	14.5	12.4	8.4	5.5		
	2%	DB	6.1	7.5	9.4	16.4	23.1	25.3	27.5	25.2	18.1	13.6	9.2	6.1		
		MCWB	3.7	5.1	5.8	9.4	14.3	16.7	17.9	17.1	12.9	11.1	6.9	4.7		
	5%	DB	4.7	5.0	6.5	12.9	19.9	23.4	25.5	22.2	16.3	12.1	7.6	4.5		
		MCWB	2.4	2.8	3.3	7.5	12.6	15.7	17.0	15.6	12.0	9.8	6.0	3.4		
	10%	DB	3.4	3.1	4.3	10.1	17.5	21.2	23.2	20.4	14.7	10.9	6.1	3.1		
		MCWB	1.8	1.9	1.8	6.0	11.2	14.3	16.0	14.7	11.0	9.2	5.0	2.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	6.9	8.2	13.4	16.2	18.6	20.5	19.2	16.2	13.6	8.9	6.1		
		MCDB	7.5	9.0	11.8	20.9	24.4	25.8	28.3	25.7	19.7	14.6	10.1	7.2		
	2%	WB	4.1	5.4	6.0	9.7	14.5	17.5	19.0	17.9	14.1	11.7	7.2	4.8		
		MCDB	5.7	7.2	9.3	14.6	21.4	24.0	25.4	23.2	17.1	13.1	8.4	6.0		
	5%	WB	2.9	3.4	3.5	8.0	13.2	16.4	17.9	16.7	12.8	10.5	6.1	3.5		
		MCDB	4.1	4.7	6.0	12.0	18.8	22.2	23.6	20.8	15.1	11.6	7.4	4.3		
	10%	WB	1.9	1.9	2.1	6.6	11.8	15.0	16.8	15.6	11.8	9.3	5.0	2.3		
		MCDB	3.3	2.9	3.7	9.6	16.6	20.1	21.9	19.6	13.9	10.5	6.0	3.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.1	7.8	8.2	8.9	10.9	10.0	10.6	9.5	8.6	6.3	4.9	5.7		
		MCDBR	5.8	6.8	9.9	14.4	15.9	14.3	15.5	13.3	10.9	7.6	5.7	6.2		
		MCWBR	5.1	5.4	6.7	8.4	8.2	6.7	6.7	6.1	6.2	5.3	4.8	5.6		
		MCDBR	5.4	5.6	8.9	12.4	14.1	13.2	12.8	11.6	9.1	5.9	4.9	5.9		
	5% WB	MCWBR	5.1	4.7	6.2	7.6	7.8	6.7	6.2	5.8	5.8	4.8	4.4	5.6		
(40) Clear-Sky Solar Irradiance	taub		0.261	0.307	0.330	0.366	0.364	0.356	0.378	0.373	0.337	0.324	0.287	0.242		
	taud		2.201	2.290	2.362	2.345	2.409	2.454	2.410	2.420	2.509	2.445	2.264	2.112		
	Ebn at Noon		516	692	801	832	863	876	843	818	794	674	476	375		
	Edh at Noon		40	66	84	103	104	101	103	95	73	57	38	28		
(44) All-Sky Solar Radiation	RadAvg		0.29	0.93	2.42	3.88	4.95	5.53	5.10	4.00	2.62	1.18	0.37	0.18		
	RadStd		0.04	0.15	0.29	0.40	0.49	0.38	0.53	0.41	0.33	0.20	0.09	0.02		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (54 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-115	N/A	N/A	N/A

Nomenclature: See separate page