

EGGEGRUND, Sweden

WMO: 024500

Lat: 60.730N

Lon: 17.558E

Elev: 4

StdP: 101.28

Time Zone: 1.00 (EUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-11.5	-9.1	-13.2	1.2	-10.9	-11.2	1.4	-8.4	16.5	-2.7	15.1	-3.1	5.0	330	0.732

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.2	23.1	19.0	21.6	18.1	20.4	17.3	19.9	22.0	18.8	20.9	17.7	19.8	4.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	13.9	21.3	17.8	12.8	20.1	16.9	12.0	19.2	57.1	22.1	53.3	21.0	50.1	19.9	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.3	12.6	11.2	DB	-13.7	25.9	4.2	1.4	-16.8	27.0	-19.2	27.8	-21.6	28.6	-24.7	29.6	(4)
(5)			WB	-13.8	20.3	3.7	1.4	-16.4	21.3	-18.6	22.1	-20.6	22.9	-23.3	24.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-1.4	-1.8	0.1	3.9	8.6	13.5	17.0	16.5	12.6	7.4	3.4	0.5	(6)	
	DBStd	7.26	3.45	3.93	3.35	2.79	2.94	2.78	2.46	2.36	2.21	2.71	2.70	3.60	(7)	
	HDD10.0	1830	355	331	307	184	63	3	0	0	4	88	198	296	(8)	
	HDD18.3	4267	613	564	566	434	302	148	57	68	173	339	448	554	(9)	
	CDD10.0	633	0	0	0	1	19	107	217	200	81	7	0	0	(10)	
	CDD18.3	28	0	0	0	0	0	2	16	9	0	0	0	0	(11)	
	CDH23.3	37	0	0	0	0	0	4	23	10	0	0	0	0	(12)	
	CDH26.7	1	0	0	0	0	0	0	1	1	0	0	0	0	(13)	
(14) Wind	WSAvg	5.6	6.7	6.3	5.6	4.9	4.8	4.7	4.7	4.8	5.2	6.2	6.7	6.9	(14)	
(15) Precipitation	PrecAvg	584	38	34	29	34	42	63	68	70	53	54	55	45	(15)	
	PrecMax	787	74	70	62	89	80	139	136	172	120	131	112	95	(16)	
	PrecMin	476	4	5	2	4	12	6	22	10	10	2	17	9	(17)	
	PrecStd	77	19	14	15	22	18	32	35	35	28	29	25	24	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.1	5.8	9.6	14.6	19.3	23.6	26.2	24.7	20.4	14.2	10.5	8.7	(19)	
		MCWB	4.7	3.7	5.2	9.2	13.1	16.4	19.8	19.3	15.9	11.8	8.9	7.3	(20)	
	2%	DB	4.6	4.5	7.1	11.4	16.1	20.8	23.5	22.6	18.2	13.0	9.1	7.1	(21)	
		MCWB	3.4	2.9	4.0	7.8	11.6	16.2	19.4	18.7	14.9	11.4	7.7	5.9	(22)	
	5%	DB	3.6	3.6	5.5	9.3	14.2	19.1	22.1	21.2	16.7	12.1	8.0	6.0	(23)	
		MCWB	2.6	2.3	3.1	6.6	10.6	15.2	18.9	18.0	14.0	10.8	7.0	4.9	(24)	
	10%	DB	2.8	2.7	4.2	7.6	12.7	17.4	20.9	19.9	15.6	11.2	7.1	5.0	(25)	
		MCWB	2.0	1.6	2.3	5.4	9.7	14.3	18.1	17.2	13.5	9.9	6.2	4.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.0	4.4	5.6	10.2	14.0	17.9	21.5	20.7	16.3	12.4	9.2	7.7	(27)	
		MCDB	5.6	5.3	8.4	13.6	18.3	20.8	23.4	22.6	19.2	13.4	10.0	8.6	(28)	
	2%	WB	3.6	3.1	4.4	8.3	12.2	16.7	20.6	19.4	15.4	11.7	7.9	6.1	(29)	
		MCDB	4.3	4.0	6.4	11.4	15.3	20.4	22.5	21.5	17.5	12.7	8.8	7.0	(30)	
	5%	WB	2.7	2.4	3.3	6.9	11.2	15.6	19.5	18.5	14.5	11.1	7.0	5.1	(31)	
		MCDB	3.4	3.3	4.9	9.1	13.7	18.4	21.6	20.5	16.2	12.1	7.7	5.8	(32)	
	10%	WB	2.1	1.7	2.5	5.7	10.1	14.7	18.4	17.7	13.8	10.0	6.3	4.2	(33)	
		MCDB	2.7	2.5	3.8	7.4	12.3	17.1	20.5	19.6	15.3	11.2	7.0	5.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.4	3.6	4.3	4.6	4.8	4.5	4.2	4.2	3.9	3.2	2.7	3.3	(35)	
		MCDBR	3.5	4.0	6.3	8.2	7.9	7.4	6.3	6.2	5.8	4.1	3.5	3.7	(36)	
	5% WB	MCWBR	3.2	3.1	4.2	5.0	4.3	3.7	3.2	3.5	3.5	3.2	3.5	3.4	(37)	
		MCWBR	3.4	3.7	5.7	8.1	7.3	6.5	5.1	4.9	5.1	3.8	3.4	3.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.265	0.310	0.331	0.365	0.366	0.357	0.381	0.373	0.340	0.326	0.288	0.365	(40)	
		taud	2.194	2.284	2.360	2.352	2.418	2.479	2.433	2.451	2.525	2.433	2.236	2.635	(41)	
	Ebn at Noon		486	676	794	830	859	873	839	816	786	659	446	336	(42)	
		Edh at Noon	38	65	83	101	102	98	101	92	72	57	37	26	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.26	0.90	2.38	3.86	4.96	5.52	5.14	4.00	2.58	1.16	0.35	0.16	(44)	
	RadStd		0.04	0.16	0.28	0.37	0.51	0.39	0.52	0.40	0.32	0.19	0.08	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (45 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-100	N/A	N/A	N/A

Nomenclature: See separate page