

STOCKHOLM ARLANDA, Sweden

WMO: 024600

Lat: 59.627N

Lon: 17.954E

Elev: 42

StdP: 100.82

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -16.1	(c) -13.2	(d) -18.2	(e) 0.8	(f) -15.6	(g) -15.5	(h) 1.0	(i) -12.4	(j) 11.9	(k) 3.2	(l) 10.7	(m) 2.7	(n) 2.0	(o) 250	(p) 0.638

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	27.4	17.9	25.6	17.3	23.9	16.4	19.5	24.3	18.5	23.1	17.5	21.9	4.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.0	20.9	16.9	12.1	20.0	15.8	11.3	19.3	55.7	24.2	52.3	22.8	49.4	22.0	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.0	(b) 8.7	(c) 7.8	(e) -19.4	(f) 29.5	(g) 3.7	(h) 2.0	(i) -22.1	(j) 31.0	(k) -24.3	(l) 32.2	(m) -26.4	(n) 33.3	(o) -29.1	(p) 34.8		
(a) 10.0	(b) 8.7	(c) 7.8	(e) -19.6	(f) 20.7	(g) 3.7	(h) 1.4	(i) -22.2	(j) 21.7	(k) -24.4	(l) 22.6	(m) -26.5	(n) 23.4	(o) -29.2	(p) 24.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-2.6	-2.6	0.4	5.4	10.4	14.7	17.8	16.6	12.1	6.8	2.3	-0.9
	DBStd	8.17	5.00	4.96	4.17	3.62	3.79	3.01	2.91	2.89	3.21	3.59	3.92	4.98
	HDD10.0	1925	392	352	298	143	42	2	0	0	16	111	230	339
	HDD18.3	4278	650	586	556	387	247	115	47	69	187	358	480	597
	CDD10.0	738	0	0	0	6	54	142	241	204	80	11	0	0
	CDD18.3	50	0	0	0	0	1	5	29	15	1	0	0	0
	CDH23.3	469	0	0	0	0	14	66	271	116	2	0	0	0
	CDH26.7	81	0	0	0	0	0	6	60	15	0	0	0	0
Wind	WSAvg	3.8	4.0	3.9	3.9	3.9	3.9	3.8	3.5	3.4	3.6	3.7	3.8	4.0
Precipitation	PrecAvg	559	39	31	27	31	38	57	65	67	52	53	51	46
	PrecMax	659	79	66	52	94	64	97	139	151	135	102	120	109
	PrecMin	440	8	3	2	4	15	17	11	4	6	25	16	10
	PrecStd	51	20	13	11	23	15	25	35	37	33	21	25	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.2	8.0	13.2	20.1	25.1	27.7	30.5	28.2	23.1	16.2	11.7	10.0
		MCWB	5.9	6.0	7.4	11.6	15.2	17.0	19.1	18.1	15.8	13.2	10.2	8.4
	2%	DB	5.9	6.1	10.5	17.1	22.7	25.2	28.2	26.2	20.9	14.5	10.1	7.9
		MCWB	4.8	4.4	5.9	9.9	13.9	16.1	18.2	18.1	15.3	12.3	8.9	6.9
	5%	DB	4.7	4.9	8.1	14.8	20.2	23.2	26.3	24.2	19.1	13.2	9.0	6.2
		MCWB	3.8	3.5	4.8	9.0	12.7	15.0	17.7	17.4	14.5	11.4	8.1	5.4
	10%	DB	3.5	3.8	6.1	12.2	17.9	21.2	24.2	22.5	17.3	12.1	7.9	5.1
		MCWB	2.7	2.6	3.6	7.1	11.2	14.3	16.9	16.5	13.7	10.5	7.1	4.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.3	6.4	8.1	12.5	16.9	18.7	21.2	21.1	17.2	14.1	10.7	8.5
		MCDB	6.7	7.4	12.1	18.4	23.3	24.7	26.5	25.3	20.6	15.6	11.4	9.5
	2%	WB	4.7	4.6	6.4	10.6	15.0	17.3	19.8	19.4	16.0	12.7	9.2	6.8
		MCDB	5.2	5.6	9.4	15.9	20.1	22.7	25.1	23.4	19.4	14.1	9.8	7.3
	5%	WB	3.7	3.6	5.1	9.2	13.4	16.1	18.8	18.4	15.2	11.9	8.0	5.5
		MCDB	4.3	4.5	7.4	13.9	18.8	21.1	23.8	22.2	18.2	13.2	8.8	6.0
	10%	WB	2.7	2.5	4.0	7.8	12.0	15.1	17.8	17.4	14.2	10.8	7.1	4.2
		MCDB	3.3	3.4	5.7	11.4	17.2	20.0	22.8	21.1	16.8	12.0	7.6	4.8
Mean Daily Temperature Range	5% DB	MDBR	4.8	5.8	7.3	9.6	10.5	9.7	9.8	9.4	8.3	6.3	4.5	4.5
		MCDBR	4.6	5.5	9.7	13.6	14.5	13.5	13.2	12.0	10.3	6.9	5.4	4.7
		MCWBR	4.4	4.5	6.3	7.7	7.4	6.3	5.3	5.2	5.6	5.0	5.0	4.4
	5% WB	MCDBR	4.4	5.0	8.7	12.4	12.5	11.4	11.0	9.9	8.9	6.3	5.0	4.3
		MCWBR	4.4	4.3	6.1	7.3	7.0	5.9	5.1	5.0	5.2	4.9	4.7	4.2
Clear-Sky Solar Irradiance	taub	0.278	0.318	0.337	0.373	0.370	0.361	0.388	0.379	0.345	0.333	0.304	0.262	
	taud	2.207	2.279	2.353	2.324	2.394	2.449	2.395	2.416	2.498	2.419	2.251	2.129	
	Ebn at Noon	511	685	796	826	858	872	836	815	788	668	469	375	
	Edh at Noon	43	69	86	106	106	102	105	96	75	60	41	31	
All-Sky Solar Radiation	RadAvg	0.29	0.88	2.39	3.97	5.22	5.83	5.39	4.25	2.74	1.20	0.38	0.19	
	RadStd	0.04	0.14	0.28	0.38	0.46	0.35	0.52	0.39	0.30	0.20	0.09	0.02	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	+1.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (51 neighbors)		+0.37	N/A	N/A	N/A	N/A	N/A	-119	-147	N/A	N/A

Nomenclature: See separate page