

SKEPPMORA, SwedenWMO: **024720**Lat: **60.1228N**Lon: **15.1228E**Elev: **787**StdP: **14.28**Time Zone: **1.00 (EUC)**Period: **01-16**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.6	(c) 2.7	(d) -7.9	(e) 3.7	(f) -0.4	(g) -2.5	(h) 4.9	(i) 5.7	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 17.4	(c) 79.9	(d) 62.4	(e) 76.3	(f) 60.7	(g) 73.1	(h) 59.2	(i) 65.2	(j) 74.8	(k) 63.3	(l) 71.3	(m) 61.6	(n) 68.9	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.2	86.0	67.0	60.3	80.4	65.9	58.5	75.3	64.5	30.5	75.2	29.1	71.5	27.9	68.8	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) N/A	(b) N/A	(c) N/A	(e) -5.3	(f) 85.1	(g) 7.6	(h) 2.2	(i) -10.8	(j) 86.7	(k) -15.2	(l) 88.0	(m) -19.4	(n) 89.2	(o) -24.9	(p) 90.8		
(4) N/A	(5) N/A	(6) N/A	(e) -6.4	(f) 67.2	(g) 6.5	(h) 1.4	(i) -11.1	(j) 68.2	(k) -15.0	(l) 69.1	(m) -18.6	(n) 69.8	(o) -23.4	(p) 70.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.1	23.6	25.4	31.8	40.9	49.4	57.3	61.9	59.7	51.5	41.6	34.0	26.4
	DBStd	15.16	10.05	8.75	8.04	6.12	6.07	5.94	5.08	4.78	5.49	6.92	7.50	10.39
	HDD50	3975	820	689	565	280	86	6	0	2	48	269	479	731
	HDD65	8427	1285	1109	1030	722	484	242	125	175	406	724	929	1196
	CDD50	1071	0	0	0	7	67	225	370	301	92	9	0	0
	CDD65	50	0	0	0	0	0	11	29	10	0	0	0	0
	CDH74	562	0	0	0	0	14	180	284	84	0	0	0	0
	CDH80	84	0	0	0	0	0	30	45	9	0	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	30.9	2.2	1.6	1.6	1.9	2.0	3.0	3.5	3.5	3.1	3.0	3.0	2.4
	PrecMax	43.5	5.4	4.3	3.3	4.8	4.9	9.7	8.3	9.1	6.5	7.1	6.6	6.2
	PrecMin	22.6	0.2	0.2	0.1	0.2	0.6	0.6	0.3	0.9	0.4	0.6	0.5	0.4
	PrecStd	4.8	1.2	0.9	0.9	1.1	1.0	1.9	1.6	1.8	1.5	1.7	1.4	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.2	43.6	57.8	67.4	75.8	84.0	84.6	80.7	71.2	59.5	51.3	48.1
		MCWB	39.8	38.7	44.1	50.3	58.1	63.0	64.6	64.0	58.1	52.2	48.7	45.6
	2%	DB	39.5	41.0	51.0	61.9	70.6	79.0	80.6	76.0	66.8	56.0	48.9	44.4
		MCWB	37.4	37.4	40.9	47.6	55.3	60.1	63.3	61.7	56.4	51.0	46.5	42.5
	5%	DB	37.5	38.7	45.9	57.3	66.1	74.8	77.2	73.0	63.5	53.7	46.6	41.8
		MCWB	35.8	36.0	38.2	44.9	52.5	57.4	62.1	60.8	54.7	50.2	44.4	39.8
	10%	DB	35.6	36.4	41.9	53.4	61.8	70.6	73.7	69.7	60.4	51.5	44.3	39.1
		MCWB	34.1	34.3	36.2	43.0	50.1	55.9	60.4	59.3	53.4	48.2	42.4	37.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.5	41.0	44.5	52.4	60.5	65.3	67.5	67.7	60.0	54.4	49.8	46.5
		MCDB	41.3	42.8	56.1	63.2	73.3	78.9	78.9	74.5	65.9	56.4	51.1	47.4
	2%	WB	38.2	38.6	41.7	49.0	57.1	61.9	65.6	65.0	58.2	52.4	47.1	42.8
		MCDB	39.1	40.0	49.1	58.5	65.7	74.4	76.7	71.6	64.3	54.9	48.7	44.3
	5%	WB	36.2	36.4	39.5	46.4	54.7	59.5	63.8	62.9	56.6	50.7	44.7	40.1
		MCDB	37.2	38.2	44.4	54.9	62.5	69.9	73.0	68.6	61.4	53.3	46.2	41.6
	10%	WB	34.1	34.2	37.6	44.4	52.1	57.7	62.3	61.2	55.0	49.0	42.6	37.5
		MCDB	35.3	36.0	41.1	51.4	59.5	67.1	69.8	66.6	58.9	51.4	44.1	38.9
Mean Daily Temperature Range	5% DB	MDBR	8.7	11.2	15.0	17.7	18.6	18.9	17.4	16.6	15.7	12.0	7.9	8.0
		MCDBR	8.1	12.0	20.0	25.5	26.7	26.9	24.0	22.6	19.9	13.4	10.2	8.9
		MCWBR	8.3	8.7	11.6	12.6	12.8	11.0	9.8	10.3	10.5	9.0	8.9	9.1
	5% WB	MCDBR	7.9	9.6	17.6	21.5	21.8	22.2	20.9	18.4	16.8	11.0	9.2	8.8
		MCWBR	8.3	7.7	10.5	11.3	11.7	10.4	10.1	9.9	10.1	8.4	8.6	9.2
Clear-Sky Solar Irradiance	taub	0.253	0.297	0.321	0.358	0.357	0.350	0.370	0.363	0.330	0.317	0.277	0.231	
	taud	2.207	2.305	2.371	2.365	2.427	2.470	2.428	2.442	2.524	2.468	2.277	2.110	
	Ebn at Noon	169	225	258	267	276	280	270	263	255	218	158	126	
	Edh at Noon	13	21	26	32	32	31	32	30	23	18	12	9	
All-Sky Solar Radiation	RadAvg	90	292	779	1229	1526	1734	1580	1233	815	367	115	58	
	RadStd	16	55	92	143	152	116	189	135	110	67	30	6	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-221	N/A	N/A	N/A

Nomenclature: See separate page