

FLODA, Sweden

WMO: 024760

Lat: 59.0558N

Lon: 16.3944E

Elev: 33

StdP: 100.93

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.8	-15.0	-20.9	0.6	-18.6	-17.0	0.8	-14.5	11.0	6.0	9.6	4.4	0.6	300	0.586

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	27.0	18.5	25.3	17.8	23.5	16.8	19.8	24.6	18.8	23.3	17.8	22.1	3.1	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	13.2	21.5	17.1	12.3	20.6	16.0	11.4	19.4	56.8	24.7	53.3	23.3	50.2	22.1	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.5	6.4	DB	-22.3	29.1	4.6	2.0	-25.6	30.5	-28.3	31.6	-30.9	32.7	-34.3	34.2	(4)
(5)			WB	-22.5	21.3	4.6	1.2	-25.8	22.2	-28.5	22.9	-31.1	23.6	-34.4	24.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	-2.7	-2.2	0.6	5.5	10.5	14.4	17.0	16.0	11.7	6.6	2.4	-0.9	(6)	
	DBStd	7.99	5.55	5.19	4.55	3.52	3.49	2.81	2.58	2.68	3.18	3.59	3.99	5.41	(7)	
	HDD10.0	1908	395	343	291	139	36	2	0	1	20	115	228	338	(8)	
	HDD18.3	4307	653	576	549	384	242	122	58	82	200	364	478	597	(9)	
	CDD10.0	675	0	0	0	6	52	133	218	186	71	9	1	0	(10)	
	CDD18.3	30	0	0	0	0	0	3	18	9	0	0	0	0	(11)	
	CDH23.3	414	0	0	0	0	16	65	232	100	2	0	0	0	(12)	
	CDH26.7	66	0	0	0	0	1	7	48	10	0	0	0	0	(13)	
(14) Wind	WSAvg	2.8	2.9	2.9	3.1	2.9	2.9	2.8	2.5	2.5	2.7	2.8	2.8	3.0	(14)	
(15) Precipitation	PrecAvg	598	39	34	28	36	43	62	74	73	58	52	53	46	(15)	
	PrecMax	736	76	70	59	99	83	124	169	187	156	120	123	95	(16)	
	PrecMin	433	9	13	6	5	12	11	16	3	12	1	14	12	(17)	
	PrecStd	61	18	14	12	23	20	28	33	39	38	25	26	21	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.0	8.6	14.3	20.5	25.3	27.6	30.3	27.9	23.3	16.4	12.2	10.5	(19)	
		MCWB	6.8	6.4	8.7	12.2	15.4	18.1	19.3	18.7	16.6	13.4	10.6	8.9	(20)	
	2%	DB	6.3	6.8	11.1	17.4	22.9	25.2	27.9	26.0	21.0	14.5	10.5	8.2	(21)	
		MCWB	5.1	5.0	6.6	10.6	14.4	17.2	18.9	18.5	15.8	12.4	9.3	7.1	(22)	
	5%	DB	4.9	5.4	8.8	15.0	20.6	23.3	25.9	24.1	19.1	13.2	9.2	6.8	(23)	
		MCWB	3.8	3.9	5.4	9.4	13.5	16.0	18.1	17.6	14.8	11.4	8.1	5.7	(24)	
	10%	DB	3.7	4.1	6.8	12.5	18.2	21.2	24.0	22.2	17.3	12.1	7.9	5.5	(25)	
		MCWB	2.8	2.8	4.2	7.6	12.1	15.0	17.7	16.6	13.9	10.6	7.1	4.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	6.9	8.9	13.3	17.2	19.7	21.3	20.9	18.1	14.3	11.0	9.1	(27)	
		MCDB	8.0	8.3	13.4	18.7	22.4	24.6	26.1	25.2	21.5	15.7	11.8	10.1	(28)	
	2%	WB	5.4	5.3	7.1	11.1	15.6	18.1	20.1	19.5	16.4	12.8	9.5	7.2	(29)	
		MCDB	6.1	6.5	10.4	16.1	20.5	23.2	25.3	23.6	19.9	14.0	10.4	8.0	(30)	
	5%	WB	4.0	4.1	5.8	9.8	14.1	16.7	19.2	18.4	15.4	11.8	8.2	5.8	(31)	
		MCDB	4.8	5.2	8.3	14.2	19.1	21.7	24.3	22.2	18.2	13.0	9.0	6.6	(32)	
	10%	WB	2.9	3.0	4.5	8.3	12.8	15.6	18.2	17.5	14.4	10.7	7.2	4.6	(33)	
		MCDB	3.6	4.1	6.5	11.8	17.6	19.9	23.0	21.1	16.9	11.9	7.8	5.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.4	6.3	8.2	10.4	11.3	10.7	10.9	10.9	9.7	6.9	4.6	4.9	(35)	
		MCDBR	4.8	5.8	11.0	15.4	16.0	14.9	15.2	14.0	12.2	8.0	6.1	4.8	(36)	
	5% WB	MCWBR	4.5	4.6	7.2	9.2	8.7	7.7	7.4	7.3	7.5	6.0	5.4	4.5	(37)	
		MCWBR	4.7	5.3	10.1	13.6	13.0	12.9	11.6	11.0	7.1	5.9	4.7	4.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.279	0.319	0.338	0.376	0.371	0.361	0.387	0.379	0.345	0.335	0.306	0.264	(40)	
		taud	2.224	2.287	2.356	2.317	2.396	2.447	2.394	2.414	2.493	2.424	2.279	2.156	(41)	
	Ebn at Noon		533	695	800	827	859	874	838	817	792	675	493	406	(42)	
		Edh at Noon	44	70	87	107	106	102	106	97	76	61	43	33	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.32	0.94	2.44	3.95	5.17	5.76	5.26	4.17	2.77	1.24	0.41	0.22	(44)	
	RadStd		0.05	0.15	0.28	0.39	0.45	0.31	0.51	0.40	0.32	0.20	0.09	0.03	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (59 neighbors)		+0.37	N/A	N/A	N/A	N/A	N/A	N/A	-124	-150	N/A	N/A

Nomenclature: See separate page