

SALA, Sweden

WMO: 024810

Lat: 59.9093N

Lon: 16.6843E

Elev: 190

StdP: 14.60

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.4	2.4	-7.1	3.8	-3.2	-1.2	5.2	3.1	19.0	32.6	17.3	31.6	1.1	0	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.9	81.3	65.5	77.9	64.2	74.7	62.2	68.2	77.1	66.0	74.5	64.0	71.9	4.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	93.6	71.4	62.9	86.5	69.2	60.9	80.3	67.1	32.5	77.1	30.8	74.5	29.3	72.0	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.3	14.1	12.2	DB	-11.1	84.7	6.4	2.9	-15.7	86.8	-19.4	88.5	-22.9	90.1	-27.6	92.2	(4)
			WB	-9.9	70.7	7.5	2.7	-15.2	72.7	-19.6	74.3	-23.8	75.9	-29.2	77.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.9	24.9	25.7	31.7	41.2	51.0	58.2	62.8	60.4	52.3	42.2	35.0	28.3
	DBStd	15.20	10.35	9.34	8.38	6.38	6.48	5.51	5.00	4.88	5.59	6.79	7.28	10.34
	HDD50	3792	780	681	567	273	66	5	0	1	40	256	452	671
	HDD65	8130	1245	1101	1032	714	435	213	105	158	382	708	901	1136
	CDD50	1195	0	0	0	9	96	250	396	323	109	12	0	0
	CDD65	59	0	0	0	0	0	9	36	14	0	0	0	0
	CDH74	833	0	0	0	0	36	189	445	161	2	0	0	0
	CDH80	150	0	0	0	0	1	24	104	21	0	0	0	0
Wind	WSAvg	5.1	5.1	5.1	5.6	5.4	5.6	5.1	4.8	4.4	4.9	5.1	5.2	5.1
Precipitation	PrecAvg	23.3	1.5	1.2	1.1	1.3	1.6	2.6	3.1	2.8	2.0	2.2	2.1	1.8
	PrecMax	28.6	2.9	2.4	2.2	3.5	2.9	4.4	7.0	6.6	5.2	4.6	5.1	3.5
	PrecMin	19.5	0.3	0.1	0.2	0.2	0.6	1.1	0.6	0.4	0.4	0.8	0.7	0.3
	PrecStd	2.2	0.8	0.6	0.5	0.9	0.7	1.0	1.5	1.5	1.3	1.0	1.2	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.0	46.2	58.0	69.1	78.2	83.1	87.2	82.2	73.4	60.5	52.3	50.3
		MCWB	41.8	41.9	46.9	52.7	60.2	64.5	67.8	66.4	61.2	55.5	50.3	48.0
	2%	DB	41.7	42.6	51.4	64.1	73.8	79.3	82.9	78.5	69.2	57.2	49.8	46.1
		MCWB	39.7	39.2	43.1	50.6	58.7	63.2	67.1	65.6	59.4	53.7	48.2	44.3
	5%	DB	39.4	39.9	46.8	59.2	69.5	75.5	78.9	74.8	65.3	54.9	47.2	43.0
		MCWB	38.0	37.5	40.6	48.2	56.4	60.9	65.8	63.5	57.7	52.4	45.8	41.2
	10%	DB	37.1	37.5	42.8	54.4	64.7	71.2	75.3	71.2	62.2	52.6	45.0	40.3
		MCWB	36.0	35.8	38.2	45.0	53.6	59.1	63.8	61.8	56.1	50.4	43.9	39.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.0	43.4	47.6	55.3	63.3	67.5	71.4	70.6	62.9	56.8	51.1	48.2
		MCDB	44.0	45.0	56.2	65.0	73.9	79.5	80.8	77.7	69.6	58.9	51.8	50.0
	2%	WB	40.0	39.8	43.8	51.5	60.2	64.6	68.9	67.6	60.4	54.7	48.4	44.4
		MCDB	41.1	41.7	49.6	61.9	69.7	75.6	78.1	74.9	66.5	56.2	49.5	45.8
	5%	WB	38.0	37.9	41.5	48.8	57.3	62.4	66.9	65.0	58.6	52.8	46.1	41.3
		MCDB	39.1	39.6	46.0	58.2	67.1	72.5	76.2	71.3	63.4	54.5	47.0	42.3
	10%	WB	36.1	35.8	38.9	46.0	54.9	60.4	65.0	63.2	56.9	50.8	44.0	39.1
		MCDB	37.1	37.4	42.2	52.8	63.3	69.3	73.7	69.2	61.1	52.2	44.9	40.1
Mean Daily Temperature Range	5% DB	MDBR	10.1	12.1	14.9	19.4	20.4	20.0	19.9	18.8	17.2	12.4	8.1	9.1
		MCDBR	9.3	11.6	19.7	28.5	29.5	28.5	27.2	25.1	21.8	14.2	10.4	9.3
		MCWBR	9.0	9.0	12.6	16.5	16.4	14.4	14.0	13.3	13.3	10.7	9.4	8.8
	5% WB	MCDBR	8.9	10.3	18.2	25.6	24.3	24.7	23.1	20.5	19.1	12.3	9.7	9.2
MCWBR		8.8	8.5	12.3	15.8	14.8	14.1	13.1	12.6	12.3	10.2	8.9	8.9	
Clear-Sky Solar Irradiance	taub	0.268	0.311	0.333	0.368	0.366	0.357	0.381	0.375	0.339	0.327	0.293	0.249	
	taud	2.204	2.282	2.362	2.335	2.401	2.448	2.401	2.413	2.501	2.435	2.262	2.121	
	Ebn at Noon	164	219	254	263	273	278	267	259	252	213	151	120	
	Edh at Noon	13	21	27	33	33	32	33	30	23	18	12	9	
All-Sky Solar Radiation	RadAvg	94	298	773	1238	1595	1778	1637	1290	844	379	120	60	
	RadStd	14	46	96	122	154	118	164	131	100	62	27	6	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (56 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-214	-254	N/A	N/A

Nomenclature: See separate page