

SALA, Sweden

WMO: 024810

Lat: 59.9093N

Lon: 16.6843E

Elev: 58

StdP: 100.63

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.7	-16.5	-21.7	0.5	-19.6	-18.5	0.7	-16.0	8.5	0.3	7.7	-0.2	0.5	0	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	27.4	18.6	25.5	17.9	23.7	16.8	20.1	25.0	18.9	23.6	17.8	22.2	2.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.4	21.9	17.2	12.4	20.7	16.0	11.5	19.5	57.8	25.1	53.8	23.6	50.4	22.2	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.3	6.3	5.4	-23.9	29.3	3.5	1.6	-26.5	30.4	-28.5	31.4	-30.5	32.3	-33.1	33.4		
			-23.3	21.5	4.2	1.5	-26.2	22.6	-28.7	23.5	-31.0	24.4	-34.0	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.1	-4.0	-3.5	-0.2	5.1	10.5	14.6	17.1	15.8	11.3	5.6	1.6	-2.0
	DBStd	8.45	5.75	5.19	4.66	3.55	3.60	3.06	2.78	2.71	3.10	3.77	4.05	5.75
	HDD10.0	2107	433	378	315	152	37	3	0	1	22	142	251	373
	HDD18.3	4517	692	612	573	397	242	118	58	88	212	393	501	631
	CDD10.0	664	0	0	0	5	53	139	220	179	61	7	0	0
	CDD18.3	33	0	0	0	0	0	5	20	8	0	0	0	0
	CDH23.3	463	0	0	0	0	20	105	247	89	1	0	0	0
	CDH26.7	83	0	0	0	0	1	13	58	12	0	0	0	0
Wind	WSAvg	2.3	2.3	2.3	2.5	2.4	2.5	2.3	2.1	2.0	2.2	2.3	2.3	2.3
Precipitation	PrecAvg	593	38	31	28	33	41	65	78	72	51	55	54	46
	PrecMax	727	73	61	55	90	74	112	178	168	132	117	129	90
	PrecMin	496	7	2	4	4	16	27	14	9	11	21	17	8
	PrecStd	57	20	14	13	22	17	25	38	38	32	26	30	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.2	7.9	14.4	20.6	25.7	28.4	30.6	27.9	23.0	15.9	11.3	10.2
		MCWB	5.4	5.5	8.3	11.5	15.7	18.1	19.9	19.1	16.2	13.1	10.1	8.9
	2%	DB	5.4	5.9	10.8	17.8	23.2	26.3	28.3	25.8	20.7	14.0	9.9	7.8
		MCWB	4.3	4.0	6.2	10.3	14.8	17.3	19.5	18.7	15.2	12.1	9.0	6.8
	5%	DB	4.1	4.4	8.2	15.1	20.8	24.2	26.1	23.8	18.5	12.7	8.4	6.1
		MCWB	3.3	3.0	4.8	9.0	13.5	16.1	18.8	17.5	14.3	11.4	7.7	5.1
	10%	DB	2.9	3.1	6.0	12.4	18.2	21.8	24.0	21.8	16.8	11.4	7.2	4.6
		MCWB	2.2	2.1	3.4	7.2	12.0	15.0	17.7	16.6	13.4	10.2	6.6	4.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	6.3	8.7	12.9	17.4	19.7	21.9	21.5	17.2	13.8	10.6	9.0
		MCDB	6.7	7.2	13.5	18.4	23.3	26.4	27.1	25.4	20.9	15.0	11.0	10.0
	2%	WB	4.4	4.3	6.6	10.8	15.7	18.1	20.5	19.8	15.8	12.6	9.1	6.9
		MCDB	5.1	5.4	9.8	16.6	21.0	24.2	25.6	23.8	19.2	13.4	9.7	7.7
	5%	WB	3.3	3.3	5.3	9.3	14.1	16.9	19.4	18.3	14.8	11.6	7.8	5.2
		MCDB	3.9	4.2	7.8	14.6	19.5	22.5	24.5	21.8	17.5	12.5	8.4	5.7
	10%	WB	2.3	2.1	3.8	7.8	12.7	15.8	18.3	17.3	13.8	10.4	6.7	4.0
		MCDB	2.8	3.0	5.6	11.6	17.4	20.7	23.1	20.7	16.2	11.2	7.2	4.5
Mean Daily Temperature Range	5% DB	MDBR	5.6	6.7	8.3	10.8	11.3	11.1	11.0	10.5	9.6	6.9	4.5	5.1
		MCDBR	5.2	6.4	10.9	15.9	16.4	15.8	15.1	14.0	12.1	7.9	5.8	5.2
		MCWBR	5.0	5.0	7.0	9.2	9.1	8.0	7.8	7.4	7.4	6.0	5.2	4.9
	5% WB	MCDBR	5.0	5.7	10.1	14.2	13.5	13.7	12.8	11.4	10.6	6.9	5.4	5.1
	MCWBR	4.9	4.7	6.9	8.8	8.2	7.9	7.3	7.0	6.9	5.7	5.0	4.9	
Clear-Sky Solar Irradiance	taub	0.268	0.311	0.333	0.368	0.366	0.357	0.381	0.375	0.339	0.327	0.293	0.249	
	taud	2.204	2.282	2.362	2.335	2.401	2.448	2.401	2.413	2.501	2.435	2.262	2.121	
	Ebn at Noon	516	690	800	830	862	875	841	817	793	673	476	379	
	Edh at Noon	41	67	85	104	105	102	104	96	74	58	39	29	
All-Sky Solar Radiation	RadAvg	0.30	0.94	2.44	3.90	5.03	5.61	5.16	4.07	2.66	1.20	0.38	0.19	
	RadStd	0.04	0.14	0.30	0.38	0.48	0.37	0.52	0.41	0.32	0.20	0.09	0.02	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (56 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-119	-141	N/A	N/A	

Nomenclature: See separate page