

ADELSO, Sweden

WMO: 024860

Lat: 59.3579N

Lon: 17.5213E

Elev: 6

StdP: 101.25

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.0	-12.9	-18.3	0.7	-15.8	-15.3	1.0	-12.3	9.3	1.1	8.3	1.1	1.4	300	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	27.0	19.0	25.2	17.9	23.6	17.1	20.2	24.7	19.1	23.5	18.1	22.3	3.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.5	22.1	17.5	12.5	20.9	16.4	11.7	20.1	58.0	25.0	54.3	23.7	51.2	22.2	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.4	6.5	-19.5	29.2	5.4	1.4	-23.3	30.2	-26.5	31.0	-29.5	31.8	-33.5	32.8		
(5)			-19.2	21.3	4.9	1.3	-22.8	22.2	-25.7	22.9	-28.4	23.6	-32.0	24.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.1	-2.2	-2.5	0.4	5.4	10.8	14.9	17.9	16.9	12.5	7.3	3.3	0.1		
	DBStd	8.02	5.00	4.95	4.43	3.26	3.37	2.77	2.66	2.51	2.96	3.41	3.52	4.73		
	HDD10.0	1817	379	349	299	141	31	2	0	0	11	97	202	306		
	HDD18.3	4139	638	583	557	387	234	107	42	58	174	343	452	564		
	CDD10.0	765	0	0	0	4	55	149	243	214	87	12	1	0		
	CDD18.3	46	0	0	0	0	0	4	27	13	1	0	0	0		
	CDH23.3	408	0	0	0	0	12	72	243	81	1	0	0	0		
	CDH26.7	61	0	0	0	0	0	8	44	9	0	0	0	0		
(14) Wind	WSAvg	3.3	3.7	3.4	3.2	3.1	3.1	3.2	3.0	3.0	3.3	3.6	3.8	3.8		
(15) Precipitation	PrecAvg	565	38	31	27	32	39	61	70	68	54	52	48	46		
	PrecMax	650	74	64	52	98	76	103	138	157	157	97	120	115		
	PrecMin	428	8	4	2	5	20	23	11	3	11	23	13	10		
	PrecStd	49	19	13	11	24	15	24	39	39	35	21	25	23		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.9	8.1	13.5	19.3	25.0	28.0	30.0	27.8	22.7	16.0	11.7	11.0		
		MCWB	5.9	6.0	8.0	11.1	15.2	17.6	19.9	19.5	16.7	12.9	10.5	9.2		
	2%	DB	6.1	6.1	10.1	16.6	22.3	25.3	27.9	25.5	20.6	14.6	10.2	8.5		
		MCWB	4.6	4.2	6.1	9.8	14.4	17.1	19.5	18.7	15.5	12.4	9.0	7.1		
	5%	DB	4.8	4.8	8.0	14.2	19.9	23.5	26.0	23.7	18.9	13.4	9.1	6.9		
		MCWB	3.7	3.4	4.7	8.5	13.2	16.0	18.7	17.7	14.7	11.6	8.1	5.7		
	10%	DB	3.7	3.6	6.0	12.0	17.7	21.6	24.3	22.2	17.4	12.3	8.1	5.7		
		MCWB	2.7	2.5	3.7	7.1	11.8	15.0	18.0	17.0	14.0	10.7	7.1	4.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.4	6.6	8.3	12.0	16.9	19.3	21.8	21.9	17.3	14.0	10.8	9.3		
		MCDB	7.5	7.7	12.5	17.4	23.2	25.2	26.0	25.5	21.0	15.1	11.6	10.7		
	2%	WB	5.0	4.6	6.4	10.4	15.1	17.9	20.6	19.9	16.2	12.7	9.2	7.3		
		MCDB	5.9	5.7	9.5	15.7	20.4	24.2	25.5	23.3	19.5	14.1	10.1	8.3		
	5%	WB	3.8	3.5	5.1	8.8	13.7	16.7	19.6	18.8	15.2	11.8	8.2	5.9		
		MCDB	4.8	4.6	7.5	13.4	19.0	21.8	24.5	22.2	17.9	13.1	9.0	6.6		
	10%	WB	2.7	2.6	4.0	7.5	12.5	15.6	18.6	17.8	14.4	10.9	7.2	4.7		
		MCDB	3.6	3.6	5.7	11.4	17.0	20.3	23.2	21.0	16.9	12.1	8.0	5.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	5.8	7.4	10.1	10.6	10.4	9.9	9.1	7.8	5.6	3.9	4.1		
		MCDBR	4.8	5.4	9.8	14.5	14.7	14.8	13.2	11.7	9.9	6.4	4.8	4.4		
		MCWBR	4.5	4.3	6.5	8.5	8.1	7.6	6.2	5.9	5.7	4.8	4.3	4.1		
	5% WB	MCDWR	4.7	4.9	8.7	13.0	12.7	13.0	11.6	10.1	8.7	5.8	4.6	4.4		
		MCWBR	4.6	4.0	6.0	7.8	7.5	7.1	6.0	5.7	5.4	4.7	4.2	4.1		
(40) Clear-Sky Solar Irradiance	taub		0.281	0.320	0.340	0.376	0.373	0.363	0.390	0.381	0.347	0.336	0.307	0.265		
	taud		2.212	2.276	2.351	2.320	2.393	2.448	2.395	2.414	2.494	2.419	2.259	2.138		
	Ebn at Noon		517	686	796	825	857	871	835	814	788	669	476	386		
	Edh at Noon		44	70	87	106	106	102	106	96	76	61	42	32		
(44) All-Sky Solar Radiation	RadAvg		0.32	0.95	2.46	3.95	5.13	5.73	5.25	4.16	2.73	1.22	0.40	0.21		
	RadStd		0.05	0.14	0.30	0.39	0.46	0.34	0.51	0.41	0.31	0.20	0.09	0.02		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (56 neighbors)		+0.36	N/A	N/A	N/A	N/A	N/A	-116	-145	N/A	N/A

Nomenclature: See separate page